

SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Rosehart had 12 samples collected for routine bacteriological quality testing in 2025.					
Microbiological Contaminants	Highest # of Detections (in a month)	# of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (Total Coliform Rule)	0	0	More than 5.0% of monthly samples are positive	0	Naturally present in the environment
E. Coli	0	0	(a)	0	Human and animal fecal waste
(a) Routine and repeat samples are total coliform-positive and either is E. coli-positive or system fails to take repeat samples following E. coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli.					

SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
In July of 2025, 5 samples were collected in consumers’ businesses and analyzed for lead and copper. Rosehart is required to perform this monitoring every 3 years by the Board. The following is a summary of the results:						
Lead & Copper (& reporting units)	# of samples collected	90 th percentile level detected	# of Sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (µg/l)	5	0	0	15	0.2	Corrosion of household plumbing systems; erosion of natural deposits
Copper (mg/l)	5	0.341	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (& reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (mg/l)	10/2002	44	44	none	none	Salt present in the water; generally naturally occurring
Hardness (mg/l)	10/2002	180	180	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium; usually naturally occurring

DISINFECTION BY-PRODUCTS, DISINFECTANT RESIDUALS & DISINFECTION BY-PRODUCT PRECURSORS (FEDERAL RULE)						
Chemical or Constituent (& reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
TTHMs [Total Trihalomethanes] (µg/l)	3/2024 to 9/2024	9.3	5.6 to 13	80	N/A	By-product of drinking water disinfection
HAA5 [Sum of 5 Haloacetic Acids] (µg/L)	3/2024 to 9/2024	0	0 to 0	60	N/A	By-product of drinking water disinfection
Chlorine (mg/l)	1/2025 to 12/2025	0.60	0.28 to 1.48	[4.0 (as Cl ₂)]	[4 (as Cl ₂)]	Drinking water disinfectant added for treatment

DETECTION OF UNREGULATED CONTAMINANTS				
Unregulated contaminant monitoring helps USEPA & the Board to determine where certain contaminants occur & whether the contaminants need to be regulated..				
Chemical or Constituent (& reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level
Boron (µg/l)	6/2020	160	160	1,000

MAKE WATER CONSERVATION A WAY OF LIFE

Alco Water Service

Rosehart Industrial Park Water System

System ID #CA2702121

2025 Water Quality Monitoring

CONSUMER CONFIDENCE REPORT

The Tables on this page list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. Although Alco's Rosehart Industrial Park Water System (Rosehart) had the water tested for hundreds of constituents, the following tables list only those that were detected. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of an MCL or AL is asterisked.

Abbreviations Used in the Tables:

< means “less than” N/A = Not Applicable

MFL = Million Fibers per Liter ND = Not Detectable at testing limit

NTU = Nephelometer Turbidity Unit µmhos/cm = micromhos per centimeter

pCi/L = picoCuries per liter (a measure of radiation)

µg/l = micrograms per liter or parts per billion (ppb)

mg/l = milligrams per liter or parts per million (ppm)

Definitions Used in the Tables:

- ❖ **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
- ❖ **Primary Drinking Water Standard (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
- ❖ **Secondary Drinking Water Standard (SDWS):** MCLs for contaminants that affect taste, odor or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
- ❖ **Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
- ❖ **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).
- ❖ **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- ❖ **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- ❖ **Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (& reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Gross Alpha (pCi/L)	9/13/2022	5.31	5.31	15	(0)	Erosion of natural deposits
Uranium (pCi/L)	9/13/2022	8.4	8.4	20	0.43	Erosion of natural deposits
Barium (µg/l)	7/26/2023	85.7	85.7	1,000	2,000	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium, Total (µg/l)	7/26/2023	1.5	1.5	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (mg/l)	7/26/2023	0.4	0.4	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (mg/l) (as nitrogen, N)	8/19/2025	1.5	1.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (µg/l)	7/26/2023	2.7	2.7	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)

DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD					
Chemical or Constituent (& reporting units)	Sample Date	Average Level Detected	Range of Detections	Secondary MCL	Typical Source of Contaminant
Iron (µg/l)	3/29/2012	120	120	300	Leaching from natural deposits; industrial wastes
Turbidity (NTU)	3/29/2012	1.3	1.3	5	Soil runoff
Zinc (µg/l)	6/2/2020	34	34	5,000	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/l)	3/29/2012	410	410	1,000	Runoff/leaching from natural deposits
Specific Conductance (µmhos/cm)	6/2/2020	760	760	1,600	Substances that form ions when in water; seawater influence
Chloride (mg/l)	10/30/2002	32	32	500	Runoff/leaching from natural deposits; seawater influence
Sulfate (mg/l)	10/30/2002	115	115	500	Runoff/leaching from natural deposits; industrial wastes

PFAS MONITORING Per- and polyfluoroalkyl substances (PFAS) are widely used, long lasting chemicals, components of which break down very slowly over time, and are resistant to water, grease, or stains. They have been used to make many products, including the following: cleaning products; water and stain resistant fabrics for carpets, clothing, umbrellas, tents and furniture; grease-resistant paper packaging for food; personal care products like shampoo, dental floss, nail polish and eye makeup; and other household materials like non-stick cookware. One common characteristic of concern of PFAS is that because many of them break down very slowly, they can build up in people, animals, and the environment over time. **Rosehart monitored for PFAS** in April and July of 2023 and there were NO DETECTIONS of PFAS found. As a result, Rosehart was granted a waiver for further PFAS monitoring at this time. Although Rosehart is not required to report Non-Detected constituents in its CCR, Rosehart wants its customers to know that these constituents, which are still being studied for adverse health effects, are not present in the water provided to you.

Lead and Drinking Water

Lead can cause serious health effects, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home/business plumbing. Rosehart is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in components in your plumbing. You share the responsibility for protecting yourself and your family from the lead in your plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Alco Water Service at (831) 424-0441. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>. In compliance with the EPA's Lead and Copper Rule, Rosehart has completed its Lead Service Line Inventory (LSLI) identifying potential lead service lines in its water distribution sytem. Rosehart is pleased to notify its customers that there are no lead service lines or fittings in its system. A copy of the LSLI is available for customer review by request by contacting Alco's office at (831) 424-0441.

STAGE 1 WATER USE RESTRICTIONS



- 1) DO NOT USE a hose without a shut-off nozzle.
- 2) ONLY water before 6AM or after 9:30PM for 15 minutes.
- 3) DO NOT water during, or 48 hours after, precipitation.
- 4) DO NOT allow outdoor watering to flood, pool or runoff.
- 5) DO NOT water public street medians with potable water.
- 6) DO NOT water new constructions without a drip or microspray system.
- 7) DO NOT wash a vehicle using a hose without a shut-off nozzle.
- 8) DO NOT use drinking water to wash structures, roadways, driveways, walkways, or other hard surfaced areas.
- 9) DO NOT use drinking water for construction purposes.
- 10) DO NOT use drinking water in a fountain or decorative water feature.
- 11) DO NOT fill or re-fill ornamental lakes or ponds with potable water.
- 12) DO NOT fill or re-fill residential swimming pools or spas with potable water.
- 13) Restaurants and other food service establishments can only serve water to customers on request.
- 14) Hotels & motels must allow guests to choose not to have towels and linens laundered daily & display notice of this option.
- 15) Use of fire hydrant water for any reason other than fire suppression or Utility system maintenance and operation purposes is prohibited.
- 16) Customers will be informed of leaks that are within their control and will have 4 days to make the necessary repairs satisfactory to the Utility.

Consumer Confidence Report



for 2025 water quality data
for PWS ID# CA2710001
ROSEHART INDUSTRIAL
PARK WATER SYSTEM

YOUR WATER QUALITY REPORT: It's that time of year again, when Alco's Rosehart Industrial Park Water System (Rosehart) shares important information about your water quality with you, our customers! Rosehart monitors the drinking water quality for many constituents as required by State and Federal Regulations. This Consumer Confidence Report (CCR) is a summary of the quality of the water provided to you by Rosehart and shows the results of our monitoring for the period of January 1 through December 31, 2025. There is a list of important definitions and abbreviations of reporting units included in the CCR for your convenience. If you have any questions about this information, please contact Thomas R. Adcock, Monday to Friday, 8AM to 5PM at (831) 424-0441. Any water related public meetings will be announced in water bill inserts or by direct mailing.

WATER CONSERVATION: We ask you to keep “**Making Water Conservation a California Way of Life**” by monitoring your water usage habits to conserve water whenever possible. Alco is currently at Stage 1 of its “Water Conservation and Mandatory Staged Water Use Prohibitions and Reduction Plan” to achieve the important goals set by regulators in conserving water. Come by the office and pick up a copy of the Stage 1 Water Use Restrictions to use as your guideline to responsible water usage, a summary of which is also listed on the back of this CCR. We also ask that you report any water waste or water theft, as this not only wastes a valuable and essential resource, but it results in additional costs to all ratepayers.

TALK TO ALCO: If you have any problems, questions, suggestions, or concerns, please call us during regular business hours, or leave a message after hours with our live answering service at (831) 424-0441. Also, you can visit us at our office or send us a note in the mail to Alco Water Service, 249 Williams Road, Salinas, CA 93905 or e-mail us at mail@alcowater.com. We look forward to hearing from you!

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Alco a (831) 424-0441 para asistirlo en español.

***SEE REVERSE SIDE FOR YOUR
WATER QUALITY DATA!***

Where does your water come from?



Alco Water Service's Rosehart Industrial Park Water System has 1 active water source, which is a groundwater well. The well draws from aquifers in one sub-area of the Salinas Groundwater Basin; the Pressure Area. A Source Water Assessment was performed in 2002 and a copy of the Vulnerability Summary is available upon request. The water sources are most vulnerable to high density septic systems, and to the activities of nearby businesses and agricultural areas.

Laboratory testing:

Rosehart contracts with independent, state-certified laboratories to monitor the quality of the water it provides to you. This helps us to provide you with the best quality water possible and to conform to Board regulations. Rosehart also contracts with independent samplers who collect all samples for monitoring purposes and deliver them to the independent laboratories directly. The laboratory water quality results contained in the table sections of this report are of detectable constituents only. This means that there was a detection of the constituent found in the water by the laboratory. The tables also include a list of the State and Federal standards so that you may compare the results of our water analyses to them. The water system tests for hundreds of regulated and unregulated constituents and submits the results to the Board. The constituents that do not appear on the table are non-detectable. This means that there was no detection of the constituent found in the water by the laboratory.

Rosehart's water quality meets ALL State and Federal drinking water standards and is SAFE to use for all purposes, including drinking, cooking and washing. All of Rosehart's water comes from a groundwater source, which provides protective physical measures, including soil barriers, to ensure that the source is protected from pathogens, including viruses. In addition, Rosehart maintains a chlorine disinfectant residual in its water system, which inactivates viruses and bacteria. Rosehart's water system is monitored daily for chlorine disinfectant residual and is tested monthly for bacteriological contaminants to ensure that the water provided to you is free of disease-causing agents. All these protective measures ensure that the water Rosehart provides to you is SAFE to use for all purposes, including drinking, cooking and washing.



Regulation of Drinking Water:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, & wildlife.
- Inorganic contaminants, such as salts & metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil & gas production, mining, or farming.
- Pesticides & herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, & residential uses.
- Organic chemical contaminants, including synthetic & volatile organic chemicals, that are by-products of industrial processes & petroleum production, & can also come from gas stations, urban stormwater runoff, agricultural application, & septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil & gas production & mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Additional Drinking Water Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).