

# 2022 Consumer Confidence Report

Water System Name: **Ventana Inn & Spa**

Report Date: 6/21/23

**We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.**

*Este informe contiene información muy importante sobre su agua para beber. Favor de Ventana Inn & Spa a ( 831 ) 659-3595 para asistirlo en español.*

*这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Ventana Inn & Spa 以获得中文的帮助: ( 831 ) 659-3595*

*Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Ventana Inn & Spa o tumawag sa ( 831 ) 659-3595 para matulungan sa wikang Tagalog.*

*Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Ventana Inn & Spa để được hỗ trợ giúp bằng tiếng Việt.*

*Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Ventana Inn & Spa ntawm ( 831 ) 659-3595 rau kev pab hauv lus Askiv.*

Type of water source(s) in use: Wells & Surface Sources

Name & location of source(s): Lower Well, Campground Well, Well 59, Upper Well, Post Creek, Lower Springs & McCarty Springs

Drinking Water Source Assessment information: Most of the sampling results listed in Tables 3, 4, and 5 within this report are from untreated well water. All of the untreated well water then passes through a filtration plant before being delivered to the customer.

Time and place of regularly scheduled board meetings for public participation: N/A

For more information, contact: Carmel Lahaina Utility Services, Inc.

Phone: ( 831 ) 659-3595

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variances and Exemptions:** Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

| Microbiological Contaminants<br>(complete if bacteria detected) | Highest No. of<br>Detections | No. of Months<br>in Violation | MCL   | MCLG | Typical Source of<br>Bacteria           |
|---|------------------------------|-------------------------------|---|------|---|
| Total Coliform Bacteria<br>(state Total Coliform Rule)          | (In a month)<br>0            | 0                             | 1 positive monthly sample <sup>(a)</sup>  | 0    | Naturally present in the<br>environment |
| Fecal Coliform or <i>E. coli</i><br>(state Total Coliform Rule) | (In the year)<br>0           | 0                             | A routine sample and a repeat<br>sample are total coliform positive,<br>and one of these is also fecal<br>coliform or <i>E. coli</i> positive |      | Human and animal fecal<br>waste         |
| <i>E. coli</i><br>(federal Revised Total<br>Coliform Rule)      | (In the year)<br>0           | 0                             | (b)   | 0    | Human and animal fecal<br>waste         |

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

| Lead and Copper<br>(complete if lead or copper<br>detected in the last sample set) | Sample<br>Date | No. of<br>Samples<br>Collected | 90 <sup>th</sup><br>Percentile<br>Level<br>Detected | No. Sites<br>Exceeding<br>AL | AL  | PHG | No. of Schools<br>Requesting<br>Lead Sampling | Typical Source of<br>Contaminant  |
|--|----------------|--------------------------------|---|------------------------------|-----|-----|---|---|
| Lead (ppb)   | 2022           | 5                              | 1.55  | 0                            | 15  | 0.2 | Not applicable                                | Internal corrosion of<br>household water plumbing<br>systems; discharges from<br>industrial manufacturers;<br>erosion of natural deposits |
| Copper (ppm)   | 2022           | 5                              | 0.1007  | 0                            | 1.3 | 0.3 | Not applicable                                | Internal corrosion of<br>household plumbing<br>systems; erosion of natural<br>deposits; leaching from<br>wood preservatives               |

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

| Chemical or Constituent<br>(and reporting units) | Sample Date | Level Detected | Range of Detections | MCL  | PHG (MCLG) | Typical Source of Contaminant  |
|--|-------------|----------------|---------------------|------|------------|--|
| Sodium (ppm)                                     | 2021        | 13.79          | 10-21               | None | None       | Salt present in the water and is generally naturally occurring   |
| Hardness (ppm)                                   | 2021        | 224.40         | 188-291             | None | None       | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

| Chemical or Constituent<br>(and reporting units) | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant  |
|--|-------------|----------------|---------------------|------------|--------------------|--|
| Aluminum (ppm)                                   | 2021        | 0.01           | ND-0.091            | 1000       | 600                | Erosion of natural deposits; residue from some surface water treatment processes   |
| Antimony (ppb)                                   | 2021        | ND             | ND                  | 6          | 20                 | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder  |
| Arsenic (ppb)                                    | 2021        | 0.50           | ND-1                | 10         | 0.004              | Erosion of natural deposits; runoff from orchards; glass and electronics production wastes   |
| Barium (ppm)                                     | 2021        | 0.017          | 0.0107-0.033        | 1          | 2                  | Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits  |
| Chromium (ppb)                                   | 2021        | 1.55           | ND-3.1              | 50         | (100)              | Discharge from steel and pulp mills and chrome plating; erosion of natural deposits  |
| Copper (ppm)                                     | 2021        | 0.003          | ND – 0.018          | AL=1.3     | 0.17               | Internal corrosion of house hold plumbing systems; erosion of natural deposits; leaching from wood preservatives   |
| Fluoride (ppm)                                   | 2021        | 0.18           | 0.1-0.2             | 2          | 1                  | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories  |
| Gross Alpha Particle Activity                    | 2022        | 0.53           | 0.53                | 15         | 0                  | Erosion of natural deposits  |
| Haloacetic Acids (ppb)                           | 2022        | 1              | 1                   | 60         | N/A                | By-product of drinking water disinfection  |
| Nitrate as N (ppm)                               | 2022        | 0.02           | ND-0.1              | 45         | 45                 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits  |
| Perchlorate (ppb)                                | 2021        | ND             | ND                  | 6          | 6                  | Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts. |
| Selenium (ppb)                                   | 2021        | 0.85           | ND-1.7              | 50         | 50                 | Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)  |
| TTHMs (Total Trihalomethanes) (ppb)              | 2022        | 5              | 5                   | 80         | N/A                | By-product of drinking water disinfection  |
| Turbidity  | 2022        | 0.03           | ND-0.1              | TT         | N/A                | Soil runoff  |

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

| Chemical or Constituent<br>(and reporting units) | Sample<br>Date | Level<br>Detected | Range of<br>Detections | MCL   | PHG<br>(MCLG) | Typical Source of Contaminant                                  |
|--|----------------|-------------------|------------------------|-------|---------------|--|
| Chloride (ppm)                                   | 2021           | 17.40             | 10-42                  | 500   | N/A           | Runoff/leaching from natural deposits;<br>industrial wastes    |
| Color  | 2021           | 3.40              | ND-15                  | 15    | N/A           | Natural- occurring organic materials                           |
| Manganese (ppb)                                  | 2021           | 37.25             | ND-61                  | 50    | N/A           | Leaching from natural deposits                                 |
| Odor (TON)                                       | 2021           | ND                | ND                     | 3     | N/A           | Naturally-occurring organic materials                          |
| Sulfate (ppm)                                    | 2021           | 34                | 27-37                  | 500   | N/A           | Runoff/leaching from natural deposits;<br>industrial wastes    |
| Total Dissolved Solids<br>(TDS) (ppm)            | 2021           | 296.50            | 270-349                | 500   | N/A           | Runoff/leaching from natural deposits                          |
| Specific Conductance (E.C.)<br>(µS/cm)           | 2021           | 482.80            | 449-531                | 1,600 | N/A           | Substances that form ions when in water;<br>seawater influence |
| Zinc (ppm)                                       | 2021           | 0.19              | ND-0.366               | 5     | NA            | Runoff/leaching from natural deposits;<br>industrial wastes    |

\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Ventana Inn & Spa is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

## For Systems Providing Surface Water as a Source of Drinking Water

**TABLE 6 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES**

|  |   |
|--|---|
| Treatment Technique <sup>(a)</sup><br>(Type of approved filtration technology used)                      | Treatment techniques include polymer-added inline filtration, pressure sand filtration, Strainrite filtration technology, and post-chlorination   |
| Turbidity Performance Standards <sup>(b)</sup><br>(that must be met through the water treatment process) | Turbidity of the filtered water must:<br>1 – Be less than or equal to <b>0.1</b> NTU in 95% of measurements in a month.<br>2 – Not exceed <b>1.0</b> NTU for more than eight consecutive hours.<br>3 – Not exceed <b>5.0</b> NTU at any time. |
| Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.                      | <b>100%</b>   |
| Highest single turbidity measurement during the year   | <b>0.029</b>  |
| Number of violations of any surface water treatment requirements   | <b>0</b>  |

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.