

**ATTACHMENT 7**

**Consumer Confidence Report  
Certification Form**

*(to be submitted with a copy of the CCR)*

**(to certify electronic delivery of the CCR, use the certification form on the State Board's website at [http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))**

Water System Name: OASIS RD WS #2

Water System Number: CA2702802

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Andrea Vasquez  
Signature: \_\_\_\_\_  
Title: Environmental Manager  
Phone Number: (209) 824-3675 Date: 06/25/2024

DocuSigned by:  
*Andrea Vasquez*  
DABE76D29CAC4E0...

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: \_\_\_\_\_  
Emailed directly to users and posted in public places for those without email.

- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- Posting the CCR on the Internet at www.\_\_\_\_\_
  - Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - Advertising the availability of the CCR in news media (attach copy of press release)
  - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - Posted the CCR in public places (attach a list of locations)
  - Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
  - Delivery to community organizations (attach a list of organizations)
  - Other (attach a list of other methods used)
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.\_\_\_\_\_
- For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2023 Consumer Confidence Report

## Water System Information

Water System Name: Oasis Rd #2 CA2702802

Report Date: June 5, 2024

Type of Water Source(s) in Use: Groundwater

Name and General Location of Source(s): CA2702802-001 Well 1, 53001 Oasis Rd, Kings City CA

Drinking Water Source Assessment Information: The source is considered most vulnerable to the following activities not associated with any detected contaminants: Septic system use for vineyard office, vineyard shop, potential fertilizer Pesticide applications, storm water runoff.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Call for scheduled meetings

For More Information, Contact: Andrea Vasquez, Telephone: Office (209) 824-3675

## About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2023, and may include earlier monitoring data.

## Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Oasis Rd #2, 53001 Oasis Rd, King City CA a (831) 386-5610 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系，Oasis Rd #2 以获得中文的帮助，53001 Oasis Rd, Kings City CA (831) 386-5610。

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Oasis Rd#2, 53001 Oasis Rd, King City, CA o tumawag sa (831) 386-5610 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên Oasis Rd#2, tại (831) 386-5610 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Oasis Rd#2, ntawm (831) 386-5610 rau kev pab hauv lus Askiv.

## Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(0)	[0.]	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb) 8/31/22	5	0	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm) 8/31/22	5	0.36	0	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	3/4/14	32	N/A	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)		Not Available	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

\*Any violation of an MC or AL is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<b>Inorganic Contaminants</b>						
Arsenic (As) (ppb)	1/24/23 – 12/5/23	8	6.3 - 11	10	0.004	Erosion of natural deposits; runoff from orchards, from glass and electronics production waste
Fluoride (ppm)	3/13/23	0.15	N/A	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate (as nitrogen) (ppm)	1/24/23 – 11/6/23	5.5	4.0 - 7.1	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits.
Selenium (ppb)	3/13/23	9.9	N/A	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
<b>Radioactive Contaminants</b>						
Uranium (pCi/L)	7/7/20	1.1	N/A	20	0.43	Erosion of natural deposits

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	3/4/14	79.1	N/A	500	none	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	3/4/14	88	N/A	500	none	Runoff/leaching from natural deposits; industrial wastes
Specific Conductance (EC) $\mu$ S/cm	3/4/14	668	N/A	1600	none	Substances that form ions when in water; seawater influence

**TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Boron (ppm)	3/4/14	0.18	N/A	1 ppm	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.
Hexavalent Chromium (ppb)	7/5/17	0.92	N/A	n/a	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits

\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

(a) Results of monitoring under former section 64450 (UCMR) need only be included for 5 years from the date of the last sampling or until any of the detected contaminants becomes regulated and subject to routine monitoring requirement, whichever comes first. Section 64450 was repealed effective October 18, 2007.

*The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.*

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Oasis Rd #2 is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

**Arsenic:** While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**Nitrate:** While your drinking water meets the federal and state standard for nitrate, it does contain low levels of nitrate. Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

## Summary Information for Contaminants Exceeding an MCL, MRDL, or AL or Violation of Any TT or Monitoring and Reporting Requirement

**No Violations**

**2023 ANNUAL WATER ANALYSES SUMMARY WORKSHEET**

The following water quality information is provided annually.

For further water system information or to inquire about the most recent water quality information available, please contact manager.

**MICROBIOLOGICAL QUALITY**

Minimum number of tests required per year is 12.

Number of water samples tested for the presence of coliform bacteria during the year is 20.

Number of samples tested which failed to meet the microbiological drinking standard during the year is 3.

Sampling results showing the detection of coliform bacteria			
	Highest No. of Detections	No. of months in violation	MCL
Total Coliform Bacteria	(In a mo.) <u>3</u>	1	More than 1 sample in a month with a detection
Fecal Coliform or <i>E. coli</i>	(In the year) <u>0</u>	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>
<i>E. coli</i> (Federal Revised Total Coliform Rule)	(In the year) <u>0</u>	0	(a)

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**INORGANIC CHEMICAL QUALITY**

Results of water samples analyses done to determine the presence or absence of inorganic chemical contamination. All values expressed in milligrams per liter (mg/l) unless otherwise indicated. Milligrams per liter are equivalent to parts per million (ppm). The symbol "<" means less than. The symbol "ND" means not detected.

Inorganic Chemical	California California		PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Level	Date Sampled
	MCL <sup>1</sup> (mg/l)	MCL <sup>1</sup> (ug/l)			Detected (mg/l)	Detected (ug/l)	
Aluminum (Al)	1		N/A	N/A		<50	03/13/23
Antimony (Sb)	0.006	6	20			<2.0	03/13/23
Arsenic (As)	0.01	10	N/A	0		11	03/13/23
Asbestos	<b>7 MFL</b>		7	7		ND	03/13/23
Barium (Ba)	1.0	1000	N/A	2		<100	03/13/23
Beryllium (Be)	0.004	4	N/A	0.004		<1	03/13/23
Cadmium (Cd)	0.005	5	N/A	0.005		<1	03/13/23
Chromium (Cr)	0.05	50	N/A	0.1		<10	03/13/23
Cyanide (CN)	0.15	150	2			<5	03/13/23
Fluoride (F)	2.0				0.15		03/13/23
Lead (Pb)		<b>AL=15</b>	N/A	0.002		<1.0	03/13/23
Mercury (inorganic) (Hg)	0.002	2	N/A	0.1		<0.2	03/13/23
Nickel (Ni)	0.10	100	N/A	0.05		<10	03/13/23
Selenium (Se)	0.05	50				9.9	03/13/23
Silver (Ag)	0.10	100	N/A	0.0005		<10	03/13/23
Thallium (Tl)	0.002	2	1000			<1.0	03/13/23
Nitrate (as nitrogen, N) (NO <sub>3</sub> -N)	10		10000 as N		6.3		03/13/23
Nitrite (as nitrogen, N) (NO <sub>2</sub> -N)	3		10000 as N		<0.40	<400	03/13/23

**AL = Action Level**

Hexavalent Chromium	N/A				0.92	07/05/17	
					(mg/l)	(ug/l)	Sampled
Sys # 2702802-001							
Arsenic (As)	0.01	10	N/A	0		8.7	01/24/23
Arsenic (As)	0.01	10	N/A	0		9.4	02/06/23
Arsenic (As)	0.01	10	N/A	0		11.0	03/13/23
Arsenic (As)	0.01	10	N/A	0		8.8	04/11/23
Arsenic (As)	0.01	10	N/A	0		7.3	05/24/23
Arsenic (As)	0.01	10	N/A	0		7.1	06/19/23
Arsenic (As)	0.01	10	N/A	0		6.5	07/19/23
Arsenic (As)	0.01	10	N/A	0		6.3	08/09/23
Arsenic (As)	0.01	10	N/A	0		7.8	09/13/23
Arsenic (As)	0.01	10	N/A	0		8.5	10/02/23
Arsenic (As)	0.01	10	N/A	0		6.5	11/06/23
Arsenic (As)	0.01	10	N/A	0		8.5	12/05/23
					Average	<b>8.0</b>	
Nitrate (as nitrogen, N) (NO3-N)	10		10000 as N		4.4		01/24/23
Nitrate (as nitrogen, N) (NO3-N)	10		10000 as N		4.3		03/13/23
Nitrate (as nitrogen, N) (NO3-N)	10		10000 as N		4.3		03/24/23
Nitrate (as nitrogen, N) (NO3-N)	10		10000 as N		4.0		04/11/23
Nitrate (as nitrogen, N) (NO3-N)	10		10000 as N		4.2		04/25/23
Nitrate (as nitrogen, N) (NO3-N)	10		10000 as N		7.1		08/09/23
Nitrate (as nitrogen, N) (NO3-N)	10		10000 as N		6.5		11/06/23
					Average	<b>5.5</b>	

**GENERAL MINERAL QUALITY TEST RESULTS**

Constituents	California California		PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Level	Date Sampled
	MCL <sup>1</sup> (mg/l)	MCL <sup>1</sup> (ug/l)			Detected (mg/l)	Detected (ug/l)	
pH (Unit)					7.30		03/04/14
Total Alkalinity as CaCO3 Hydroxide (OH)					121.00		03/04/14
Carbonate (CO3)					<1		03/04/14
Bicarbonate (HCO3)					121.00		03/04/14
Calcium (Ca)					64.90		03/04/14
Copper (Cu)	1.0	1000	170				
Iron (Fe)	0.3	300	1000		<0.10		03/04/14
Magnesium (Mg)					24.9		03/04/14
Manganese (Mn)	0.05	50			<0.02		03/04/14
Sodium (Na)					32		03/04/14
Zinc (Zn)	5.0	5000					
Total Hardness as CaCO3 Langlier Index (LI)					-0.2		03/04/14
Foaming Agents (MBAS)	0.5	500					
Boron (B)					0.18		03/04/14
Potassium (K)					1.5		03/04/14
Constituent, Units	MCL		MCL	MCL	Level	Date	
	Recommended	Upper			Short Term	Detected (mg/l)	Sampled
Total Dissolved Solids (TDS), mg/l		500	1000	1600			
Specific Conductance (EC), micromhos/cm		900-2200	1600	2200	610	9/22/21	
Chloride (Cl), mg/l		250	500	600	79.1	3/4/14	
Sulfate (SO4), mg/l		250	500	600	88	3/4/14	

**ORGANIC CHEMICAL QUALITY**

Results of water sample analyses done to determine the presence of organic chemical contamination in the water supply.

Names and concentrations of any organic contaminants including pesticides, herbicides and other organic chemicals detected in the water supply source.

Organic Chemical Method: EPA 515.1	California	California	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Date Sampled
	MCL <sup>1</sup> (mg/l)	MCL <sup>1</sup> (ug/l)			Detected (in ug/l)	
					<b>default values</b>	
Bentazon (Basagran)	18	200			<0.20	3/13/23
Dalapon	200	790			<10	3/13/23
Pentachlorophenol (PCP)	1				<0.02	3/13/23
Picloram	500				<1	3/13/23
2,4-D	70	70			<0.10	3/13/23
Dinoseb (DNBP)	7	14			<0.20	3/13/23
2,4,5-TP (Silvex)	50	25			<1	3/13/23
2,4,5-T	<b>10</b>				<1	3/13/23
Banvel (Dicamba)					<1.5	3/13/23

Organic Chemical Method: EPA 525.2.(507)	California	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Date Sampled
	MCL <sup>1</sup> (ug/l)			Detected (in ug/l)	
Molinate (Ordram)	20	NA		<0.50	03/13/23
Simazine (Princep)	4	4		<0.30	03/13/23
Thiobencarb (Bolero)	70	70		<0.50	03/13/23
Alachlor (Lasso)	2	4		<0.20	03/13/23
Bromacil (HYVAR)				<0.50	03/13/23
Butachlor				<0.30	03/13/23
Metribuzin	NA			<0.50	03/13/23
Propachlor				<0.50	03/13/23
Metolachlor	NA			<0.50	03/13/23
Dimethoate (CYGON)	NA			<2.0	03/13/23
Atrazine (AATREX)	1	0.15		<0.30	03/13/23

Semi-Volatile Organics (EPA Method 531.1, 548.1, 549.2)	California	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Date Sampled
	MCL <sup>1</sup> (ug/l)			Detected (ug/l)	
				<b>default values</b>	
Carbofuran (FURADAN)	18			<5	03/13/23
Oxamyl (Vydate)	50			<20	03/13/23
Diquat				<4	03/13/23
3-Hydroxycarbofuran				<3	03/13/23
Aldicarb (TEMIK)				<3	03/13/23
Aldicarb sulfone				<2	03/13/23
Aldicarb sulfoxide				<3	03/13/23
Carbaryl (Sevin)				<5	03/13/23
Methomyl				<2	03/13/23
Propoxur					
<b>EPA 548</b>					
Endothall	100			<45	

Constituents	California			Level		Date Sampled
	MCL <sup>1</sup> (ug/l)	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Detected (ug/l)		
1 1,1,1-Trichloroethane (1,1,1-TCA)		0.2	200	1000	<0.50	7/19/23
2 1,1,2,2-Tetrachloroethane		0.001	1	0.1	<0.50	7/19/23
3 1,1,2-Trichloro-1,2,2-trifluoroethane		1.2	1200		<10	7/19/23
4 1,1,2-Trichloroethane (1,1,2-TCA)		0.005	5	0.3	<0.50	7/19/23
5 1,1-Dichloroethane (1,1-DCA)		0.005	5	3	<0.50	7/19/23
6 1,1-Dichloroethylene (1,1-DCE)		0.006	6	10	<0.50	7/19/23
7 1,2,4-Trichlorobenzene		0.005	5	5	<0.50	7/19/23
8 1,2 Dichlorobenzene (o-DCB)		0.6	600	660	<0.50	7/19/23
9 1,2-Dichloroethane (1,2-DCA)		0.0005	0.5	0.4	<0.50	7/19/23
10 1,2-Dichloropropane		0.005	5		<0.50	7/19/23
11 1,4-Dichlorobenzene (p-DCB)		0.005	5	6	<0.50	7/19/23
12 Benzene		0.001	1	0.15	<0.50	7/19/23
13 Carbon Tetrachloride		0.0005	0.5	0.1	<0.50	7/19/23
14 Monochlorobenzene (Chlorobenzene)		0.07	70	200	<0.50	7/19/23
15 cis-1,2-Dichloroethylene (c-1,2-DCE)		0.006	6	100	<0.50	7/19/23
16 cis-1,3-Dichloropropene (D-D)		0.0005	0.5		<0.50	7/19/23
17 Dichloromethane (Methylene Chloride)		0.005	5	4	<1.0	7/19/23
18 Ethyl Benzene		0.3	300	300	<0.50	7/19/23
19 m,p,-Xylene					<0.50	7/19/23
20 Methyl tert-Butyl Ether (MTBE)		0.005	5	5	<0.50	7/19/23
21 O-Xykene		0.0005	0.5		<0.50	7/19/23
22 Styrene		0.1	100	100	<0.50	7/19/23
23 Tetrachloroethylene (PCE)		0.005	5	0.06	<0.50	7/19/23
24 Toluene		0.15	150	150	<0.50	7/19/23
25 trans-1,2-Dichloroethylene (t-1,2-DCE)		0.01	10	60	<0.50	7/19/23
26 trans-1,3-Dichloropropene		0.0005	0.5		<0.50	7/19/23
27 Trichloroethylene (TCE)		0.005	5	0.8	<0.50	7/19/23
28 Trichlorofluoromethane (Freon 11)		0.15	150	700	<5	7/19/23
29 Vinyl Chloride (VC)		0.0005	0.5	0.05	<0.50	7/19/23
30 Total 1,3-Dichloropropene		0.0005	0.5	0.2	<0.50	7/19/23
31 Total Xylenes		1.75	1750	1800	<0.50	7/19/23

	MCL (ug/l)	Level Detected (ug/l)	Date Sampled
1,2,3-Trichloropropane [TCP]	0.005	<0.0050	8/2/21

EDB/DBCP EPA Method 504.1	California			Level	
	MCL <sup>1</sup> (ug/l)	PHGs <sup>2</sup> (ug/l)	MCLGs <sup>3</sup> (ug/l)	Detected (ug/l)	Date Sampled
Enter all data for the year (needed for CCR's) Dibromochloropropane (DBCP)	0.2	N/A	0.0017		

**RADIOLOGICAL QUALITY**

<b>Every 3 years</b>	<b>Max. Level Allowed (in pCi/l)</b>	<b>Level Detected (in pCi/l)</b>	<b>Date Sampled</b>
<i>Enter all data for the year (needed for CCR's)</i>			
Gross Alpha	15	2.48	07/14/21
Uranium	20	1.00	07/14/21

<b>Method EPA 314 Parameter</b>	<b>Max. Level Allowed (ug/l)</b>	<b>Level Detected (ug/l)</b>	<b>Date Sampled</b>
<i>Enter all data for the year (needed for CCR's)</i>			
Perchlorate	6	2.4	09/22/21
Perchlorate	6	<4.0	10/13/21

**LEAD AND COPPER ANALYSIS**

**Constituent**      **Lead (Pb) Action Level (AL) 15 ug/l**      **Method: EPA-200.8**  
**Constituent**      **Copper (Cu) Action Level (AL) 1.3 mg/l**      **Method: EPA-200.8**  
*Enter all data for the year (needed for CCR's)*

<b>Client Sample ID</b>	<b>Copper (mg/l)</b>	<b>Copper (ug/l)</b>	<b>Lead (ug/l)</b>	<b>Date Sampled</b>	<i>enter 2 highest values for lead and copper</i>	
1 Main Office	0	0	0	08/31/22	<b>Copper (mg/l)</b>	<b>Lead (ug/l)</b>
2 Hospitality Building	0.21	210	0	08/31/22	0.21	0.0
3 Vineyard Office	0.51	510	0	08/31/22	0.51	0
4 Maintenance Shop	0.13	130	ND	08/31/22		
5 Maintenance Outside Water	0	0	ND	08/31/22	90th percentile-> 0.360	0

- <sup>1</sup>**MCL**      **Maximum Contaminant Level**
- <sup>2</sup>**PHGs**    **Public Health Goals**
- <sup>3</sup>**MCLGs**   **Maximum Contaminant Level Goals (Federal)**

Please call if you have any questions. (559) 233-6129

Sincerely,



Danyal Kasapligil, MS  
Certified Crop Advisor