

## APPENDIX B: eCCR Certification Form (Suggested Format)


### Consumer Confidence Report Certification Form

*(To be submitted with a copy of the CCR)*

|                      |                           |
|----------------------|---------------------------|
| Water System Name:   | Little Bear Water Company |
| Water System Number: | 2710016                   |

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/30/2023 (*date*) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

|                                                                                              |                |
|----------------------------------------------------------------------------------------------|----------------|
| Name: David Morisoli                                                                         | Title: manager |
| Signature:  | Date: 7/6/2023 |
| Phone number: (831) 385-3524                                                                 | blank          |

*To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:*

- ☒ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
  - ☐ Posting the CCR at the following URL: www.\_\_\_\_\_
  - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
  - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - ☒ Posted the CCR in public places (attach a list of locations)
  - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following URL: www.\_\_\_\_\_
- ☒ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

### **Consumer Confidence Report Electronic Delivery Certification**

*Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.*

- ☐ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www.\_\_\_\_\_
- ☐ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www.\_\_\_\_\_
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ Requires prior DDW review and approval. Water system utilized other electronic delivery method that meets the direct delivery requirement.

*Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.*

|  |
|--|
|  |
|  |
|  |

|                                                                         |
|-------------------------------------------------------------------------|
| CCR posted in following public places                                   |
| Pine Canyon Store – 50410 Jolon Rd, King City, Ca                       |
| Pine Canyon Mobile Estates office – 51201 Pine Canyon Rd, King City, Ca |
|                                                                         |
|                                                                         |
|                                                                         |
|                                                                         |
|                                                                         |
|                                                                         |

*This form is provided as a convenience and may be used to meet the certification  
requirement of  
section 64483(c) of the California Code of Regulations.*

## 2022 Consumer Confidence Report

Water System Name: Little Bear Water Company (CA2710016) Report Date: June 13, 2023

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: Ground Water

Name & general location of source(s): Well #3 – Ground water extracted from the Salinas River South/East of the district boundaries

**Drinking Water Source Assessment information:** The assessment of the drinking water sources was completed 12/2002. Wells 1-3 are considered most vulnerable to the following activities associated with contaminants detected in the water supply: Crops, irrigated; and Fertilizer, Pesticides/Herbicide Application. A copy of this assessment can be found at the following locations: •Division of Drinking Water – Monterey District Drinking Water Field Operations Branch

Time and place of regularly scheduled board meetings for public participation: N/A

For more information, contact: Cypress Water Services, Inc. – (831)920-6796 – Info@CypressWaterServices.com

### TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variances and Exemptions:** Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

| Microbiological Contaminants                                    | Highest #<br>Detections | # Months in<br>Violation | MCL                                                                                                                                        | MCLG | Typical Source of<br>Bacteria           |
|-----------------------------------------------------------------|-------------------------|--------------------------|--------------------------------------------------------------------------------------------------------------------------------------------|------|-----------------------------------------|
| Total Coliform Bacteria<br>(state Total Coliform Rule)          | (In a month)<br>0       | 0                        | 1 positive monthly sample                                                                                                                  | 0    | Naturally present<br>in the environment |
| Fecal Coliform or <i>E. coli</i><br>(state Total Coliform Rule) | (In the year)<br>0      | 0                        | A routine sample and a repeat sample are<br>total coliform positive, and one of these is<br>also fecal coliform or <i>E. coli</i> positive |      | Human and animal<br>fecal waste         |
| <i>E. coli</i><br>(federal Revised Total Coliform Rule)         | (In the year)<br>0      | 0                        | (a)                                                                                                                                        | 0    | Human and animal<br>fecal waste         |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

| Lead and<br>Copper | Sample<br>Date | # Samples<br>Collected | 90 <sup>th</sup> Percentile<br>Level Detected | # Sites<br>Exceeding AL | AL  | PHG | Typical Source of Contaminant                                                                                                       |
|--------------------|----------------|------------------------|-----------------------------------------------|-------------------------|-----|-----|-------------------------------------------------------------------------------------------------------------------------------------|
| Lead (ppb)         | 7/2020         | 10                     | 3.7                                           | 1                       | 15  | 0.2 | Internal corrosion of household water plumbing systems;<br>discharges from industrial manufacturers; erosion of natural<br>deposits |
| Copper (ppm)       | 7/2020         | 10                     | 0.2                                           | 0                       | 1.3 | 0.3 | Internal corrosion of household plumbing systems; erosion<br>of natural deposits; leaching from wood preservatives                  |

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

| Chemical or Constituent<br>(and reporting units) | Sample<br>Date | Average<br>Level<br>Detected | Range of<br>Detections | MCL  | PHG<br>(MCLG) | Typical Source of Contaminant                                                                                           |
|--------------------------------------------------|----------------|------------------------------|------------------------|------|---------------|-------------------------------------------------------------------------------------------------------------------------|
| Sodium (ppm)                                     | 1/2021         | 32                           | N/A                    | None | None          | Salt present in the water and is generally naturally occurring                                                          |
| Hardness (ppm)                                   | 1/2021         | 182                          | N/A                    | None | None          | Sum of polyvalent cations present in the water, generally<br>magnesium and calcium, and are usually naturally occurring |

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

| Chemical or Constituent<br>(and reporting units) | Sample<br>Date | Average<br>Level<br>Detected | Range of<br>Detections | MCL<br>[MRDL] | PHG<br>(MCLG)<br>[MRDLG] | Typical Source of Contaminant                                                                                                                                                                                  |
|--------------------------------------------------|----------------|------------------------------|------------------------|---------------|--------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Antimony (ppb)                                   | 1/2021         | 0.1                          | N/A                    | 6             | 1                        | Discharge from petroleum refineries; fire<br>retardants; ceramics; electronics; solder                                                                                                                         |
| Arsenic (ppb)                                    | 1/2021         | 2.7                          | N/A                    | 10            | 0.004                    | Erosion of natural deposits; runoff from<br>orchards; glass and electronic production<br>wastes                                                                                                                |
| Barium (ppm)                                     | 1/2021         | 0.0345                       | N/A                    | 1             | 2                        | Discharge of oil drilling wastes and from<br>metal refineries; erosion of natural deposits                                                                                                                     |
| Cadmium (ppb)                                    | 1/2021         | 0.2                          | N/A                    | 5             | 0.04                     | Internal corrosion of galvanized pipes;<br>erosion of natural deposits; discharge from<br>electroplating and industrial chemical<br>factories, and metal refineries; runoff from<br>waste batteries and paints |
| Chromium, Total (ppb)                            | 1/2021         | 2.4                          | N/A                    | 50            | 100                      | Discharge of oil drilling wastes and from<br>metal refineries; erosion of natural deposits                                                                                                                     |
| Fluoride (ppm)                                   | 1/2021         | 0.2                          | N/A                    | 2             | 1                        | Erosion of natural deposits; runoff from<br>orchards; glass and electronic production<br>wastes                                                                                                                |
| Gross Alpha (pCi/L)                              | 1/2021         | 2.29±1.27                    | N/A                    | 15            | (0)                      | Erosion of natural deposits                                                                                                                                                                                    |

|                             |                |      |           |     |     |                                                                                                                                                                                 |
|-----------------------------|----------------|------|-----------|-----|-----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Haloacetic Acids (ppb)      | 7/2022         | 4.5  | 2 - 7     | 60  | N/A | Byproduct of drinking water disinfection                                                                                                                                        |
| Nickel (ppb)                | 1/2021         | 1.8  | N/A       | 100 | 12  | Erosion of natural deposits; discharge from metal factories                                                                                                                     |
| Nitrate as N (ppm)          | Quarterly 2022 | 2.15 | 1.6 – 3.2 | 10  | 10  | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits                                                                     |
| Selenium (ppb)              | 1/2021         | 7.1  | N/A       | 50  | 30  | Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive) |
| Total Trihalomethanes (ppb) | 7/2022         | 12.5 | 9 – 16    | 80  | N/A | Byproduct of drinking water disinfection                                                                                                                                        |

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

| Chemical or Constituent<br>(and reporting units) | Sample Date | Average Level Detected | Range of Detections | SMCL  | Typical Source of Contaminant                               |
|--------------------------------------------------|-------------|------------------------|---------------------|-------|-------------------------------------------------------------|
| Chloride (ppm)                                   | 7/2021      | 19.85                  | 19.3 – 20.4         | 500   | Runoff/leaching from natural deposits; seawater influence   |
| Specific Conductance (µS/cm)                     | 1/2021      | 507                    | N/A                 | 1,600 | Substances that form ions when in water; seawater influence |
| Sulfate (ppm)                                    | 1/2021      | 79.5                   | N/A                 | 500   | Runoff/leaching from natural deposits; industrial wastes    |
| Total Dissolved Solids (ppm)                     | 1/2021      | 352                    | N/A                 | 1,000 | Runoff/leaching from natural deposits                       |
| Zinc (ppb)                                       | 1/2021      | 30                     | N/A                 | 5,000 | Runoff/leaching from natural deposits; industrial wastes    |

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Little Bear Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [OPTIONAL: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

| VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT |             |          |                                        |                         |
|---------------------------------------------------------------------------|-------------|----------|----------------------------------------|-------------------------|
| Violation                                                                 | Explanation | Duration | Actions Taken to Correct the Violation | Health Effects Language |
| None                                                                      | None        | N/A      | None                                   | N/A                     |

## For Water Systems Providing Groundwater as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLES

| Microbiological Contaminants<br>(complete if fecal-indicator detected) | Total No. of Detections | Sample Dates  | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|------------------------------------------------------------------------|-------------------------|---------------|------------|--------------------|-------------------------------|
| <i>E. coli</i>                                                         | 0                       | Taken Monthly | 0          | (0)                | Human and animal fecal waste  |
| Enterococci                                                            | 0                       | Taken Monthly | TT         | N/A                | Human and animal fecal waste  |
| Coliphage                                                              | 0                       | -             | TT         | N/A                | Human and animal fecal waste  |

## Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Groundwater TT

| SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLE |  |
|----------------------------------------------------------------------|--|
|                                                                      |  |
| SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES              |  |
|                                                                      |  |
| VIOLATION OF GROUNDWATER TT                                          |  |

| TT Violation | Explanation | Duration | Actions Taken to Correct the Violation | Health Effects Language |
|--------------|-------------|----------|----------------------------------------|-------------------------|
| None         | None        | N/A      | None                                   | N/A                     |

### Summary Information for Federal Revised Total Coliform Rule

#### Level 1 and Level 2 Assessment Requirements

##### Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system.

During the past year we were required to conduct 0 Level 1 assessment(s).

During the past year 0 Level 2 assessments were required to be completed for our water system.

##### Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

*E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.

We were NOT required to complete a Level 2 assessment because we DID NOT find *E. coli* in our water system. In addition, we were NOT required to take any corrective actions.