

## **2022 Consumer Confidence Report**

### **Camp Roberts Annual Water Quality Report**

#### **Water System Information**

Water System Name: Camp Roberts – California National Guard

Report Date: 7/1/2023

Type of Water Source(s) in Use: Wells

Name and General Location of Source(s): Well C-01, Well C-5A, Well 03-A, Well C-4A. Map available upon request.

Drinking Water Source Assessment Information: Latest assessment was completed in November of 2022. A copy of the complete assessment is available at the Camp Roberts Drinking Water System Operator's office.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: For more information, please contact the Camp Roberts Directorate of Public Works (DPW), phone number listed below.

For More Information, Contact: Mr, Steve Drayton, (805) 238-8495.

#### **About This Report**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.

#### **Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)**

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Enter Water System's Name] a [Enter Water System's Address or Phone Number] para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Enter Water System Name] 以获得中文的帮助: [Enter Water System's Address][Enter Water System's Phone Number].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Enter Water System's Name and Address] o tumawag sa [Enter Water System's Phone Number] para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Enter Water System's Name] tại [Enter Water System's Address or Phone Number] để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Enter Water System's Name] ntawm [Enter Water System's Address or Phone Number ] rau kev pab hauv lus Askiv.

## Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)

Term	Definition
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do

not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 2	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	9/23/21	10	1.2	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/23/21	10	0.10	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	1/11/22, 1/25/22, 7/18/22, 12/28/22	126	18-230	None	None	Salt present in the water and is generally naturally occurring

Hardness (ppm)	1/11/22, 1/25/22, 7/18/22, 12/28/22	191	110-280	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
----------------	--	-----	---------	------	------	--

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

<b>Chemical or Constituent (and reporting units)</b>	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Source of Contaminant</b>
Antimony (ppb)	9/8/20	0.6	ND-2.4	6	1	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppb)	9/8/20	2.6	ND-5.9	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	9/8/20	0.055	0.034-0.082	1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Beryllium (ppb)	9/8/20	ND	ND	4	1	Discharge from metal refineries, coal-burning factories, and electrical, aerospace, and defense industries
Cadmium (ppb)	9/8/20	ND	ND	5	0.04	Internal corrosion of galvanized

						pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories, and metal refineries; runoff from waste batteries and paints
Chromium (total) (ppm)	9/8/20	0.009	ND-0.031	50	100	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	9/8/20	0.41	0.29-0.54	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (Inorganic) (ppb)	9/8/20	ND	ND	2	1.2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland
Nickel (ppb)	9/8/20	8.75	ND-35	100	12	Erosion of natural deposits; discharge from metal factories
Nitrate (as Nitrogen, N) (ppm)	1/11/22, 1/25/22, 7/18/22, 12/28/22	0.99	ND-2.3	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage;

						erosion of natural deposits
Nitrite (as Nitrogen, N) (ppm)	9/8/20	ND	ND	1	1	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Perchlorate (ppb)	9/8/20	ND	ND	6	1	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts.
Selenium (ppb)	9/8/20	5.8	1.8-11	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from

						livestock lots (feed additive)
Thallium (ppb)	9/8/20	ND	ND	2	0.1	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
TTHMs [Total Trihalomethanes] (ppb)	9/6/22	9.9	7.1-9.9	80	N/A	Byproduct of drinking water disinfection
HAA5 (Sum of 5 Haloacetic Acids) (ppb)	9/6/22	2.4	ND-2.4	60	N/A	Byproduct of drinking water disinfection
Chlorine (ppm)	4 samples per month	1.02	0.68-1.30	MRDL= 4 (as Cl <sub>2</sub> )	MRDLG = 4 (as Cl <sub>2</sub> )	Drinking water disinfectant added for treatment
Gross Alpha (pCi/L)	10/11/22, 12/28/22	6.71	5.00-8.42	15	(0)	Erosion of natural deposits
Total Alpha Radium (for nontransient- noncommunity water systems) (pCi/L)	3/27/18, 6/12/18, 4/9/19	0.48	0.0950- 0.787	5	N/A	Erosion of natural deposits
Uranium (pCi/L)	10/11/22, 12/28/22	2.0	0.0028-4.0	20	0.43	Erosion of natural deposits
1,2,3- Trichloropropane (ng/L)	7/18/22	ND	ND	5	0.7	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the



						production of other compounds and pesticides.
2,4-D (ppb)	4/28/20, 11/9/21	ND	ND	70	20	Runoff from herbicide used on row crops, range land, lawns, and aquatic weeds
Atrazine (ppb)	4/28/20, 11/9/21	ND	ND	1	0.15	Runoff from herbicide used on row crops and along railroad and highway right-of-ways
Diquat (ppb)	4/28/20, 11/9/21	ND	ND	20	6	Runoff from herbicide use for terrestrial and aquatic weeds
Simazine (ppb)	4/28/20, 11/9/21	ND	ND	4	4	Herbicide runoff

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Iron	1/11/22, 1/25/22, 7/18/22, 12/28/22	41	ND-2100	0.3 mg/L	300 µg/L	Leaching from natural deposits; industrial wastes
Total Dissolved Solids [TDS]	1/11/22, 1/25/22, 7/18/22, 12/28/22	551	220-820	1,000 mg/L	1,000 mg/L	Runoff/leaching from natural deposits
Specific Conductance	1/11/22, 1/25/22, 7/18/22, 12/28/22	931	480-1300	1,600 µS/cm	1,600 µS/cm	Substances that form ions when in water; seawater influence
Chloride	1/11/22, 1/25/22, 7/18/22, 12/28/22	68	12-150	500 mg/L	500 mg/L	Runoff/leaching from natural deposits; seawater influence

Sulfate	1/11/22, 1/25/22, 7/18/22, 12/28/22	107	42-190	500 mg/L	500 mg/L	Runoff/leaching from natural deposits; industrial wastes
---------	--	-----	--------	-------------	-------------	---

**Table 6. Detection of Unregulated Contaminants**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Boron (ppm)	1/11/22, 1/25/22, 7/18/22, 12/28/22	0.83	ND-1.7	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (ppb)	7/6/15	13	6-19	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Enter Water System's Name] is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: [Enter Additional Information Described in Instructions for SWS CCR Document]

State Revised Total Coliform Rule (RTCR): On July 18, 2022, total coliform and *E. coli* were present at the Building 910 bi-monthly sampling point, as well as source Well C-1. A re-sample was performed on July 20, 2022 at Building 910 and the upstream and downstream locations, as well as all active source wells (Well C-1, Well C-4A, Well C-5A). The re-sample results showed no total coliform or *E. coli* detections at any location except Well C-1, which had a result of 2 MPN/100mL of total coliform. Well C-1 was only discharged to waste in the month of July of 2022, and was disinfected before being re-tested and cleared to return to normal operation by the Water Board on August 19, 2022.

Building 910 and the upstream and downstream locations were sampled again on July 21, 2022, with no total coliform or *E. coli* present at any location. In accordance with the BSSP and the procedure required for the month following a coliform-positive result, additional sampling occurred on August 16, 2022. While Building 910 was absent for both total coliform and *E. coli* on this day, Building 25021 MATES returned a presence for total coliform. A re-sample was performed on August 18, 2022 at Building 25021 MATES and the upstream and downstream locations, as well as all active source wells (Well C-1, Well C-4A, Well C-5A). The re-sample results showed no total coliform or *E. coli* detections at any location. In accordance with the BSSP and the procedure required for the month following a coliform-positive result, additional sampling occurred on September 27, 2022. No total coliform or *E. coli* were detected at any location on this day.

Though *E. coli* was detected in source Well C-1 and Building 910, the water system is not in violation of the *E. coli* MCL. All repeat samples were performed and no assessments were required.

### Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

**Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
None	N.A.	N.A.	N.A.	N.A.
None	N.A.	N.A.	N.A.	N.A.

### For Water Systems Providing Groundwater as a Source of Drinking Water

**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

<b>Microbiological Contaminants (complete if fecal-indicator detected)</b>	<b>Total No. of Detections</b>	<b>Sample Dates</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Source of Contaminant</b>
<i>E. coli</i>	1	7/18/22	0	(0)	Human and animal fecal waste
Enterococci	0	N.A.	TT	N/A	Human and animal fecal waste
Coliphage	0	N,A,	TT	N/A	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT**

**Special Notice of Fecal Indicator-Positive Groundwater Source Sample:** [Enter Special Notice of Fecal Indicator-Positive Groundwater Source Sample] Not Applicable.

**Special Notice for Uncorrected Significant Deficiencies:** [Enter Special Notice for Uncorrected Significant Deficiencies] Not Applicable.

**Table 9. Violation of Groundwater TT**

<b>Violation</b>	<b>Explanation</b>	<b>Duration</b>	<b>Actions Taken to Correct Violation</b>	<b>Health Effects Language</b>
None	N.A.	N.A.	N.A.	N.A.
None	N.A,	N.A.	N.A.	N.A.