


**Consumer Confidence Report
Certification Form**
(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: Grgich Hills Winery

Water System Number: 28-00536

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 4/3/19 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Nicholaus Lutz
Signature: 
Title: Certified Operator
D-2 - 29233, T-2 - 26658
Phone Number: 707-944-2471 Date: 4/3/19

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: Emailed to all users of the water system. Hard copies were provided to any user without access to email.
- ☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- ☐ Posting the CCR on the Internet at www.
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☐ Posted the CCR in public places (attach a list of locations)
 - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - ☐ Delivery to community organizations (attach a list of organizations)
 - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.
- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).

2018 Consumer Confidence Report

Water System Name: **Grgich Hills Winery**

Report Date: **April 3, 2019**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Grgich Hills Winery, a 1829 St. Helena Hwy. Rutherford, CA 94573 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Grgich Hills Winery 以获得中文的帮助: 1829 St. Helena Hwy. Rutherford, CA 94573- (707) 963-2784

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Grgich Hills Winery, 1829 St. Helena Hwy. Rutherford, CA 94573 o tumawag sa [Enter Water System's Phone Number Here] para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Grgich Hills Winery tại 1829 St. Helena Hwy. Rutherford, CA 94573 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Grgich Hills Winery ntawm 1829 St. Helena Hwy. Rutherford, CA 94573 rau kev pab hauv lus Askiv.

Type of water source(s) in use: Well

Name & general location of source(s): Well is located outside the southeast corner of the stand alone Warehouse at the south end of the parcel.

Drinking Water Source Assessment information: See Napa County Environmental Management assessment detail.

Time and place of regularly scheduled board meetings for public participation: n/a

For more information, contact: Oakville Pump Service Phone: 707-944-2471

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	8/31/16	5	0.00	0	15	0.2		Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	8/31/16	5	0.00	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	10/18/18	32.5 mg/L	29 - 36	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	10/18/18	210 mg/L	170 - 250	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic	10/8/18	3.45 ug/L	0 – 6.9	10 ug/L		Erosion of natural deposits; runoff from orchards; glass & electronic production wastes
Fluoride	10/8/18	.13 mg/L	.13 - .13	2 mg/L		Water additive that promotes strong teeth; discharge from aluminum factories; erosion of natural deposits
Barium	10/8/18	91 ug/L	62 - 120	1000 ug/L		Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits.
Nickel	10/8/18	1.3 ug/L	1.2 – 1.4	100		Erosion of natural deposits; discharge from metal factories
Gross Alpha	10/8/18	0.53 Pc/L	0.81 – 0.2440	15 PC/L		Erosion of natural deposits.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Bicarbonate	10/8/18	285 mg/L	270 - 300			Byproduct of the dissolution of carbon dioxide
Calcium	10/8/18	23.5 mg/L	17 - 30			Leaching from natural deposits
Chloride	7/11/17	18.5 mg/L	17 - 20	500 mg/L		Runoff/leaching from natural deposits; seawater influence
*Color	7/11/17	39.5 Units	3 - 76	15.00 Units		Indicative of elevated levels of dissolved organic material
Magnesium	10/8/18	30.5 mg/L	18 – 43			Leaching from natural deposits
*Manganese	10/8/18	480 ug/L	330 - 630	50 ug/L		Leaching from natural deposits
pH	10/8/18	7.4	7.3-7.5			Measure of acidity in water.
Total Dissolved Solids	7/11/17	330 mg/L	340 - 350	1000mg/L		Naturally-occurring organic materials
*Turbidity	7/11/17	7.47 NTU	.94 - 14	5.00 NTU		Measure of cloudiness in water
Specific Conductance	2/4/15	460 uMhos	380 - 540	1600 uMhos		Substances that form ions when in water; seawater influence
Sulfate	7/11/17	14.35 mg/L	3.7 - 25	500 mg/L		Leaching from natural deposits
Alkalinity	2/4/15	230 mg/L	220 - 240			Erosion of brass & copper piping.
*Iron	2/4/15	495 mg/L	210 – 780	300		Leaching from natural deposits; industrial wastes
*Odor	7/11/17	24 units	8 - 40	3		Naturally-occurring organic materials

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Toluene	2/22/12	0.275 ug/L	0 – 0.55	150 ug/L	Discharge from petroleum and chemical factories; underground gas tank leaks

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Grgich Hills Winery is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
Manganese	Level of manganese was detected to be over the Federal MCL in the from the raw water sample taken from the well on 2/4/15	Ongoing since 2/22/12	System has Napa County Environmental Management approved water treatment equipment in place that effectively removes the manganese. There is no detection of manganese in the distribution system.	Exposure to high concentrations of manganese over the course of years has been associated with toxicity to the nervous system. Producing a syndrome resembling Parkinsonism. This type of effect may be more likely to occur in the elderly.
Iron	Average level of iron in the source water tested 495 mg/L, over the MCL of 300 on 2/4/15	Ongoing since 2/4/15	System has water softener system in place that effectively removes the iron.	None - aesthetical only
Color	Average level of color in the source water tested at 39.5 units, over the MCL of 15 on 7/11/17	Ongoing since 7/11/17	The color is related to the iron in the source water. With the iron removed from the water prior to it going into the distribution system, the is no issue with color.	None - aesthetical only

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT, cont'd

Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
Odor	Average level of odor in the source water tested at 24 units, over the MCL of 3 on 7/11/17	Ongoing since 7/11/17	System has no treatment. Anode rods are replaced relatively frequently in the water heaters to combat odor in hot water in tasting room dishwasher. That is the only location where it has been an issue	None - aesthetical only
Turbidity	Average turbidity of source water was measured at 7.47 NTU, over the MCL of 5 on 7/11/17.	Ongoing since 7/11/17	The turbidity is related to the iron in the source water. With the iron removed from the water prior to it going into the distribution system, there is no issue with turbidity.	None - aesthetical only

For Water Systems Providing Groundwater as a Source of Drinking Water**TABLE 7 – SAMPLING RESULTS SHOWING
FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLES**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year) 0	0	0	(0)	Human and animal fecal waste
Enterococci	(In the year) 0	0	TT	N/A	Human and animal fecal waste
Coliphage	(In the year) 0	0	TT	N/A	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Groundwater Source Samples,
Uncorrected Significant Deficiencies, or Groundwater TT****SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLE**

None to report.

SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES

None to report.

VIOLATION OF GROUNDWATER TT

TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
one to report.				