

Your 2024 Water Quality Report

The Knowledge You Need for Continued Consumer Confidence

Look inside to see how our water quality
is equal to or better than what is required to safeguard public health.



LAGUNA BEACH
COUNTY WATER DISTRICT

306 Third Street
Laguna Beach, California 92651

PRESORT STD
U.S. Postage
PAID
Santa Ana, CA
Permit No. 1208

ECRWSS

POSTAL CUSTOMER



You Can Have Confidence in the Quality of Your Water

The Laguna Beach County Water District is pleased to distribute this report to its water customers. It provides important information about where your water comes from and the work we perform each day to assure the water delivered to your tap meets all Federal and State drinking water standards.

The tap water that comes out of your faucet has to meet rigorous Federal and State regulatory standards; otherwise, we wouldn't be able to deliver it to your home.

Our annual water quality report shares details about the water you receive. You can see for yourself that we are meeting and even exceeding standards required to maintain water quality.

Take a look inside for details on water sources, the constituents found in the water, and how

our water compares with Federal and State standards. The Laguna Beach County Water District is committed to safeguarding its water supply and ensuring that your tap water is safe to drink. We also strive to keep you informed about the quality of your water supply.

Want to Learn More About Your Water's Quality?

For information about this report, or your water quality in general, please contact the Water Quality Specialist at (949) 464-3117, or visit the LBCWD's website at www.lbcwd.org.

For more information about the health effects of the listed contaminants in the following tables, call the USEPA hotline at (800) 426-4791.

Please check our website at www.lbcwd.org for the dates and times of the monthly Water District Commission Meetings at 306 Third Street in the City of Laguna Beach. You are encouraged to participate in these meetings.

LAGUNA BEACH COUNTY WATER DISTRICT



WATER QUALITY IS
OUR TOP PRIORITY

Your 2024 Water Quality Report

IMPORTANT INFORMATION ABOUT YOUR WATER

Your 2024 Water Quality Report

Since 1990, California public water utilities have been providing an annual Water Quality Report to their customers. **This year's report covers calendar year 2023 drinking water quality testing and reporting.** Laguna Beach County Water District (LBCWD) vigilantly safeguards its water supply and, as in years past, the water delivered meets the quality standards required by federal and state regulatory agencies. The U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board, Division of Drinking Water (DDW) are the agencies responsible for establishing and enforcing drinking water quality standards.

In some cases, LBCWD goes beyond what is required by testing for unregulated chemicals that may have known health risks but do not have drinking water standards. Unregulated chemical monitoring helps USEPA and DDW determine where certain chemicals occur and whether new standards need to be established for



Whitsett Intake Pumping Plant on the Colorado River.

Quality Water is Our Priority

Turn the tap and the water flows, as if by magic. Or so it seems. The reality is considerably different, however. Delivering high-quality drinking water to our customers is a scientific and engineering feat that requires considerable effort and talent to ensure the water is always there, always safe to drink.



Because tap water is highly regulated by state and federal laws, water treatment and distribution operators must be licensed and are required to complete on-the-job training and technical education before becoming a state certified operator.

Our licensed water professionals have an understanding of a wide range of subjects, including mathematics, biology, chemistry, physics, and engineering. Some of the tasks they complete on a regular basis include:

- Operating and maintaining equipment to purify and clarify water;
- Monitoring and inspecting machinery, meters, gauges, and operating conditions;
- Conducting tests and inspections on water and evaluating the results;
- Documenting and reporting test results and system operations to regulatory agencies; and
- Serving our community through customer support, education, and outreach.

So, the next time you turn on your faucet, think of the skilled professionals who stand behind every drop.

those chemicals to protect public health.

Through drinking water quality testing programs, your drinking water is constantly monitored from source to tap for constituents that are both regulated and unregulated.

The State allows water agencies to monitor for some constituents less than once per year because the concentrations of these constituents do not change frequently. Some of the data, though representative, are more than one year old.

This report contains important information about your drinking water. Translate it, or speak with someone who understands it.

Este informe contiene información muy importante sobre su agua potable. Para mas información ó traducción, favor de contactar a Customer Service Representative. Telefono: (949) 464-3117.

يحتوي هذا التقرير على معلومات هامة عن نوعية ماء الشرب في منطقتك. يرجى ترجمته، أو ابحث التقرير مع صديق لك يفهم هذه المعلومات جيداً.

이 보고서에는 귀하가 거주하는 지역의 수질에 관한 중요한 정보가 들어 있습니다. 이것을 번역하거나 충분히 이해하시는 친구와 상의하십시오.

Bản báo cáo có ghi những chi tiết quan trọng về phẩm chất nước trong cộng đồng quý vị. Hãy nhờ người thông dịch, hoặc hỏi một người bạn biết rõ về vấn đề này.

这份报告中有些重要的信息，讲到关于您所在社区的水的品质。请您找人翻译一下，或者请能看得懂这份报告的朋友给您解释一下。

この資料には、あなたの飲料水についての大切な情報が書かれています。内容をよく理解するために、日本語に翻訳して読むか説明を受けてください。

2023 Santa Ana Basin Groundwater Quality

Chemical	MCL	PHG (MCLG)	Average Amount	Range of Detections	MCL Violation?	Most Recent Sampling Date	Typical Source of Contaminant
Radiologicals							
Uranium (pCi/L)	20	0.43	2.87	ND – 5.54	No	2019	Erosion of Natural Deposits
Inorganic Chemicals							
Arsenic (ppb)	10	0.004	2.2	ND – 4.1	No	2023	Erosion of Natural Deposits
Barium (ppm)	1	2	<0.1	ND – 0.1	No	2023	Erosion of Natural Deposits
Fluoride (ppm)	2	1	0.42	0.33 – 0.47	No	2023	Erosion of Natural Deposits
Nitrate (ppm as N)	10	10	1.39	ND – 2.73	No	2023	Fertilizers, Septic Tanks
Nitrate+Nitrite (ppm as N)	10	10	1.39	ND – 2.73	No	2023	Fertilizers, Septic Tanks
Secondary Standards*							
Chloride (ppm)	500*	n/a	40	8.2 – 79	No	2023	Erosion of Natural Deposits
Manganese (ppb)	50*	n/a	1.2	ND – 2.6	No	2023	Erosion of Natural Deposits
Specific Conductance (µmho/cm)	1,600*	n/a	547	182 – 963	No	2023	Erosion of Natural Deposits
Sulfate (ppm)	500*	n/a	76	10 – 153	No	2023	Erosion of Natural Deposits
Total Dissolved Solids (ppm)	1000*	n/a	352	108 – 638	No	2023	Erosion of Natural Deposits
Turbidity (NTU)	5*	n/a	<0.10	ND – 0.10	No	2023	Erosion of Natural Deposits
Unregulated Chemicals							
Alkalinity, total (ppm as CaCO ₃)	Not Regulated	n/a	143	67.3 – 224	n/a	2023	Erosion of Natural Deposits
Bicarbonate (ppm as HCO ₃)	Not Regulated	n/a	174	82 – 273	n/a	2023	Erosion of Natural Deposits
Boron (ppm)	NL = 1	n/a	0.16	0.12 – 0.19	n/a	2023	Erosion of Natural Deposits
Calcium (ppm)	Not Regulated	n/a	64.5	12.9 – 127	n/a	2023	Erosion of Natural Deposits
Hardness, total (ppm as CaCO ₃)	Not Regulated	n/a	225	47.5 – 415	n/a	2023	Erosion of Natural Deposits
Hardness, total (grains/gallon)	Not Regulated	n/a	13	2.8 – 24	n/a	2023	Erosion of Natural Deposits
Magnesium (ppm)	Not Regulated	n/a	10.7	1.5 – 23.5	n/a	2023	Erosion of Natural Deposits
Perfluoro Hexane Sulfonic Acid (ppt)**	NL = 3	n/a	<3	ND	n/a	2023	Industrial Discharge
Perfluoro Octane Sulfonic Acid (ppt)**	NL = 6.5	n/a	<4	ND	n/a	2023	Industrial Discharge
pH (units)	Not Regulated	n/a	7.9	7.5 – 8.2	n/a	2023	Acidity, Hydrogen Ions
Potassium (ppm)	Not Regulated	n/a	2.8	1.5 – 4.4	n/a	2023	Erosion of Natural Deposits
Sodium (ppm)	Not Regulated	n/a	41.0	24.1 – 51.9	n/a	2023	Erosion of Natural Deposits
Vanadium (ppb)	NL = 50	n/a	3.8	ND – 7.4	n/a	2023	Erosion of Natural Deposits

ppb = parts-per-billion; ppm = parts-per-million; ppt = parts-per-trillion; pCi/L = picoCuries per liter; NTU = nephelometric turbidity units; < = average is less than the detection limit for reporting purposes; MCL = Maximum Contaminant Level; PHG = California Public Health Goal; NL = Notification Level; µmho/cm = micromho per centimeter; ND = not detected; n/a = not applicable

* Contaminant is regulated by a secondary standard to maintain aesthetic qualities (taste, odor, color).

**Detections of perfluoro hexane sulfonic acid (PFHxS) and perfluoro octane sulfonic acid (PFOS) are in the City of Newport Beach shallow wells. Through blending treatment and as a result, the City of Newport Beach reservoir has no detections of these two chemicals, which serves water to customers.

Unregulated Chemicals Requiring Monitoring at Entry Points to the Distribution System

Chemical	Notification Level	PHG	Average Amount	Range of Detections	Most Recent Sampling Date
Manganese (ppb)***	SMCL = 50	n/a	0.86	0.86	2019

SMCL = Secondary MCL

***Manganese is regulated with a secondary standard of 50 ppb but was not detected, based on the detection limit for purposes of reporting of 20 ppb. Manganese was included as part of the unregulated chemicals requiring monitoring.

Source Water Assessments

Imported (MWDSC) Water Assessment

Every five years, MWDSC is required by DDW to examine possible sources of drinking water contamination in its State Water Project and Colorado River source waters.

The most recent surveys for MWDSC's source waters are the Colorado River Watershed Sanitary Survey — 2020 Update, and the State Water Project Watershed Sanitary Survey — 2021 Update.

Water from the Colorado River is considered to be most vulnerable to contamination from recreation, urban/storm-water runoff, increasing urbanization in the watershed, and wastewater. Water supplies from Northern California's State Water Project are most vulnerable to contamination from urban/stormwater runoff, wildlife, agriculture, recreation, and wastewater.

USEPA also requires MWDSC to complete one Source Water Assessment (SWA) that utilizes information collected in the watershed sanitary surveys. MWDSC completed its

SWA in December 2002. The SWA is used to evaluate the vulnerability of water sources to contamination and helps determine whether more protective measures are needed.

A copy of the most recent summary of either Watershed Sanitary Survey or the SWA can be obtained by calling MWDSC at (800) CALL-MWD (225-5693).

Groundwater Assessment

An assessment of our groundwater sources from the Santa Ana Basin was completed in December 2002 and is updated on a continuing basis. The groundwater sources are considered most vulnerable to the following activities not associated with detected contaminants: dry cleaners, gas stations, and known contaminant plumes. A copy of the complete assessment is available at State Water Resources Control Board, Division of Drinking Water, Santa Ana District, 2 MacArthur Place, Suite 150, Santa Ana, California 92707. You may request a summary of the assessment by contacting the Water Quality Specialist at (949) 464-3117.

2023 Metropolitan Water District of Southern California Treated Surface Water						
Chemical	MCL	PHG (MCLG)	Average Amount	Range of Detections	MCL Violation?	Typical Source of Chemical
Radiologicals – Tested in 2023						
Gross Alpha Particle Activity (pCi/L)	15	(0)	ND	ND – 5	No	Erosion of Natural Deposits
Gross Beta Particle Activity (pCi/L)	50	(0)	ND	ND – 6	No	Decay of Natural and Man-made Deposits
Uranium (pCi/L)	20	0.43	1	ND – 3	No	Erosion of Natural Deposits
Inorganic Chemicals – Tested in 2023						
Aluminum (ppm)	1	0.6	0.105	ND – 0.07	No	Treatment Process Residue, Natural Deposits
Bromate (ppb)	10	0.1	ND	ND – 6.3	No	Byproduct of Drinking Water Ozonation
Fluoride (ppm)	2	1	0.7	0.6 – 0.8	No	Water Additive for Dental Health
Nitrate (as Nitrogen) (ppm)	10	10	0.7	0.7	No	Fertilizers, Septic Tanks
Secondary Standards* – Tested in 2023						
Aluminum (ppb)	200*	600	105	ND – 70	No	Treatment Process Residue, Natural Deposits
Chloride (ppm)	500*	n/a	66	42 – 91	No	Runoff or Leaching from Natural Deposits
Color (color units)	15*	n/a	2	1 – 2	No	Naturally-occurring Organic Materials
Odor (threshold odor number)	3*	n/a	2	2	No	Naturally-occurring Organic Materials
Specific Conductance (µmho/cm)	1,600*	n/a	642	424 – 859	No	Substances that Form Ions in Water
Sulfate (ppm)	500*	n/a	122	70 – 175	No	Runoff or Leaching from Natural Deposits
Total Dissolved Solids (ppm)	1,000*	n/a	394	253 – 534	No	Runoff or Leaching from Natural Deposits
Unregulated Chemicals – Tested in 2023						
Alkalinity, total as CaCO ₃ (ppm)	Not Regulated	n/a	84	66 – 102	n/a	Runoff or Leaching from Natural Deposits
Boron (ppm)	NL = 1	n/a	0.13	0.13	n/a	Runoff or Leaching from Natural Deposits
Calcium (ppm)	Not Regulated	n/a	38	25 – 52	n/a	Runoff or Leaching from Natural Deposits
Hardness, total as CaCO ₃ (ppm)	Not Regulated	n/a	160	99 – 220	n/a	Runoff or Leaching from Natural Deposits
Hardness, total (grains/gallon)	Not Regulated	n/a	9.4	5.8 – 13	n/a	Runoff or Leaching from Natural Deposits
Lithium (ppb)	Not Regulated	n/a	15	ND – 30	n/a	Various Natural and Man-made Sources
Magnesium (ppm)	Not Regulated	n/a	15	9.6 – 21	n/a	Runoff or Leaching from Natural Deposits
pH (pH units)	Not Regulated	n/a	8.5	8.5	n/a	Hydrogen Ion Concentration
Potassium (ppm)	Not Regulated	n/a	3.4	2.6 – 4.3	n/a	Runoff or Leaching from Natural Deposits
Sodium (ppm)	Not Regulated	n/a	69	47 – 91	n/a	Runoff or Leaching from Natural Deposits
Total Organic Carbon (ppm)	TT	n/a	2.4	2.1 – 3	n/a	Various Natural and Man-made Sources

ppb = parts per billion; ppm = parts per million; pCi/L = picoCuries per liter; µmho/cm = micromhos per centimeter; ND = not detected; TT = treatment technique
MCL = Maximum Contaminant Level; (MCLG) = Federal MCL Goal; PHG = California Public Health Goal; NL = Notification Level; n/a = not applicable

*Chemical is regulated by a secondary standard.

Turbidity – combined filter effluent Metropolitan Water District Diemer Filtration Plant	Treatment Technique	Turbidity Measurements	TT Violation?	Typical Source of Chemical
1) Highest single turbidity measurement (NTU)	0.3	0.08	No	Soil Runoff
2) Percentage of samples less than or equal to 0.3 NTU	95%	100%	No	Soil Runoff
Turbidity is a measure of the cloudiness of the water, an indication of particulate matter, some of which might include harmful microorganisms. NTU = nephelometric turbidity units Low turbidity in Metropolitan's treated water is a good indicator of effective filtration. Filtration is called a "treatment technique" (TT). A treatment technique is a required process intended to reduce the level of chemicals in drinking water that are difficult and sometimes impossible to measure directly.				

Unregulated Chemicals Requiring Monitoring					
Chemical	Notification Level	PHG	Average Amount	Range of Detections	Most Recent Sampling Date
Manganese (ppb)**	SMCL = 50	n/a	2.75	1.4 – 4.1	2019
SMCL = Secondary MCL					

**Manganese is regulated with a secondary standard of 50 ppb but was not detected, based on the detection limit for purposes of reporting of 20 ppb.
Manganese was included as part of the unregulated chemicals requiring monitoring.

2023 Laguna Beach County Water District Distribution System Water Quality					
Disinfection Byproducts	MCL (MRDL/MRDLG)	Average Amount	Range of Detections	MCL Violation?	Typical Source of Contaminant
Total Trihalomethanes (ppb)	80	46	9.3 – 61	No	Byproducts of Chlorine Disinfection
Haloacetic Acids (ppb)	60	20	3.2 – 25	No	Byproducts of Chlorine Disinfection
Chlorine Residual (ppm)	(4 / 4)	1.7	0.04 – 3.24	No	Disinfectant Added for Treatment
Aesthetic Quality					
Color (color units)	15*	1	1	No	Erosion of Natural Deposits
Odor (threshold odor number)	3*	1	1	No	Erosion of Natural Deposits
Turbidity (NTU)	5*	0.19	0.1 – 0.46	No	Erosion of Natural Deposits

Four locations in the distribution system are tested quarterly for trihalomethanes and haloacetic acids; twelve locations are tested monthly for color, odor and turbidity.
MRDL = Maximum Residual Disinfectant Level; MRDLG = Maximum Residual Disinfectant Level Goal

*Contaminant is regulated by a secondary standard to maintain aesthetic qualities (taste, odor, color).

Lead and Copper Action Levels at Residential Taps					
	Action Level (AL)	Public Health Goal	90 th Percentile Value	Sites Exceeding AL / Number of Sites	AL Violation?
Lead (ppb)	15	0.2	ND	0 / 34	No
Copper (ppm)	1.3	0.3	0.12	0 / 34	No

Every three years, at least 30 residences are tested for lead and copper at-the-tap. The most recent set of samples was collected in 2023. Lead was not detected any homes. Copper was detected in 10 homes; none exceeded the regulatory action level. A regulatory action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Unregulated Chemicals Requiring Monitoring in the Distribution System					
Chemical	Notification Level	PHG	Average Amount	Range of Detections	Most Recent Sampling Date
Haloacetic acids (HAA5) (ppb)	n/a	n/a	7.8	5.5 – 11.5	2019
Haloacetic acids (HAA6Br) (ppb)	n/a	n/a	10.2	7.87 – 13.6	2019
Haloacetic acids (HAA9) (ppb)	n/a	n/a	15.7	11.9 – 21.7	2019

Constant Monitoring Ensures Continued Excellence

Sources of Supply

Your drinking water is surface water imported by Metropolitan Water District of Southern California (MWDSC) and ground-water from the Santa Ana Basin. MWDSC's imported water sources are the Colorado River and the State Water Project, which draws water from the Sacramento-San Joaquin River Delta. Groundwater comes from a natural underground aquifer that is replenished with water from the Santa Ana River, local rainfall, and imported water. The groundwater basin is 350 square miles and lies beneath north and central Orange County from Irvine to the Los Angeles County border and from Yorba Linda to the Pacific Ocean. More than 20 cities and retail water districts draw from the ground-water basin to provide water to homes and businesses.



Parker Dam on the Colorado River

Basic Information About Drinking Water Contaminants

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the layers of the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animal and human activity.

- Contaminants that may be present in source water include:
- ◆ **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
 - ◆ **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, and farming.
 - ◆ **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
 - ◆ **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production or mining activities.

- ◆ **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gasoline stations, urban stormwater runoff, agricultural application, and septic systems.
- In order to ensure that tap water is safe to drink, USEPA and the DDW prescribe regulations

that limit the amount of certain contaminants in water provided by public water systems.

The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791.

Drinking Water Fluoridation

Fluoride has been added to U.S. drinking water supplies since 1945. Of the 50 largest cities in the U.S., 43 fluoridate their drinking water. In December 2007, MWDSC joined a majority of the nation's public water suppliers in adding fluoride to drinking water in order to prevent tooth decay. MWDSC was in compliance with all provisions of the State's fluoridation system requirements. Fluoride levels in drinking water are limited under California state regulations at a maximum dosage of 2 parts per million.



There are many places to go for additional information about the fluoridation of drinking water:

U.S. Centers for Disease Control and Prevention
www.cdc.gov/fluoridation/

State Water Resources Control Board, Division of Drinking Water
www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Fluoridation.html

For more information about MWDSC's fluoridation program, please contact Edgar G. Dymally at edymally@mwdh2o.com or call him at (213) 217-5709.

— To Safeguard Against Issues that May Affect Your Health —

We Comply with All State & Federal Water Quality Regulations

Cryptosporidium

Cryptosporidium is a microscopic organism that, when ingested, can cause diarrhea, fever, and other gastrointestinal symptoms. The organism comes from animal and/or human wastes and may be in surface water. The MWDSC tested their source water and treated surface water for *Cryptosporidium* in 2023 but did not detect it. If it ever is detected, *Cryptosporidium* is eliminated by an effective treatment combination including sedimentation, filtration, and disinfection.

The USEPA and the federal Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from USEPA's Safe Drinking Water Hotline at (800) 426-4791, or on the web at www.epa.gov/safewater.



Immunocompromised People

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, such as those with cancer who are undergoing chemotherapy, persons who have had organ transplants, people with HIV/AIDS or other immune system disorders, some elderly persons, and infants can be particularly at risk to infection. These people should seek advice about drinking water from their health care providers.



Disinfectant and Disinfection Byproducts

Disinfection of drinking water was one of the major public health advances in the 20th century. Disinfection was a major factor in reducing waterborne disease epidemics caused by pathogenic bacteria and viruses, and it remains an essential part of drinking water treatment today.

Chlorine disinfection has almost completely eliminated from our lives the risks of microbial waterborne diseases. Chlorine is added to your drinking water at the source of supply (surface water treatment plant). Enough chlorine is added so that it does not completely dissipate through the distribution system pipes. This "residual" chlorine helps to prevent the growth of bacteria in the pipes that carry drinking water from the source into your home.

However, chlorine can react with naturally-occurring materials in the water to form unintended chemical byproducts, called disinfection byproducts (DBPs), which may pose health risks. A major challenge is how to balance the risks from microbial pathogens and DBPs. It is important to provide protection from these microbial pathogens while simultaneously ensuring decreasing health risks from disinfection byproducts. The Safe Drinking Water Act requires the



USEPA to develop rules to achieve these goals.

Trihalomethanes (THMs) and Haloacetic Acids (HAAs) are the most common and most studied DBPs found in drinking water treated with chlorine. In 1979, the USEPA set the maximum amount of total THMs allowed in drinking water at 100 parts per billion as an annual running average. Effective in January 2002, the Stage 1 Disinfectants/Disinfection Byproducts Rule lowered the total THM maximum annual average level to 80 parts per




billion and added HAAs to the list of regulated chemicals in drinking water. Your drinking water complies with the Stage 1 Disinfectants/Disinfection Byproducts Rule.

Stage 2 of the regulation was finalized by USEPA in 2006, which further controls allowable levels of DBPs in drinking water without compromising disinfection itself. A required distribution system evaluation was completed in 2008, and a Stage 2 monitoring plan has been approved by DDW. Full Stage 2 compliance began in 2012.

About Lead in Tap Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

The LBCWD is responsible for providing high quality drinking water, but cannot control the variety of materials used in on-site plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for



30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. The LBCWD can provide a list of approved testing facilities, but the cost for testing is your responsibility.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline, (800) 426-4791, or at: www.epa.gov/safewater/lead.

Water Conservation: A Little Effort Can Save a Lot of Water *and Money*

LBCWD promotes the conservation of water to its residents so the District can preserve this scarce resource and save residents money in the process.

Water is brought to Southern California via large aqueduct systems that feed off of rivers from the Central Valley and the Colorado River. There are large costs involved in maintaining these systems and transporting the water over miles of deserts, valleys, and mountain ranges. The MWDSC

is the main supplier of this water and controls the vast network of aqueducts, pumping stations, and filtration plants.

Local municipal water suppliers do have the ability to tap into underground aquifers, but this local supply of water is not enough to meet the demands of the residents; the more expensive "aqueduct" water must be used to meet the demand. For these reasons, it is recommended that you conserve water by reducing water waste. This will save you money as well.

Chart Legend

What are Water Quality Standards?

Drinking water standards established by USEPA and DDW set limits for substances that may affect consumer health or aesthetic qualities of drinking water. The charts in this report show the following types of water quality standards:

- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Secondary MCLs:** Set to protect the odor, taste, and appearance of drinking water.
- **Primary Drinking Water Standard:** MCLs for contaminants that affect health along with their monitoring and reporting requirements and water treatment requirements.
- **Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

How are Contaminants Measured?

Water is sampled and tested throughout the year. Contaminants are measured in:

- parts per million (ppm) or milligrams per liter (mg/L)
- parts per billion (ppb) or micrograms per liter (µg/L)
- parts per trillion (ppt) or nanograms per liter (ng/L)

What is a Water Quality Goal?

In addition to mandatory water quality standards, USEPA and DDW have set voluntary water quality goals for some contaminants. Water quality goals are often set at such low levels that they are not achievable in practice and are not directly measurable. Nevertheless, these goals provide useful guideposts and direction for water management practices. The charts in this report include three types of water quality goals:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by USEPA.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.