



**Grizzly Ranch Community Services District**  
**Consumer Confidence Report**  
**Water System**  
**2022**

## 2022 Consumer Confidence Report

### Water System Information

Water System Name: Grizzly Ranch Community Services District

Report Date: 6/7/23

Type of Water Source(s) in Use: Wells

Name and General Location of Source(s): Well 3P2 – Fox Sparrow Dr., Well 9M – Fox Sparrow Dr., Well 1P – Yarrow Ln.

Drinking Water Source Assessment Information:

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Grizzly Ranch CSD Board Meetings are scheduled on a Fiscal Year quarterly basis in the months of September, December, March and June. Meetings typically are scheduled on the third Tuesday of each month. Meetings are typically scheduled at 9am. Regularly scheduled Board Meetings have been conducted remotely in hybrid fashion via zoom video and phone accessibility. Board Meeting schedules, agendas and minutes are available at: [www.grizzlyranchcsd.com](http://www.grizzlyranchcsd.com).

For More Information, Contact: Office Administrator Carol Logan or General Manager Larry Smith at phone: 530-832-4716 or email: [grizzlyranchcsd@gmail.com](mailto:grizzlyranchcsd@gmail.com).

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Grizzly Ranch CSD a 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Grizzly Ranch CSD以获得中文的帮助: 4456 Grizzly Rd. Portola, CA 96122, 530-832-4716

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Grizzly Ranch CSD, 4456 Grizzly Rd. Portola, CA. 96122 o tumawag sa 530-832-4716 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Grizzly Ranch CSD tại 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Grizzly Ranch CSD ntawm 4456 Grizzly Rd. Portola, CA. 96122, 530-832-4716 rau kev pab hauv lus Askiv.

## Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)

Term	Definition
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants can be naturally-occurring, or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do

not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	7/14/2020 to 7/22/2020	5	.001	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	7/14/2020 to 7/22/2020	5	.021	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/14/20	13	0	None	None	Salt present in the water and is generally naturally occurring

Hardness (ppm)	4/14/20	187		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
----------------	---------	-----	--	------	------	--

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
See attachments for breakdowns						

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
See attachments for breakdowns						

**Table 6. Detection of Unregulated Contaminants**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
See attachments for breakdowns					

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the

water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Grizzly Ranch CSD is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

**Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*:** While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic from Well 1P. We do not utilize this well for potable water, if GRCSO would need to operate this well for potable water we do possess means of filtration. The arsenic standard balances the current understanding of arsenic’s possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**State Revised Total Coliform Rule (RTCR):** [Enter Additional Information Described in Instructions for SWS CCR Document]

**Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

**Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement**

<b>Violation</b>	<b>Explanation</b>	<b>Duration</b>	<b>Actions Taken to Correct Violation</b>	<b>Health Effects Language</b>
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

**For Water Systems Providing Groundwater as a Source of Drinking Water**

**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	N/A	0	(0)	Human and animal fecal waste
Enterococci	0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	0	N/A	TT	N/A	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT**

**Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A**

**Special Notice for Uncorrected Significant Deficiencies: N/A**

**Table 9. Violation of Groundwater TT**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

**For Systems Providing Surface Water as a Source of Drinking Water**

**Table 10. Sampling Results Showing Treatment of Surface Water Sources**

Treatment Technique <sup>(a)</sup> (Type of approved filtration technology used)	NA
Turbidity Performance Standards <sup>(b)</sup> (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month. 2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours. 3 – Not exceed [Enter Turbidity Performance Standard Not to

	Be Exceeded at Any Time] NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	N/A
Highest single turbidity measurement during the year	N/A
Number of violations of any surface water treatment requirements	N/A

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

**Summary Information for Violation of a Surface Water TT**

**Table 11. Violation of Surface Water TT**

<b>Violation</b>	<b>Explanation</b>	<b>Duration</b>	<b>Actions Taken to Correct Violation</b>	<b>Health Effects Language</b>
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

**Summary Information for Operating Under a Variance or Exemption**

NA

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: DISINFECTION BYPROD

CLASS: DBPT

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_DST_900		GRIZZLY RANCH CSD					DISINFECTION BYPROD													
	DBP	DISINFECTION BYPRODUCTS																		
		2943	BROMODICHLOROMETHANE	1.000		1.000	UG/L	-----	1	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 551.1
		2942	BROMOFORM	3.000		1.000	UG/L	-----	1	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 551.1
		2941	CHLOROFORM		<	1.000	UG/L	-----	1	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 551.1
		2454	DIBROMOACETIC ACID		<	1.000	UG/L	-----	1	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 552.2
		2944	DIBROMODICHLOROMETHANE	2.000		1.000	UG/L	-----	1	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 551.1
		2451	DICHLOROACETIC ACID		<	1.000	UG/L	-----	1	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 552.2
		2456	TOTAL HALOACETIC ACIDS (HAA5)		<	6.000	UG/L	60	-----	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 552.2
		2453	MONOBROMOACETIC ACID		<	1.000	UG/L	-----	1	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 552.2
	2450	MONOCHLOROACETIC ACID		<	2.000	UG/L	-----	2	8/17/2021	3	36			2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 552.2	
	2950	TTHM	6.000		4.000	UG/L	80	-----	8/17/2021	3	36			2024/08		CH 2176620-001 ADD2	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 551.1	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY:

Sample Point:

CLASS: DBPT

STATUS:

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MONTHS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_DST_900	DBP	2452 TRICHLORO ACETIC ACID		<	1.000		UG/L	-----	1	8/17/2021	3	36		2024/08		CH 2176620-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 552.2

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: TREATMENT PLANT (AS, FE & MN)

CLASS: TRMT

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_005_005		GRIZZLY RANCH CSD					TREATMENT PLANT (AS, FE & MN)												
	GP	SECONDARY/GP																	
		1028	IRON		<	100.000	UG/L	300	100	12/15/2022	15	3	Interval	2023/03	<b>DUE NOW</b>	CH 2290335-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1032	MANGANESE		<	20.000	UG/L	50	20	12/15/2022	15	3	Interval	2023/03	<b>DUE NOW</b>	CH 2290335-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
	IO	INORGANIC																	
	1005	ARSENIC		<	2.000	UG/L	10	2	12/15/2022	15	3	Interval	2023/03	<b>DUE NOW</b>	CH 2290335-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 1P

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_001_001		GRIZZLY RANCH CSD					WELL 1P													
	GP	SECONDARY/GP																		
		1928	ALKALINITY, BICARBONATE	80.000		0.000	MG/L	-----	-----	4/18/2017	1	108			2026/04		81060011 70418094 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1919	CALCIUM	302.000		0.000	MG/L	-----	-----	4/18/2017	1	108			2026/04		81060011 70418094 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1929	ALKALINITY, CARBONATE		<	10.000	MG/L	-----	-----	4/18/2017	1	108			2026/04		81060011 70418094 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1017	CHLORIDE	4.000		0.000	MG/L	500	-----	4/18/2017	4	108			2026/04		81060011 70418094 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1905	COLOR		<	5.000	UNITS	15	-----	4/14/2020	4	108			2029/04		81060012 00414115 6G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1022	COPPER, FREE		<	50.000	UG/L	1000	50	4/18/2017	5	108			2026/04		81060011 70418094 5L	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2905	FOAMING AGENTS (SURFACTANTS)		<	0.100	MG/L	0.5	-----	4/18/2017	4	108			2026/04		81060011 70418094 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1915	HARDNESS, TOTAL (AS CaCO3)	832.000		0.000	MG/L	-----	-----	4/18/2017	1	108			2026/04		81060011 70418094 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1021	HYDROXIDE AS CALCIUM CARBONATE		<	10.000	MG/L	-----	-----	4/18/2017	1	108			2026/04		81060011 70418094 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1028	IRON	2110.000		100.000	UG/L	300	100	1/24/2023	46	3	Interval		2023/04		CH 2370428-002	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1031	MAGNESIUM	19.000		0.000	MG/L	-----	-----	4/18/2017	1	108			2026/04		81060011 70418094 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1032	MANGANESE	700.000		20.000	UG/L	50	20	1/24/2023	46	3	Interval		2023/04		CH 2370428-002	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 1P

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_001_001	GP	<b>SECONDARY/GP</b>																		
		1920	ODOR		<	1.000		TON	3	1	4/14/2020	4	108		2029/04		81060012004141156G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1925	PH	6.800		0.000		pH	-----	-----	4/18/2017	4	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1050	SILVER		<	10.000		UG/L	100	10	4/18/2017	5	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1052	SODIUM	44.000		0.000		MG/L	-----	-----	4/18/2017	1	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1064	CONDUCTIVITY @ 25 C UMHOS/CM	1530.000		0.000		UMHO/CM	1600	-----	4/18/2017	4	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1055	SULFATE	798.000		0.500		MG/L	500	0.5	4/18/2017	4	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1930	TDS	1340.000		0.000		MG/L	1000	-----	4/18/2017	4	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		0100	TURBIDITY	0.300		0.100		NTU	5	0.1	4/14/2020	4	108		2029/04		81060012004141156G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1095	ZINC	320.000		50.000		UG/L	5000	50	4/18/2017	5	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	IO	<b>INORGANIC</b>																		
		1002	ALUMINUM	50.000		50.000		UG/L	1000	50	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1074	ANTIMONY, TOTAL		<	6.000		UG/L	6	6	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1005	ARSENIC	15.000		2.000		UG/L	10	2	1/24/2023	46	3	Interval	2023/04		CH 2370428-002	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 1P

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD		
CA3205006_001_001	IO	<b>INORGANIC</b>																			
		1010	BARIUM		<	100.000		UG/L	1000	100	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1075	BERYLLIUM, TOTAL		<	1.000		UG/L	4	1	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1015	CADMIUM		<	1.000		UG/L	5	1	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1020	CHROMIUM		<	10.000		UG/L	50	10	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1025	FLUORIDE	0.200		<	0.100		MG/L	2	0.1	4/18/2017	4	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1035	MERCURY		<	1.000		UG/L	2	1	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1036	NICKEL		<	10.000		UG/L	100	10	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1039	PERCHLORATE		<	4.000		UG/L	6	4	4/9/2019	6	36		2022/04	<b>DUE NOW</b>	81060011904091052I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1045	SELENIUM		<	5.000		UG/L	50	5	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1085	THALLIUM, TOTAL		<	1.000		UG/L	2	1	4/18/2017	5	108		2026/04		81060011704180945I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
	NI	<b>NITRATE/NITRITE</b>																			
		1040	NITRATE		<	0.400		MG/L	10	0.4	4/12/2022	7	12		2023/04		CH 2272345-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500-NO3-F-00	
		1041	NITRITE		<	0.400		MG/L	1	0.4	4/14/2020	4	36		2023/04		810600120041411154N	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 1P

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_001_001	RA	<b>RADIOLOGICAL</b>																		
		4109	GROSS ALPHA PARTICLE ACTIVITY	1.170		2.600	1.720	PCI/L	15	3	4/14/2020	2	108		2029/04		81060012004141158R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	4030	RADIUM-228		<	0.200	0.445	PCI/L	-----	1	1/7/2014	4	108		2023/01	<b>DUE NOW</b>	81060011401070910R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
	S1	<b>REGULATED VOC</b>																		
		2981	1,1,1-TRICHLOROETHANE		<	0.500		UG/L	200	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2988	1,1,2,2-TETRACHLOROETHANE		<	0.500		UG/L	1	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2985	1,1,2-TRICHLOROETHANE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2978	1,1-DICHLOROETHANE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2977	1,1-DICHLOROETHYLENE		<	0.500		UG/L	6	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2378	1,2,4-TRICHLOROBENZENE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
2968		O-DICHLOROBENZENE		<	0.500		UG/L	600	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
2980	1,2-DICHLOROETHANE		<	0.500		UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 1P

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_001_001	S1	<b>REGULATED VOC</b>																		
		2983	1,2-DICHLOROPROPANE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2413	1,3-DICHLOROPROPENE		<	0.500		UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2969	P-DICHLOROBENZENE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2990	BENZENE		<	0.500		UG/L	1	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2982	CARBON TETRACHLORIDE		<	0.500		UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2380	CIS-1,2-DICHLOROETHYLENE		<	0.500		UG/L	6	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2964	DICHLOROMETHANE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2992	ETHYLBENZENE		<	0.500		UG/L	300	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2251	METHYL TERT-BUTYL ETHER		<	3.000		UG/L	13	3	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2989	CHLOROBENZENE		<	0.500		UG/L	70	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
2996	STYRENE		<	0.500		UG/L	100	0.5	7/14/2020	2	72		2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY:

Sample Point:

CLASS: CTGP

STATUS:

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MONTHS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD		
CA3205006_001_001	S1	2987	TETRACHLOROETHYLENE		<	0.500		UG/L	5	0.5	7/14/2020	2	72			2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2991	TOLUENE		<	0.500		UG/L	150	0.5	7/14/2020	2	72			2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2979	TRANS-1,2-DICHLOROETHYLENE		<	0.500		UG/L	10	0.5	7/14/2020	2	72			2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2984	TRICHLOROETHYLENE		<	0.500		UG/L	5	0.5	7/14/2020	2	72			2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2218	TRICHLOROFLUOROMETHANE		<	5.000		UG/L	150	5	7/14/2020	2	72			2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2904	TRICHLOROTRIFLUOROETHANE		<	10.000		UG/L	1200	10	7/14/2020	2	72			2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2976	VINYL CHLORIDE		<	0.500		UG/L	0.5	0.5	7/14/2020	2	72			2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2955	XYLENES, TOTAL		<	0.500		UG/L	1750	0.5	7/14/2020	2	72			2026/07		81060012007141056V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_002_002		GRIZZLY RANCH CSD					WELL 3P2													
	GP	SECONDARY/GP																		
		1928	ALKALINITY, BICARBONATE	170.000		0.000	MG/L	-----	-----	4/14/2020	2	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1919	CALCIUM	47.000		0.000	MG/L	-----	-----	4/14/2020	2	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1929	ALKALINITY, CARBONATE		<	10.000	MG/L	-----	-----	4/14/2020	2	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1017	CHLORIDE	2.000		0.000	MG/L	500	-----	4/14/2020	3	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1905	COLOR	5.000		0.000	UNITS	15	-----	7/8/2014	3	108			2023/07		81060021 40708094 0G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1022	COPPER, FREE		<	50.000	UG/L	1000	50	4/14/2020	3	108			2029/04		81060022 00414112 7L	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2905	FOAMING AGENTS (SURFACTANTS)		<	0.100	MG/L	0.5	-----	4/14/2020	3	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1915	HARDNESS, TOTAL (AS CaCO3)	187.000		0.000	MG/L	-----	-----	4/14/2020	2	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1021	HYDROXIDE AS CALCIUM CARBONATE		<	10.000	MG/L	-----	-----	4/14/2020	2	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1028	IRON	8480.000		100.000	UG/L	300	100	1/24/2023	50	3	Interval		2023/04		CH 2370428- 003	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1031	MAGNESIUM	17.000		0.000	MG/L	-----	-----	4/14/2020	2	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1032	MANGANESE	353.000		20.000	UG/L	50	20	1/24/2023	50	3	Interval		2023/04		CH 2370428- 003	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_002_002	GP	<b>SECONDARY/GP</b>																		
		1920	ODOR	32.000		1.000		TON	3	1	7/8/2014	3	108		2023/07		81060021 40708094 0G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1925	PH	6.900		0.000		pH	-----	-----	7/26/2011	4	108		2020/07	<b>DUE NOW</b>	81060021 10726092 0G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1050	SILVER		<	1.000		UG/L	100	10	7/8/2014	4	108		2023/07		81060021 40708094 0G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1052	SODIUM	13.000		0.000		MG/L	-----	-----	4/14/2020	2	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1064	CONDUCTIVITY @ 25 C UMHOS/CM	456.000		0.000		UMHO/CM	1600	-----	4/14/2020	3	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1055	SULFATE	80.300		0.500		MG/L	500	0.5	4/14/2020	3	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1930	TDS	280.000		0.000		MG/L	1000	-----	4/14/2020	5	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		0100	TURBIDITY	52.700		0.100		NTU	5	0.1	7/8/2014	3	108		2023/07		81060021 40708094 0G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1095	ZINC		<	50.000		UG/L	5000	50	4/14/2020	3	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	IO	<b>INORGANIC</b>																		
		1002	ALUMINUM	50.000		50.000		UG/L	1000	50	7/8/2014	4	108		2023/07		81060021 40708094 0I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1074	ANTIMONY, TOTAL		<	1.000		UG/L	6	6	7/8/2014	4	108		2023/07		81060021 40708094 0I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1005	ARSENIC	3.000		2.000		UG/L	10	2	1/24/2023	50	108		2032/01		CH 2370428- 003	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_002_002	IO	<b>INORGANIC</b>																		
		1010	BARIUM	63.200		100.000		UG/L	1000	100	7/8/2014	4	108		2023/07		81060021 40708094 OI	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1075	BERYLLIUM, TOTAL		<	0.200		UG/L	4	1	7/8/2014	4	108		2023/07		81060021 40708094 OI	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1015	CADMIUM		<	0.200		UG/L	5	1	7/8/2014	4	108		2023/07		81060021 40708094 OI	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1020	CHROMIUM	5.000		10.000		UG/L	50	10	7/8/2014	4	108		2023/07		81060021 40708094 OI	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1025	FLUORIDE		<	0.100		MG/L	2	0.1	4/14/2020	3	108		2029/04		81060022 00414112 7I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1035	MERCURY	0.060		1.000		UG/L	2	1	7/8/2014	4	108		2023/07		81060021 40708094 OI	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1036	NICKEL	3.000		10.000		UG/L	100	10	7/8/2014	4	108		2023/07		81060021 40708094 OI	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1039	PERCHLORATE		<	2.000		UG/L	6	2	7/12/2022	12	36		2025/07		CH 2275218- 003	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 314.0
		1045	SELENIUM		<	1.000		UG/L	50	5	7/8/2014	4	108		2023/07		81060021 40708094 OI	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1085	THALLIUM, TOTAL		<	0.200		UG/L	2	1	7/8/2014	4	108		2023/07		81060021 40708094 OI	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
			NI	<b>NITRATE/NITRITE</b>																
1040	NITRATE				<	0.400		MG/L	10	0.4	4/12/2022	8	12		2023/04		CH 2272393- 001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500- NO3-F-00
1041	NITRITE				<	0.400		MG/L	1	0.4	4/14/2020	4	36		2023/04		81060022 00414112 7N	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_002_002	RA	<b>RADIOLOGICAL</b>																		
		4109	GROSS ALPHA PARTICLE ACTIVITY	0.637		1.500	1.120	PCI/L	15	3	1/12/2016	1	108		2025/01		81060021601121218R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	4030	RADIUM-228	1.000		0.200	0.412	PCI/L	-----	1	2/14/2017	6	108		2026/02		81060021702141130R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
	S1	<b>REGULATED VOC</b>																		
		2981	1,1,1-TRICHLOROETHANE		<	0.500		UG/L	200	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2988	1,1,2,2-TETRACHLOROETHANE		<	0.500		UG/L	1	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2985	1,1,2-TRICHLOROETHANE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2978	1,1-DICHLOROETHANE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2977	1,1-DICHLOROETHYLENE		<	0.500		UG/L	6	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2378	1,2,4-TRICHLOROBENZENE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
2968		O-DICHLOROBENZENE		<	0.500		UG/L	600	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
2980	1,2-DICHLOROETHANE		<	0.500		UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 3P2

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_002_002	S1	<b>REGULATED VOC</b>																		
		2983	1,2-DICHLOROPROPANE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2413	1,3-DICHLOROPROPENE		<	0.500		UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2969	P-DICHLOROBENZENE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2990	BENZENE		<	0.500		UG/L	1	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2982	CARBON TETRACHLORIDE		<	0.500		UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2380	CIS-1,2-DICHLOROETHYLENE		<	0.500		UG/L	6	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2964	DICHLOROMETHANE		<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2992	ETHYLBENZENE		<	0.500		UG/L	300	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2251	METHYL TERT-BUTYL ETHER		<	3.000		UG/L	13	3	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2989	CHLOROBENZENE		<	0.500		UG/L	70	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
2996	STYRENE		<	0.500		UG/L	100	0.5	7/14/2020	2	72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY:

Sample Point:

CLASS: CTGP

STATUS:

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MONTHS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_002_002	S1	2987	TETRACHLOROETHYLENE		<	0.500		UG/L	5	0.5	7/14/2020	2		72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2991	TOLUENE		<	0.500		UG/L	150	0.5	7/14/2020	2		72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2979	TRANS-1,2-DICHLOROETHYLENE		<	0.500		UG/L	10	0.5	7/14/2020	2		72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2984	TRICHLOROETHYLENE		<	0.500		UG/L	5	0.5	7/14/2020	2		72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2218	TRICHLOROFLUOROMETHANE		<	5.000		UG/L	150	5	7/14/2020	2		72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2904	TRICHLOROTRIFLUOROETHANE		<	10.000		UG/L	1200	10	7/14/2020	2		72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2976	VINYL CHLORIDE		<	0.500		UG/L	0.5	0.5	7/14/2020	2		72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2955	XYLENES, TOTAL		<	0.500		UG/L	1750	0.5	7/14/2020	2		72		2026/07		81060022007141122V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_003_003		GRIZZLY RANCH CSD					WELL 9M													
	GP	SECONDARY/GP																		
		1928	ALKALINITY, BICARBONATE	190.000		0.000	MG/L	-----	-----	8/16/2016	2	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1919	CALCIUM	62.000		0.000	MG/L	-----	-----	8/16/2016	2	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1929	ALKALINITY, CARBONATE		<	10.000	MG/L	-----	-----	8/16/2016	2	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1017	CHLORIDE	3.000		0.000	MG/L	500	-----	8/16/2016	3	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1905	COLOR		<	5.000	UNITS	15	-----	8/16/2016	3	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1022	COPPER, FREE		<	10.000	UG/L	1000	50	8/16/2016	3	108			2025/08		81060031 60816120 5L	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2905	FOAMING AGENTS (SURFACTANTS)		<	0.100	MG/L	0.5	-----	8/16/2016	3	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1915	HARDNESS, TOTAL (AS CaCO3)	208.000		0.000	MG/L	-----	-----	8/16/2016	2	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1021	HYDROXIDE AS CALCIUM CARBONATE		<	10.000	MG/L	-----	-----	8/16/2016	2	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1028	IRON	6270.000		100.000	UG/L	300	100	1/24/2023	37	3	Interval		2023/04		CH 2370428-004	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1031	MAGNESIUM	13.000		0.000	MG/L	-----	-----	8/16/2016	2	108			2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1032	MANGANESE	840.000		20.000	UG/L	50	20	1/24/2023	37	3	Interval		2023/04		CH 2370428-004	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_003_003	GP	<b>SECONDARY/GP</b>																		
		1920	ODOR		<	1.000		TON	3	1	8/16/2016	3	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1925	PH	6.800		0.000		pH	-----	-----	8/16/2016	3	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1050	SILVER		<	1.000		UG/L	100	10	8/16/2016	3	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1052	SODIUM	13.000		0.000		MG/L	-----	-----	8/16/2016	2	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1064	CONDUCTIVITY @ 25 C UMHOS/CM	487.000		0.000		UMHO/CM	1600	-----	8/16/2016	3	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1055	SULFATE	84.600		0.500		MG/L	500	0.5	8/16/2016	3	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1930	TDS	320.000		0.000		MG/L	1000	-----	8/16/2016	3	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		0100	TURBIDITY	10.100		0.100		NTU	5	0.1	8/16/2016	3	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1095	ZINC	2700.000		50.000		UG/L	5000	50	8/16/2016	3	108		2025/08		81060031 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	IO	<b>INORGANIC</b>																		
		1002	ALUMINUM		<	10.000		UG/L	1000	50	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1074	ANTIMONY, TOTAL		<	1.000		UG/L	6	6	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1005	ARSENIC		<	2.000		UG/L	10	2	1/24/2023	37	108		2032/01		CH 2370428- 004	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_003_003	IO	<b>INORGANIC</b>																		
		1010	BARIUM		<	0.200		UG/L	1000	100	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1075	BERYLLIUM, TOTAL		<	1.000		UG/L	4	1	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1015	CADMIUM		<	0.200		UG/L	5	1	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1020	CHROMIUM		<	1.000		UG/L	50	10	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1025	FLUORIDE		<	0.100		MG/L	2	0.1	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1035	MERCURY		<	0.000		UG/L	2	1	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1036	NICKEL		<	1.000		UG/L	100	10	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1039	PERCHLORATE		<	2.000		UG/L	6	2	7/12/2022	5	36		2025/07		CH 2275218- 004	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 314.0
		1045	SELENIUM		<	1.000		UG/L	50	5	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1085	THALLIUM, TOTAL		<	0.200		UG/L	2	1	8/16/2016	3	108		2025/08		81060031 60816120 5I	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
			NI	<b>NITRATE/NITRITE</b>																
1040	NITRATE				<	0.400		MG/L	10	0.4	4/12/2022	7	12		2023/04		CH 2272344- 001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500- NO3-F-00
1041	NITRITE				<	0.400		MG/L	1	0.4	4/12/2022	4	36		2025/04		CH 2272344- 001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500- NO3-F-00

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_003_003	RA	<b>RADIOLOGICAL</b>																		
		4109	GROSS ALPHA PARTICLE ACTIVITY	0.712		1.500	1.180	PCI/L	15	3	8/16/2016	1	108		2025/08		81060031 60816120 7R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	4030	RADIUM-228	1.000		0.200	0.400	PCI/L	-----	1	2/14/2017	4	108		2026/02		81060031 70214120 3R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
	S1	<b>REGULATED VOC</b>																		
		2981	1,1,1-TRICHLOROETHANE		<	0.500		UG/L	200	0.5	4/9/2019	2	72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2988	1,1,2,2-TETRACHLOROETHANE		<	0.500		UG/L	1	0.5	4/9/2019	2	72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2985	1,1,2-TRICHLOROETHANE		<	0.500		UG/L	5	0.5	4/9/2019	2	72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2978	1,1-DICHLOROETHANE		<	0.500		UG/L	5	0.5	4/9/2019	2	72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2977	1,1-DICHLOROETHYLENE		<	0.500		UG/L	6	0.5	4/9/2019	2	72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2378	1,2,4-TRICHLOROBENZENE		<	0.500		UG/L	5	0.5	4/9/2019	2	72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
2968		O-DICHLOROBENZENE		<	0.500		UG/L	600	0.5	4/9/2019	2	72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
2980	1,2-DICHLOROETHANE		<	0.500		UG/L	0.5	0.5	4/9/2019	2	72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

CLASS: CTGP

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_003_003	S1	<b>REGULATED VOC</b>																		
		2983	1,2-DICHLOROPROPANE		<	0.500		UG/L	5	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2413	1,3-DICHLOROPROPENE		<	0.500		UG/L	0.5	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2969	P-DICHLOROBENZENE		<	0.500		UG/L	5	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2990	BENZENE		<	0.500		UG/L	1	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2982	CARBON TETRACHLORIDE		<	0.500		UG/L	0.5	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2380	CIS-1,2-DICHLOROETHYLENE		<	0.500		UG/L	6	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2964	DICHLOROMETHANE		<	0.500		UG/L	5	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2992	ETHYLBENZENE		<	0.500		UG/L	300	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2251	METHYL TERT-BUTYL ETHER		<	3.000		UG/L	13	3	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2989	CHLOROBENZENE		<	0.500		UG/L	70	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
2996	STYRENE		<	0.500		UG/L	100	0.5	4/9/2019	2	72		2025/04		81060031904091106V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY:

Sample Point:

CLASS: CTGP

STATUS:

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MONTHS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_003_003	S1	2987	TETRACHLOROETHYLENE		<	0.500		UG/L	5	0.5	4/9/2019	2		72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2991	TOLUENE		<	0.500		UG/L	150	0.5	4/9/2019	2		72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2979	TRANS-1,2-DICHLOROETHYLENE		<	0.500		UG/L	10	0.5	4/9/2019	2		72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2984	TRICHLOROETHYLENE		<	0.500		UG/L	5	0.5	4/9/2019	2		72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2218	TRICHLOROFLUOROMETHANE		<	5.000		UG/L	150	5	4/9/2019	2		72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2904	TRICHLOROTRIFLUOROETHANE		<	10.000		UG/L	1200	10	4/9/2019	2		72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2976	VINYL CHLORIDE		<	0.500		UG/L	0.5	0.5	4/9/2019	2		72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)
		2955	XYLENES, TOTAL		<	0.500		UG/L	1750	0.5	4/9/2019	2		72		2025/04		81060031 90409110 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)

# Individual System Lead and Copper Rule Tracking Report

3205006 Grizzly Ranch CSD Pop: 0 Eng: Lead Action Level: 0.015 mg/L  
Copper Action Level: 1.3 mg/L

Sample Date Begin/(End)	Monitoring Period	Sample Set ID	Number Required	Number Sampled	Lead 90th % (mg/L)	Copper 90th % (mg/L)	Action Taken	Action Type	Next Due Date	Next Due Freq	Comments
( 9/25/2007 )	YR2007			5	0.019	0.129			8/1/2008		Lead Exceedance
( 7/22/2008 )	YR2008			5	0.012	0.213			3/1/2009		No Exceedance
( 9/10/2009 )	YR2009			5	0.023	0.182			8/1/2010		Lead Exceedance - 5 samples due
( 7/20/2010 )	YR2010			5	0.026	0.314			3/1/2011		Lead Exceedance - 5 samples due
( 9/9/2011 )	YR2011			5	0.017	0.127			8/1/2012		Lead Exceedance - 5 samples due
( 9/24/2013 )	YR2013			5	0.014	0.431			8/1/2015		No Exceedance
9/16/2014 (10/24/2014)	YR2014			5	0.007	0.555			8/1/2017		No Exceedance
7/9/2017 ( 7/12/2017 )	YR2017			5	0.000	0.118			8/1/2020		No Exceedance
7/15/2020 ( 7/22/2020 )	YR2020			5	0.000	0.000			8/1/2023		No Exceedance

## Legend:

Cit: Citation  
 EL: Enforcement letter  
 1st 6: 1st initial 6-mo. round of monitoring  
 2nd 6: 2nd initial 6-mo. round of monitoring  
 A1: 1st Annual monitoring  
 A2: 2nd Annual monitoring  
 T1: 1st Triennial (3 yr) monitoring  
 T2: 2nd Triennial (3 yr) monitoring  
 T3: 3rd Triennial (3 yr) monitoring