

## 2023 Consumer Confidence Report

### Water System Information

Water System Name: RIVERSIDE COUNTY SERVICE AREA 51

Report Date: June 7, 2024

Type of Water Source(s) in Use: The water is from wells.

Name and General Location of Source(s): Well #4 is the primary well. Well #5 is equal in size and quality and is used as a backup source.

Drinking Water Source Assessment Information: A water source assessment was conducted for Well #4 and Well #5 in March 2001. Source is considered most vulnerable to the following activities not associated with any detected contaminants. Sewer collection systems. A copy of the complete assessment can be viewed at Riverside County Environmental Health Department 760-863-7570.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: The County Service Area Advisory Committee meets on the third Thursday of the Month from November through May at 7:00 p.m.

For More Information, Contact: Rick Jones at 760-227-3203.

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2023 and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Riverside County Service Area 51 at 26251 Parkview Drive, Desert Center, CA 92239; 760-227-3203 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Riverside County Service Area 51 以获得中文的帮助: 26251 Parkview Drive, Desert Center, CA 92239; 760-227-3203.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Riverside County Service Area 51 o tumawag sa 26251 Parkview Drive, Desert Center, CA 92239; 760-227-3203 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Riverside County Service Area 51 tại 26251 Parkview Drive, Desert Center, CA 92239; 760-227-3203 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Riverside County Service Area 51 ntawm 26251 Parkview Drive, Desert Center, CA 92239; 760-227-3203 rau kev pab hauv lus Askiv.

### Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Term	Definition
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter ( $\mu\text{g/L}$ )
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

### Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

### Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

**About Your Drinking Water Quality**

**Drinking Water Contaminants Detected**

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	2023	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive, or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Lead And Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	9/22	5	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/22	5	0.094	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	9/22	120 mg/L	NA	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	9/22	39 mg/L	NA	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic (ppb) After Treatment	9/22	5.6 ppb ND	NA	10 ppb	0.004	Erosion of natural deposits
Gross Alpha (pCi/L)	8/23	4.9	NA	15 pCi/L	(0)	Erosion of natural deposits
Uranium (pCi/L)	8/23	9.3	NA	20 pCi/L	0.43	Erosion of natural deposits
Total Chromium (ppb)	9/22	8.0	NA	50	(100)	Discharge from steel and pulp mills, Chrome plating; erosion of natural deposits.
Nitrate (as N) (ppm)	8/23	1.0	NA	10	10	Erosion of natural deposits.
Fluoride (ppm) After Treatment	3/22 & 6/22	7.8 & 7.5 0.48 & 0.99	7.5 – 7.8 0.48 – 0.99	2 ppm	1	Erosion of natural deposits.
Barium (ppb)	9/22	55	NA	1000	2000	Discharge of oil drilling wastes and from metal refineries, erosion of natural deposits.

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids (ppm)	9/22	460	NA	1000 ppm	NA	Runoff/leaching natural deposits.
Specific Conductance (umhos/cm)	9/22	650	NA	1600	NA	Substances that form ions when in water, Sea water influence.
Sulfate (ppm)	9/22	110	NA	500 ppm	NA	Runoff/leaching natural deposits.
Chloride (mg/L)	9/22	83 mg/L	NA	500 ppm	NA	Runoff/leaching natural deposits.
MBAS (ppb)	9/22	ND	NA	500 ppb	NA	Municipal and industrial waste discharges

**Table 6. Detection of Unregulated Contaminants**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Source of Contaminant
Hexavalent Chromium	9/14	7.7 ppb	NA	NA	Found in natural deposits of ores containing other elements, mostly as chrome-iron ore. It is also widely present in soil and plants.

There is currently no MCL for hexavalent chromium. The previous MCL of 0.010 mg/l was withdrawn on September 11, 2017.

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Riverside County Service Area 51 is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

---

While your drinking water meets the federal and state standards for arsenic, it does contain low levels of arsenic. The Arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U. S. Environmental Protection Agency continues to research the health effects of Low levels of arsenic. Which is a mineral, known to cause cancer in humans at high concentrations and is linked to other Health effects such as skin damage and circulatory problems.

The drinking water delivered to your home is treated for excessive Fluoride. A water treatment plant operated by CSA 51 removes the excess fluoride. Fluoride is reduced to a level below the maximum contaminant level by the water treatment facility. The treatment process that is utilized reduce the arsenic to a minimum level as well.

Standby well (Well #5) was not used in 2023.

The homes have outside hose bibs that are serviced by irrigation water. This water is not approved for domestic use. These hose bibs should be labeled "Non-Potable Water. Do Not Drink". Contact Rick Jones at CSA 51 if your hose bib is not properly labeled.