


**Consumer Confidence Report
Certification Form**

(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: RIVERSIDE COUNTY SERVICE AREA 62
Water System Number: 3301577

The water system named above hereby certifies that its Consumer Confidence Report was distributed on June 27, 2019 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Steve H. Jones
Signature: 
Title: Manager
Phone Number: 760-922-4909 Date: June 27, 2019

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: U. S. Mail

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- Posting the CCR on the Internet at www.
- Mailing the CCR to postal patrons within the service area (attach zip codes used)
- Advertising the availability of the CCR in news media (attach copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).

2018 Consumer Confidence Report

Water System Name: RIVERSIDE COUNTY SERVICE AREA #62 RIPLEY Report Date: MAY 30, 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Riverside County Service Area #62 Ripley a (760) 922-4909 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 RIVERSIDE COUNTY SERVICE AREA 62 以获得中文的帮助: 13341 MESA DRIVE BLYTHE CA 92225 760-922-4909

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa RIVERSIDE COUNTY SERVICE AREA 62 o tumawag sa 13341 MESA DRIVE BLYTHE CA 92225 760-922-4909 para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ RIVERSIDE COUNTY SERVICE AREA 62 tại : 13341 MESA DRIVE BLYTHE CA 92225 760-922-4909 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau RIVERSIDE COUNTY SERVICE AREA 62 ntawm 13341 MESA DRIVE BLYTHE CA 92225 760-922-4909 rau kev pab hauv lus Askiv.

Type of water source(s) in use: The water is from wells.

Name & general location of source(s): Well # 1 (School Road Well) is the primary well. Well # 2 is an equal size and Quality and is used as a backup source

Drinking Water Source Assessment information: A source water assessment was conducted for Well # 1 & Well # 2 in February 2001. Assessment can be viewed at Riverside County Environmental Health Department (760) 863-7570

Time and place of regularly scheduled board meetings for public participation: The County Service Area Advisory Committee meet on the 2nd Wednesday quarterly beginning in January at 5:30 in the Ripley Community Center

For more information, contact: Steve H. Jones Phone: 760 922-4909

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month)	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year)	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year)	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	9/18	5	ND	0	15	0.2	Not applicable	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/18	5	0.09 mg/L	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	9/18	270	N/A	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	8/16	550	N/A	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Fluoride (ppm)	8/16	0.3	N/A	2	1	Erosion of natural deposits
Trihalomethanes (ppb)	8/18	60 ppb	53 – 66	80 ppb	N/A	By-product of drinking water Disinfection.
1, 2 Dichloropropane (ppb)	8/18	0.83 ppb	-	5 ppb	0.5 ppb	Discharge from industrial chemical Factories: primary component of Some fumigants.
HAA5 (ppb)	8/18	3.95 ppb	ND-7.9	60 ppb	N/A	By-product of drinking water Disinfection.
Chlorine (ppm)	2018	0.08	0.07 – 0.22	4.0 As Cl ₂)	4.0	Drinking water disinfectant added For treatment
1,2,3 – Trichloropropane* (ng/L)	2018	12.5	12-13	5	0.7	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Iron (ppb) After Treatment Plant	2018	208 ppb ND	190 – 230 ND-120	300 ppb	N/A	Leaching from natural deposits
Manganese (ppb) After Treatment Plant	2018	253 ppb ND	230 – 290 ND	50 ppb	N/A	Leaching from natural deposits
Sulfate* (ppm)	8/16	500	N/A	500 ppm	N/A	Leaching from natural deposits
Chloride (ppm)	8/16	220	N/A	500	N/A	Runoff/ leaching from natural deposits.
Turbidity (NTU)	8/16	1.2 NTU		5 NTU	N/A	Runoff/leaching from natural deposits.
Specific Conductance* (uS/cm)	8/16	2300 uS/cm		1600 uS/cm	-	Substances that form ions when in water; seawater influence
Total Dissolved Solids* (ppm)	9/18	1600 ppm	-	1000 ppm	-	Runoff/leaching from natural deposits
Color (color units)	8/16	10	-	15	-	Naturally-occurring organic materials.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More

information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Riverside County Service Area 62 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [**OPTIONAL:** If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

**Summary Information for Violation of a MCL, MRDL, AL, TT,
or Monitoring and Reporting Requirement**

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
Secondary MCL Sulfate	Natural leaching from deposits	On Going		
Secondary MCL Specific Conductance	Natural Leaching from Deposits	On Going		
Secondary MDL TDS	Natural Leaching from Deposits	On Going		
Primary MCL 1,2,3 Trichloropropane	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides		An investigation for an alternative water source or a treatment technique has been implemented and results are being worked on for a conclusion.	Some people who drink water containing 1,2,3 trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.

The Ripley Water Treatment Plant is reducing and or eliminating the Iron & Manganese present in the groundwater. The Sulfate is still above the Secondary Standards. The Total Dissolved Solids Concentration at 1600 mg/L exceeds the MCL of 1000 mg/L. The Specific Conductance of 2300 uSc/cm exceeds the MCL of 1600 cS/cm. These are Secondary MCL violations and may cause taste, odor and

other problems, but are not to be considered to be harmful to health. Iron and Manganese continue to be sampled with the operation of the Water Treatment Plant and the water produced has consistently tested below the MCL and usually is non-detect for these secondary contaminants. The Service Area continues to monitor the Disinfection By-Products that occur with the addition of Chlorine to precipitate Iron and Manganese from the well water.

The Ripley Water System has sampled for 1,2,3 Trichloropropane for the year of 2018 and have discovered the contaminant in the groundwater. It is 12.0 ng/L which is above the MCL of 5 ng/L. This is violation of the drinking water Standard. The County Service Area is working on an alternate water source to eliminate the problem with the groundwater. Tier notices will be handed out quarterly until problem is resolved.