



# CONSUMER CONFIDENCE REPORT



## YOUR 2024 WATER QUALITY



2270 Trumble Road

P.O. Box 8300

Perris, CA 92572-8300

EMWD Main Phone Number:  
951.928.3777

EMWD Customer Service:  
800.426.3693

Careers: [emwd.org/joinemwd](https://emwd.org/joinemwd)

Conservation Hotline: ext. 3322

Water Quality: ext. 3327

Systems Outages, Trouble Calls:  
ext. 6265 or 800.698.0400

Public and Governmental Affairs:  
ext. 3430

[PublicandGovtAffairs@emwd.org](mailto:PublicandGovtAffairs@emwd.org)




EMWD publications are designed to keep EMWD's customers and the public informed of matters affecting them.



@EASTERNMUNI  
[www.emwd.org](https://www.emwd.org)

## 2024 SERVICE BY THE NUMBERS

QUALITY YOU CAN COUNT ON 24/7/365





INSIDE THIS REPORT

..... PAGE 3 .....

Regulations  
Contaminants  
Sensitive populations  
Nitrate  
Arsenic  
Unregulated contaminants  
Lead and copper  
PFAS

..... PAGE 4 .....

Source water map

..... PAGE 5 .....

The communities we serve

..... PAGE 6 .....

Facts about total coliform bacteria  
Abbreviations and definitions

..... PAGE 7 .....

Distribution system data

..... PAGES 8-11 .....

Water quality tables

..... BACK PAGE .....

Get your report electronically

Public meeting and contact information

OUR MISSION

To deliver value to our diverse customers and the communities we serve by providing safe, reliable, economical and environmentally sustainable water, wastewater and recycled water services.

OUR VISION

To be recognized as a leading organization in performance, technology, and advocacy; advancing innovative solutions that provide an exceptional level of customer and community service.

EMWD wants you, our valued customer, to be confident that your drinking water is safe.

OUR CONTINUING COMMITMENT TO YOU

EMWD and its trained, certified water quality professionals are committed to...

- Providing high quality, safe drinking water at the lowest price possible.
- Monitoring and testing the water we serve to optimize quality and ensure it is always safe to drink.
- Finding and developing new water supply sources to ensure continued reliability for our customers.
- Providing educated staff to answer any questions from our customers.

Dear Valued EMWD Customer,

At Eastern Municipal Water District (EMWD), our guiding principles as an organization are rooted in public trust.

For 75 years, we have proudly served the community and done so with transparency, accountability, and safety at the forefront of our decisions as an organization. That commitment is reaffirmed every time you turn on your tap and a safe, clean and reliable water supply is delivered to you and your family.

That is why we are pleased to present our annual water quality report, which details the high-quality drinking water we delivered throughout 2024. This annual report shows how EMWD continues to meet all drinking water quality standards established by the United States Environmental Protection Agency (USEPA) and the State Water Resources Control Board (State Water Board).

EMWD uses state-of-the-art water treatment processes to provide a safe and highly reliable water supply while protecting public health. By efficiently maintaining and operating our facilities along with conducting rigorous monitoring and testing, EMWD consistently delivers high-quality tap water service. Water samples are collected throughout the year from EMWD’s 36 drinking water sources to carefully test for 382 water quality constituents. In 2024, EMWD collected 8,120 water samples and performed 48,194 tests to monitor and ensure quality.

EMWD supports science-based standards that provide health benefits to the public in an economically balanced manner. While groundwater or surface waters can have trace contaminants, EMWD protects your health and safety by treating the water we deliver—ensuring your water meets or surpasses all regulated drinking water standards.

In 2024, our service area continued to grow in both population and geographic footprint. EMWD completed a consolidation of the City of Perris water system and began providing wholesale water service to northern San Diego County. While we serve one of the fastest-growing regions in California, we are focused on ensuring every customer can have confidence in the quality of water we provide.

The State Water Board requires that EMWD customers receive an annual copy of this report, which summarizes the results of water quality tests and provides specific details about sources and quality of the water served in your community. The guidelines for distributing this report allow for electronic delivery, instead of a paper copy in the mail. By delivering this report electronically, we reduce costs and eliminate paper waste associated with printing and mailing the report to our more than 171,000 accounts. We will be happy to provide you with a paper copy of this report upon request through our website at emwd.org/CCR or by calling us at 951-928-3777, extension 3430. Please note that you may change your delivery preference at any time.

We strongly encourage you to read this report and if you have any water quality questions, please feel free to contact Michelle Karras, Principal Environmental Analyst, or any of our Water Quality staff at 951-928-3777, extension 3327. We also encourage you to get the latest news and information from EMWD through our website at emwd.org.

Thank you for being part of the EMWD family and for trusting us to provide for you and your family with a safe and reliable water supply.



Joe Mouawad, P.E.  
GENERAL MANAGER  
EASTERN MUNICIPAL WATER DISTRICT

*This annual water quality report contains important and useful information about the source and the tests used to ensure the quality and safety of your drinking water. It also describes how EMWD meets all drinking water standards as set by the United States Environmental Protection Agency (USEPA) and enforced by the State Water Resources Control Board (State Water Board).*

About Regulations

In order to ensure that tap water is safe to drink, the United States Environmental Protection Agency (USEPA) and the State Water Resources Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDE:

- **MICROBIAL CONTAMINANTS**, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock, and wildlife.
- **INORGANIC CONTAMINANTS**, such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **ORGANIC CHEMICAL CONTAMINANTS**, including synthetic and volatile organic chemicals may be by-products of industrial processes or petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
- **PESTICIDES AND HERBICIDES** may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **RADIOACTIVE CONTAMINANTS** can be naturally-occurring or be the result of oil and gas production and mining activities.



SENSITIVE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised individuals such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about their drinking water from their health care providers. USEPA and Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

ABOUT NITRATE

Nitrate in drinking water at levels above 10 parts per million (ppm) is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of an infant’s blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 ppm may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should seek advice from your health care provider.

ABOUT ARSENIC

While your drinking water meets the federal and state standard for arsenic, some of our sources do contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic’s possible health effects against the costs of removing arsenic from drinking water. The USEPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

UNREGULATED CONTAMINANTS

Unregulated contaminant monitoring helps USEPA and the State Water Board determine where certain contaminants occur and whether the contaminants need to be regulated.

ABOUT LEAD AND COPPER

Lead and copper are rarely found in source waters; however, both of these metals can enter drinking water by leaching from household plumbing and fixtures. Water that sits in your pipes for long periods of time may dissolve tiny amounts of lead and/or copper (parts per billion levels) into household water. The USEPA has developed the Lead and Copper Rule to protect public health by establishing an action level of 15 parts per billion (ppb) for lead and 1300 ppb for copper.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. EMWD is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family’s risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact EMWD Water Quality staff at 951-928-3777, extension 3327. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

In 2024, EMWD conducted an inventory of water service lines required by U.S. EPA’s Lead and Copper Rule Revisions. EMWD determined through historical records, information provided directly by customers, and information acquired during physical field inspections that the water system contains no lead service lines or galvanized service lines requiring replacement in its distribution system. For more information or to access the inventory, visit <https://www.emwd.org/lead-service-line-inventory>.


PFAS (PER- AND POLYFLUOROALKYL SUBSTANCES)

PFAS are chemicals that are resistant to heat, water and oil and have been used for decades in hundreds of consumer products and industrial applications. As a result, these chemicals are often found in the environment.

Although PFAS compounds such as perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic acid (PFOS) are no longer manufactured in the United States, many products that contain the chemicals still exist, such as cosmetics, food packaging, clothing and furniture fabrics. In addition, other countries still make products containing these chemicals, which may be imported into the United States. PFAS have been monitored by water agencies and reported based on United States Environmental Protection Agency (USEPA) regulations. Information on PFAS in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (800) 426-4791 or at [www.epa.gov/pfas](http://www.epa.gov/pfas).

# THE SOURCES OF YOUR TAP WATER...

To help you find specific details about your tap water, we have organized this report according to the communities we serve.



# THE COMMUNITIES WE SERVE...

**COMMUNITIES SERVED**

- Good Hope
- Homeland
- Juniper Flats
- Lakeview
- Mead Valley
- Menifee\*\*
- Moreno Valley
- North Canyon Lake
- Nuevo
- Perris
- Quail Valley
- Romoland
- Wildomar

**WEST COMMUNITIES SERVED**

- Diamond Valley
- Green Acres
- Hemet
- San Jacinto
- Winchester\*\*\*

**EAST COMMUNITIES SERVED**

- Hemet
- San Jacinto
- Soboba Hot Springs
- Valle Vista

**COMMUNITIES SERVED**

- French Valley
- Menifee\*\*
- Murrieta
- Rancho Glen Oaks\*\*\*\*
- Temecula
- Winchester\*\*\*

**MILLS SERVICE AREA** | Water for this service area comes from a combination of sources:

- The Henry J. Mills Filtration Plant\* treats imported surface water supplied solely from northern California through the State Water Project (SWP). The Mills Filtration Plant adjusts the fluoride levels in the water to an optimal level recommended by the Centers for Disease Control and Prevention (CDC) for oral health, and uses chloramine for final disinfection.

WATER FROM THE MILLS FILTRATION PLANT IS BLENDED WITH SEVERAL OTHER EMWD WATER SOURCES:

- Two Perris Valley Wells serve a limited area of Perris – along Perris Boulevard north and south of the Ramona Expressway.
- Four North Perris Wells serve the northeast area of Perris.
- The Perris Water Filtration Plant (PWFP) treats both Colorado River and SWP waters. This plant uses the latest ultrafiltration technology to remove particulate contaminants to produce quality, potable water. The PWFP serves Lakeview, Nuevo, Romoland, Homeland, and Juniper Flats. This plant uses chloramine for final disinfection.
- The Desalination Complex (Menifee and Perris I Desalters, and Perris II Desalter) convert salty groundwater into potable water using a reverse osmosis process. Menifee, North Canyon Lake, and Quail Valley are communities within the Mills Service Area to receive blended water from this desalination plant. The Desalination Complex uses chloramine for final disinfection.

**EAST VALLEY SERVICE AREA** | This service area is split into two regions:

**WEST OF STATE STREET:**

- The Hemet Water Filtration Plant (HWFP) treats both Colorado River and SWP waters. This plant uses the latest ultrafiltration technology to remove particulate contaminants and produce quality drinking water. This treatment plant uses chloramine for final disinfection. Local groundwater also supplies this area.

**EAST OF STATE STREET:**

- A system of deep groundwater wells serves these communities. These wells are treated by adding free chlorine for final disinfection.

**SKINNER SERVICE AREA** | Water for this service area comes from:

- The Robert A. Skinner Filtration Plant\* treats water from the Colorado River and from the SWP. The Skinner Plant adjusts the fluoride levels in the water to an optimal level recommended by the CDC for oral health, and uses chloramine for final disinfection.

## PROTECTING YOUR DRINKING WATER

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791 or online at [www.epa.gov/ground-water-and-drinking-water](http://www.epa.gov/ground-water-and-drinking-water).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. The land that the water comes into contact with is called the watershed; everything that happens to or in the watershed can affect the quality of your drinking water supply.

EMWD uses several sources of water to serve its customers, including surface water from the Colorado River and the State Water Project (SWP), as well as local groundwater.

An initial assessment of all the watersheds, both surface water and groundwater, was completed. The Colorado River, a surface water source, was reassessed in 2022 and found to be most vulnerable to recreational activities, urban and storm water runoff, increasing urbanization in the watershed, and wastewater.

Water from the SWP, also a surface water source, was reassessed in 2021 and found to be most vulnerable to urban and storm water runoff, wildlife, agriculture, recreational activities, and wastewater.

An assessment of all EMWD wells was completed in 2013. Two sources were considered vulnerable to airports and airplane maintenance associated with a contaminant detected in the water supply. In addition, other EMWD wells were considered most vulnerable to the following due to proximity (not associated with any contaminants): commercial and industrial activities, residential activities, agriculture, and other activities such as recreation and transportation.

You can view vulnerability assessments online at [www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/DWSAP.html](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html). You can also call 951-928-3777, ext. 3327 for a copy of EMWD's vulnerability assessments.

**Protecting the sources of drinking water helps protect our health. It's everyone's responsibility, and here are a few ways you can help:**

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- Dispose of chemicals properly; take used motor oil to a recycling center.

\* The Mills and Skinner Filtration Plants are owned and operated by The Metropolitan Water District of Southern California. \*\* Typically served by the Mills Filtration Plant and occasionally served by the Skinner Filtration Plant. \*\*\* Typically served by the Hemet Water Filtration Plant and occasionally served by the Skinner Filtration Plant. \*\*\*\* This area is served water produced by Rancho California Water District (RCWD). You may view RCWD's Consumer Confidence Report on their website at [www.ranchowater.com](http://www.ranchowater.com).



# Facts about Total Coliform Bacteria

Water agencies test for the presence of coliform bacteria as an indicator of drinking water quality.

Coliform bacteria are naturally present in the environment and are generally not harmful. Coliform bacteria may occur in soil, vegetation, animal waste, sewage, and surface waters.

All water systems are required to comply with the state Revised Total Coliform Rule. All water systems are also required to comply with the federal Revised Total Coliform Rule. The federal rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e. total coliform and *E. coli* bacteria). The USEPA anticipates greater public health protection as the rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system.

Eastern Municipal Water District routinely tests for the presence of coliform

bacteria as an indicator of the sanitary quality of drinking water. EMWD analyzed 3,198 coliform samples in 2024, five of which were total coliform positive. The maximum allowed by USEPA for coliforms is no more than 5 percent in any month. The highest monthly coliform result in 2024 was 0.4 percent, which complies with this standard. EMWD also tests for *E. coli* bacteria, which indicate fecal or sewage contamination. Zero samples tested positive for *E. coli* in 2024.

The City of Perris analyzed 312 coliform samples in 2024, none of which were total coliform positive. The highest monthly coliform result was zero percent. Zero samples tested positive for *E. coli* in 2024. A positive coliform test result does not necessarily mean a maximum contaminant level (MCL) has been exceeded, or that there is a problem in the water system.

More information and general guidelines on ways to lessen the risk of infection by microbes are available from the USEPA’s Safe Drinking Water Hotline at (800) 426-4791 or at [epa.gov/ground-water-and-drinking-water](https://www.epa.gov/ground-water-and-drinking-water).

## ABBREVIATIONS

AL	Action Level	NA	Not Applicable: no State or Federal standards are established	ppt	Parts per trillion or nanograms per liter (ng/L)
CCRD	Consumer Confidence Report Detection Levels	ND	Non-Detected: sample was taken and chemical was not detected	RAA	Running Annual Average
CFU/mL	Colony-Forming Units per milliliter	NL	Notification Level	RL	Reporting Limit
DLR	Detection Limits for purposes of Reporting	NR	No Range: all result(s) were the same value	TDS	Total Dissolved Solids
grains/gallon	Grains per gallon	NTU	Nephelometric Turbidity Units	TON	Threshold Odor Number
HPC	Heterotrophic Plate Count	pCi/L	PicoCuries per Liter	TT	Treatment Technique
HFPO-DA	Hexafluoropropylene Oxide Dimer Acid	PFAS	Per- and Polyfluoroalkyl Substances	µS/cm	MicroSiemens per centimeter; or micromhos per centimeter (µmho/cm)
LRAA	Locational Running Annual Average	PFBS	Perfluorobutanesulfonic Acid	—	Samples not required
MCL	Maximum Contaminant Level	PFHxS	Perfluorohexanesulfonic Acid	=	Equal
MCLG	Maximum Contaminant Level Goal	PFNA	Perfluorononanoic Acid	>	Greater than
MRDL	Maximum Residual Disinfectant Level	PHG	Public Health Goal	<	Less than
MRDLG	Maximum Residual Disinfectant Level Goal	ppb	Parts per billion or micrograms per liter (µg/L)	≤	Less than or equal to
MRL	Minimum Reporting Level: set by EPA for unregulated contaminant monitoring	ppm	Parts per million or milligrams per liter (mg/L)	#	Number
				%	Percent

## DEFINITIONS

**90th Percentile:** The value in a data set in which 90 percent of the set is less than or equal to this value.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Detection Limits for purposes of Reporting (DLR):** State-determined level that a test can detect the chemical.

**Disinfection By-Product:** Compounds which are formed from mixing of organic or mineral precursors in the water with ozone, chlorine or chloramine. Bromate, Total Trihalomethanes, and Haloacetic Acids are disinfection by-products.

**Grains per Gallon (grains/gallons):** A measure of water hardness. One grain/gallon equals 17.1 ppm or mg/L

**Heterotrophic Plate Count (HPC):** a bacteriological test that counts the number of bacteria per milliliter of sample.

**Locational Running Annual Average (LRAA):** The Running Annual Average (RAA) at one sample location.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the Public Health Goals (PHGs) or Maximum Contaminant Level Goals (MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Notification Level (NL):** Notification levels are health-based advisory levels established by the State Water Board for chemicals in drinking water that lack MCLs.

**Primary Drinking Water Standard (Primary Standard):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Running Annual Average (RAA):** The yearly average which is calculated every 3 months using the previous 12 months’ data.

**Secondary Drinking Water Standard (Secondary Standard):** MCLs for contaminants that do not affect health but are used to monitor the aesthetics of the water.

**Treatment Technique (TT):** A required treatment process intended to reduce the level of a contaminant in drinking water.

# EASTERN MUNICIPAL WATER DISTRICT DISTRIBUTION SYSTEM DATA FOR 2024

							SERVICE AREA					
Parameter	Units	State or Federal Maximum Contaminant Level (MCL)	California Public Health Goal (PHG)	State Detection Limit for Reporting (DLR)	Range / Average	EMWD's Entire Distribution System	Mills	East Valley	Skinner	North Perris	City of Perris	
PRIMARY STANDARDS – MANDATORY HEALTH-RELATED STANDARDS												
MICROBIOLOGICAL												
Total Coliform Bacteria	# Positive coliforms	A	MCLG = 0	NA	# positives in 2024 Highest monthly %	5 0.4	--- 4	--- 1	--- 0	--- 0	--- 0	
Fecal Coliform Bacteria ( <i>E. coli</i> )	# positive <i>E. coli</i>	B	MCLG = 0	NA	# positives in 2024	0	0	0	0	0	0	
Heterotrophic Plate Count (HPC)	# HPCs > 500 CFU/mL	C	NA	NA	# HPCs>500 in 2024 Lowest monthly %	10 98.8	--- 9	--- 0	--- 1	--- 0	--- 0	
DISINFECTION BY-PRODUCTS AND DISINFECTANT RESIDUALS												
Bromate (Mills & Skinner plants only)	D	ppb	RAA = 10	0.1	1	Range Highest RAA	--- ---	ND - 19 7.9	--- ---	ND - 6 1.5	--- ---	
Haloacetic Acids (5) (HAA5s)	E	ppb	LRAA = 60	NA	E	Range Highest LRAA	ND - 27 28	ND - 27 20	ND - 27 28	ND - 18 18	1.3 - 2.4 1.9 F	
Total Trihalomethanes (TTHMs)	G	ppb	LRAA = 80	NA	1	Range Highest LRAA	2.7 - 70 64	9.1 - 70 60	2.7 - 65 64	21 - 50 54	8.9 - 10 9.6 F	
Total Chlorine Residual Chlorine and Chloramines	H	ppm	MRDL = 4.0 as Cl <sub>2</sub>	MRDLG = 4 as Cl <sub>2</sub>	NA	Range Average	ND - 4.3 1.8	ND - 4.3 1.6	ND - 4.1 1.8	ND - 3.1 1.6	0.45 - 1.1 0.79	
METALS AS A BY-PRODUCT OF CORROSION OF CONSUMERS' PLUMBING I												
Copper	ppb	AL = 1300	300	50	NA	NA	90th percentile of 50 samples: 134 ppb   Zero samples exceeded the AL				J	K
Lead	ppb	AL = 15	0.2	5	NA	NA	90th percentile of 50 samples: 2 ppb   Zero samples exceeded the AL				J	K
SECONDARY STANDARDS – AESTHETIC STANDARDS												
PHYSICAL PARAMETERS H												
Color	Units	15	NA	NA		Range	ND - 15	NR	ND - 15	NR	NR	
						Average	ND	ND	ND	ND	---	
Odor Threshold	TON	3	NA	1		Range	1 - 2	NR	NR	NR	1 - 2	
						Average	1	1	1	1	---	
pH	pH unit	6.5 - 8.5	NA	NA		Range	6.3 - 8.9	6.3 - 8.9	7.3 - 8.3	6.3 - 8.6	---	
						Average	8.0	8.1	7.9	7.9	---	
Turbidity	NTU	5	NA	0.1		Range	ND - 0.4	ND - 0.9	ND - 1	ND - 0.3	ND - 0.3	
						Average	ND	ND	ND	ND	ND	



## FOOTNOTES

- A Total coliform MCLs: No more than 5.0% of the monthly samples may be total coliform-positive. Compliance is based on distribution system samples. The MCL was not violated in 2024.

B Fecal coliform/*E. coli* MCLs: An MCL violation is the occurrence of two (2) consecutive total coliform-positive samples, one of which contains fecal coliform or *E. coli*. There were zero detected fecal coliforms. The MCL was not violated in 2024.

C HPCs were tested only in distribution system samples, which had no detectable chlorine residual. No less than 95% of all distribution system samples in one month may have no detectable chlorine residual and an HPC greater than 500 colony forming units per mL. The HPC results were no less than 98.8% in any month in 2024.

D Bromate is a disinfection by-product resulting from the use of ozone. Currently, the Mills and Skinner Filtration plants use ozone. Values above the MCL may be acceptable so long as the RAA complies with the MCL.

E DLR = 1.0 ppb for each Haloacetic Acid 5 (HAA5) analyte (dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid) except for monochloroacetic acid which has a DLR = 2.0 ppb. Locational running annual averages and ranges are calculated from 12 samples sites collected quarterly throughout the distribution system. HAA5s are a by-product of drinking water chlorination.
- F The North Perris System is monitored annually for TTHM and HAA5. Compliance is determined by individual sample results and must be less than or equal to the MCL.

G Total Trihalomethanes (TTHMs) are the sum of the following analytes: bromodichloromethane, bromoform, chloroform, and dibromochloromethane. Locational Running Annual Averages (LRAA) and ranges are calculated from 12 sample sites collected quarterly throughout the distribution system. TTHMs are a by-product of drinking water chlorination. Values above the MCL may be acceptable so long as the LRAA complies with the MCL.

H Compliance is determined by the average, however all samples are reviewed and any values outside the compliance range are noted and corrected if possible. Values above the MRDL or MCL may be acceptable so long as the average complies with the MCL.
- I Lead and Copper are regulated as a Treatment Technique under the Lead and Copper Rule, which requires EMWD to take 50 water samples at the consumers' tap every three years. Results are from 2022. 20 tap samples are collected within the City of Perris water system service, and 20 tap samples are collected within the North Perris Water System service area every 3 years. Neither lead nor copper are typically found in the source waters but can get into water by way of internal corrosion of household plumbing.

J North Perris Water System last conducted lead and copper tap sampling in 2023. A total of 20 samples were collected, with 90th percentile lead result of <5 ppb and copper result of 180 ppb.

K The City of Perris water system last conducted lead and copper tap sampling in 2024. A total of 20 samples were collected, with 90th percentile lead result of <5 ppb and copper result of 150 ppb.

EASTERN MUNICIPAL WATER DISTRICT 2024 WATER QUALITY TABLE

WE ARE REQUIRED TO MONITOR YOUR DRINKING WATER FOR SPECIFIC CONTAMINANTS ON A REGULAR BASIS.

RESULTS ARE AN INDICATOR THAT YOUR DRINKING WATER MEETS HEALTH STANDARDS.

Parameter	Units	State or Federal Maximum Contaminant Level (MCL)	California Public Health Goal (PHG)	State Detection Limit for Reporting (DLR)
Percent of total water delivered by EMWD	%	---	---	---
PRIMARY DRINKING WATER STANDARDS – MANDATORY HEALTH-RELATED STANDARDS				
CLARITY				
Combined Filter Effluent Turbidity	NTU and %	N	NA	N
INORGANIC CHEMICALS				
Aluminum	ppb	1000 O 200	600	50
Arsenic	ppb	10	0.004	2
Barium	ppb	1000	2000	100
Fluoride P	ppm	2.0	1	0.1
Hexavalent Chromium	ppb	10	0.02	0.1
Nitrate (as N)	ppm	10	10	0.4
Nitrite (as N)	ppm	1	1	0.4
Perchlorate	ppb	6	1	2
Selenium	ppb	50	30	5
RADIOLOGICALS				
Gross Alpha	pCi/L	15	MCLG = 0	3
Gross Beta	pCi/L	50	MCLG = 0	4
Radium - 226	pCi/L	5 Q	0.05	1
Radium - 228	pCi/L	5 Q	0.019	1
Uranium	pCi/L	20	0.43	1
SECONDARY DRINKING WATER STANDARDS – AESTHETIC STANDARDS				
Chloride	ppm	500	NA	NA
Color	units	15	NA	3
Specific Conductance	uS/cm	1600	NA	NA
Iron R	ppb	300	NA	100
Manganese	ppb	50	500	20
Sulfate	ppm	500	NA	0.5
Total Dissolved Solids (TDS)	ppm	1000	NA	NA
Turbidity, Laboratory S	NTU	5	NA	0.1

MENIFEE, MORENO VALLEY, NORTH CANYON LAKE, PERRIS & WILDOMAR									
Desalination Complex L		Mills Filtration Plant		North Perris Wells		Perris Filtration Plant		Perris Valley Wells M	
15.9%		31.2%				17.3%		3.0%	
Range	Average	Range	Average	Range	Average	Range	Average	Range	Average
		Highest NTU	% ≤ 0.3	Highest NTU	% ≤ 0.1	Highest NTU	% ≤ 0.1		
---	---	0.08	100	---	---	0.74	97	---	---
NR	ND	ND - 110	ND	NR	ND	NR	ND	NR	ND
NR	ND	NR	ND	NR	ND	NR	ND	NR	2.5
NR	ND	NR	ND	120 - 140	130	NR	ND	NR	209
NR	ND	0.6 - 0.9	0.7	0.4 - 0.6	0.5	ND - 0.3	ND	NR	0.4
NR	ND	NR	ND	ND - 0.2	ND	NR	ND	NR	1.2
ND - 2.1	1.7	NR	0.8	ND - 0.87	0.43	ND - 1.1	ND	5.7 - 6.5	0.6
ND - 0.53	ND	NR	ND	NR	ND	ND - 0.83	ND	NR	ND
NR	ND	NR	ND	NR	ND	NR	ND	NR	2.3
NR	ND	NR	ND	NR	ND	NR	ND	NR	ND
3.3 - 4.5	3.9	NR	ND	ND - 3.9	ND	NR	ND	NR	5.2
13 - 16	14	NR	ND	---	---	NR	12.9	NR	9.6
NR	ND	NR	ND	0.38 - 0.72	0.48	NR	ND	NR	ND
NR	ND	ND - 1	ND	ND - 1.2	ND	NR	ND	NR	ND
NR	ND	NR	ND	1 - 2	1.4	NR	ND	NR	1.8
95 - 145	115	41 - 67	54	86 - 97	91	48 - 120	71	NR	233
NR	ND	1 - 2	2	NR	ND	NR	ND	NR	ND
307 - 629	518	317 - 466	392	591 - 643	612	346 - 1210	502	NR	1120
ND - 668	ND	NR	ND	NR	ND	NR	ND	NR	ND
ND - 24	ND	NR	ND	NR	ND	NR	ND	NR	ND
15 - 29	21	21 - 47	34	22 - 34	28	19 - 224	46	NR	53
259 - 462	332	178 - 263	220	381 - 412	396	199 - 715	289	800 - 852	826
NR	ND	NR	ND	ND - 0.3	ND	NR	ND	NR	ND

MURRIETA	
Skinner Filtration Plant	
13.3%	
Range	Average
Highest NTU	% ≤ 0.3
0.07	100
ND - 160	74
NR	ND
NR	116
0.6 - 0.8	0.7
NR	ND
NR	ND
NR	ND
NR	ND
NR	ND
ND - 4	ND
ND - 5	4
NR	ND
NR	ND
ND - 3	2
92 - 100	96
1 - 2	2
903 - 917	910
NR	ND
NR	ND
195 - 203	199
560 - 572	566
NR	ND

HEMET & SAN JACINTO			
East Valley Wells		Hemet Filtration Plant	
10.4%		8.7%	
Range	Average	Range	Average
		Highest NTU	% ≤ 0.1
---	---	0.15	100
NR	ND	NR	ND
ND - 5.6	2.3	NR	2.3
ND - 187	114	NR	ND
0.1 - 0.3	0.2	ND - 0.1	ND
NR	ND	NR	ND
ND - 3.4	0.75	ND - 1.6	ND
NR	ND	ND - 0.8	ND
NR	ND	NR	ND
ND - 12	ND	NR	ND
ND - 10.6	3.5	NR	ND
ND - 20	8.5	NR	18.6
NR	ND	NR	ND
NR	ND	NR	ND
ND - 6.6	2.4	NR	ND
9.8 - 105	33	38 - 84	58
NR	ND	ND - 2.5	1.9
316 - 938	509	280 - 527	396
ND - 213	ND	NR	ND
NR	ND	NR	ND
9.7 - 177	56	15 - 46	30
196 - 582	313	157 - 305	228
ND - 0.26	ND	NR	ND

Major Sources in Drinking Water
---
---
Soil runoff
Residue from water treatment process; natural deposits erosion
Natural deposits erosion; runoff from orchards; glass and electronics production wastes
Discharges of oil drilling wastes and from metal refineries; natural deposits erosion
Erosion of natural deposits; discharge from fertilizer and aluminum factories; water additive to promote strong teeth
Runoff/leaching from natural deposits; discharge from industrial wastes
Runoff/leaching from fertilizer use; septic tank and sewage; natural deposits erosion
Runoff/leaching from fertilizer use; septic tank and sewage; natural deposits erosion
Naturally-occurring in arid regions; industrial waste discharge
Refineries, mines, and chemical waste discharge; runoff from livestock lots
Erosion of natural deposits
Decay of natural and man-made deposits
Erosion of natural deposits
Erosion of natural deposits
Erosion of natural deposits
Runoff/leaching from natural deposits; seawater influence
Naturally-occurring organic materials
Substances that form ions in water; seawater influence
Leaching from natural deposits; industrial waste
Leaching from natural deposits
Runoff/leaching from natural deposits; industrial wastes
Runoff/leaching from natural deposits; seawater influence
Soil runoff

FOOTNOTES

- L Data is representative of the Menifee and Perris I Desalters, and Perris II Desalter, also known as the Desalination Complex.
- M Values are from Well 59 after granular activated carbon treatment.
- N The turbidity level of the combined filter effluent at the Mills and Skinner Filtration plants shall be less than or equal to 0.3 NTU in 95% of the measurements taken each month and shall not exceed 1 NTU at any time. For the Perris and Hemet Filtration plants, the turbidity level of the combined filter effluent shall be less than or

- equal to 0.1 NTU in 95% of the measurements taken each month and shall not exceed 1 NTU at any time. Turbidity is a measure of the cloudiness of the water, is regulated as a treatment technique (TT) and is an indicator of treatment performance.
- O Aluminum has both primary (1,000 ppb) and secondary (200 ppb) standards (MCLs).
- P Metropolitan began fluoride treatment of water at Mills and Skinner Filtration plants in 2007.

- Q The MCL of 5 pCi/Lis for combined radium (radium-226 + radium-228)
- R Compliance is determined by the average, however all samples are reviewed and any values outside the compliance range are noted and corrected if possible. Values above the MRDL or MCL may be acceptable so long as the average complies with the MCL.

- S Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. Secondary standards were based either on the treatment plant effluent or raw well water.



Represents 2019-2020 Data Values

Represents 2023 Data Values



EASTERN MUNICIPAL WATER DISTRICT 2024 WATER QUALITY TABLE

WE ARE REQUIRED TO MONITOR YOUR DRINKING WATER FOR SPECIFIC CONTAMINANTS ON A REGULAR BASIS.

RESULTS ARE AN INDICATOR THAT YOUR DRINKING WATER MEETS HEALTH STANDARDS.

Parameter	Units	State or Federal Maximum Contaminant Level (MCL)	California Public Health Goal (PHG)	State Detection Limit for Reporting (DLR)
OTHER PARAMETERS				
Alkalinity Total (CaCO3)	ppm	NA	NA	NA
Boron	ppb	NL = 1000	NA	100
Calcium	ppb	NA	NA	NA
Hardness as Calcium Carbonate <sup>T</sup>	grains/gallon	NA	NA	NA
Magnesium	ppm	NA	NA	NA
Potassium	ppm	NA	NA	NA
Sodium	ppm	NA	NA	NA
Total Organic Carbon	ppm	TT	NA	0.3
UNREGULATED CONTAMINANT MONITORING				
Lithium	ppb	NA	NA	9
PERFLUOROALKYL AND POLYFLUOROALKYL SUBSTANCES (PFAS) <sup>U</sup>				
Perfluorobutanesulfonic acid (PFBS)	ppt	<sup>V</sup>	NA	3
Perfluorobutanoic acid (PFBA)	ppt	NA	NA	5
Perfluorohexanoic acid (PFHxA)	ppt	NA	NA	3
Perfluoropentanoic acid (PFPeA)	ppt	NA	NA	3

MENIFEE, MORENO VALLEY, NORTH CANYON LAKE, PERRIS & WILDOMAR									
Desalination Complex		Mills Filtration Plant		North Perris Wells		Perris Filtration Plant		Perris Valley Wells	
Range	Average	Range	Average	Range	Average	Range	Average	Range	Average
23 - 59	41	68 - 71	70	123 - 139	132	62 - 135	84	NR	121
183 - 508	372	NR	130	132 - 190	155	81 - 175	132	NR	381
24 - 110	35	15 - 22	18	42 - 49	45	19 - 83	27	NR	84
4.8 - 27	6.7	4.0 - 5.8	4.9	9.2 - 11	9.9	4.8 - 16	6.8	NR	18
5.1 - 44	7.5	8.4 - 11	9.7	13 - 17	14	8.6 - 29	12	NR	24
1.1 - 4.8	1.4	1.9 - 3.1	2.5	3.3 - 4.1	3.7	2.1 - 5.9	3.1	NR	2.7
44 - 214	57	35 - 54	44	56 - 60	58	36 - 121	55	NR	93
NR	ND	1.5 - 2.5	2.2	0.5 - 0.7	0.6	1.7 - 2.7	2.2	NR	0.4
NR	ND	NR	ND	NR	ND	ND - 9.1	ND	NR	10
NR	ND	NR	ND	NR	ND	NR	ND	ND - 3.1	ND
NR	ND	NR	ND	NR	ND	ND - 5.3	ND	ND - 35	22
NR	ND	NR	ND	NR	ND	NR	ND	ND - 24	5.7
NR	ND	NR	ND	NR	ND	NR	ND	ND - 100	33

MURRIETA		HEMET & SAN JACINTO			
Skinner Filtration Plant		East Valley Wells		Hemet Filtration Plant	
Range	Average	Range	Average	Range	Average
103 - 107	105	102 - 193	134	57 - 94	72
NR	130	ND - 222	ND	ND - 167	118
61 - 62	62	34 - 80	55	14 - 27	19
14.1 - 14.2	14.1	5.5 - 14.8	9.4	3.8 - 7.0	5.1
22 - 23	22	2.3 - 14.6	5.8	7.4 - 13	9.7
4.6 - 4.9	4.8	2.5 - 7.2	4.0	1.9 - 3.8	2.7
91 - 95	93	23 - 90	39	30 - 63	46
2.3 - 3.0	2.6	ND - 2.3	0.7	2.0 - 3.2	2.6
24 - 32	28	NR	ND	NR	ND
NR	ND	NR	ND	NR	ND
NR	ND	NR	ND	NR	ND
NR	ND	NR	ND	NR	ND
NR	ND	NR	ND	NR	ND

Major Sources in Drinking Water
---
Naturally-occurring carbonates; measures water's ability to neutralize acid
Runoff/leaching from natural deposits; industrial wastes
Naturally-occurring mineral
Naturally-occurring; the sum of calcium and magnesium in the water
Naturally-occurring mineral
Naturally-occurring mineral
Various natural and man-made sources; TOC is a precursor for the formation of disinfection byproducts
Naturally-occurring mineral
Naturally-occurring; used in electrochemical cells; batteries, and organic syntheses and pharmaceuticals
Industrial chemical factory discharges; runoff or leaching from landfills; used in fire-retardant foams and various industrial processes



FOOTNOTES

- <sup>T</sup> Water hardness, measured in grains per gallon as calcium carbonate, is characterized by the following scale: 0 - 4.4 is soft, 4.4 - 8.8 is moderately hard, 8.8 - 17.5 is hard and greater than 17.5 is very hard.
- <sup>U</sup> A total of 29 PFAS compounds were analyzed. Detected compounds are presented in the report, all other PFAS compounds were non-detected.
- <sup>V</sup> The State NL and RL is 500 ppt and 5,000 ppt, respectively. EPA MCL's were adopted in April 2024. Compliance is determined by a PFAS mixture containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS. The calculated co-occurring levels shall not exceed a Hazard Index of 1 (unitless).

ONE PART PER MILLION (PPM) (mg/L) IS LIKE

- 1 second in 11.5 days
- 1 teaspoon in 1,302 gallons
- 1 drop in 13.6 gallons



ONE PART PER BILLION (PPB) (mg/L) IS LIKE

- 1 second in nearly 32 years
- 1 teaspoon in 1.3 million gallons
- 1 drop in 13,563 gallons



ONE PART PER TRILLION (PPT) (ng/L) IS LIKE

- 1 second in nearly 32,000 years
- 1 teaspoon in 1.3 billion gallons
- 1 drop in 13,563,368 gallons



The State allows EMWD to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Data presented is from sampling completed in 2024, unless otherwise indicated. Some of EMWD's data, though representative, are more than one year old.

EMWD supports science-based standards that provide health benefits to the public in an economically balanced manner. Should more stringent standards be set, EMWD will meet them. EMWD's water has met and will continue to meet all regulations.

Unregulated contaminant monitoring helps EPA and the State Water Board determine where certain contaminants occur and whether the contaminants need to be regulated.



Eastern Municipal Water District  
2270 Trumble Road  
PO Box 8300  
Perris, CA 92572-8300

PSRST STD  
US POSTAGE  
PAID  
PERRIS, CA  
PERMIT NO.10

## Your 2024 Water Quality CONSUMER CONFIDENCE REPORT

Issued July 2025

### DO YOU WANT A PAPER OR ELECTRONIC COPY OF THIS REPORT?

The choice is yours! It's easy to tell us how you want to receive future water quality reports, or if you would like to change your current delivery method.

Just use one of the following options:

1. Tell us online at [www.emwd.org/CCR](http://www.emwd.org/CCR).
2. Call 951-928-3777, extension 3430.

## Public Meetings

EMWD's Board of Directors meetings are generally held on the 1st and 3rd Wednesdays of each month beginning at 9:00 a.m.

If you wish to attend a meeting, please call the Board Secretary during normal business hours at 951-928-3777, extension 4235 to confirm meeting dates or check the Board Meeting Calendar online at [www.emwd.org/BoardMeetings](http://www.emwd.org/BoardMeetings).

For more information on this report, contact:  
**Water Quality (951) 928-3777, extension 3327**  
or visit [www.emwd.org/WaterQuality](http://www.emwd.org/WaterQuality).

## Why You Should Read This Report

THIS YEAR'S DRINKING WATER QUALITY REPORT...

- Examines how EMWD ensures your drinking water is safe, high quality, and reliable.
- Provides science-based data and facts about the sources, quality, and safety of your drinking water.
- Explains how customers can always choose how they wish to receive future water quality reports.

## Would You Like to Receive This Report in Spanish?

IF YOU WOULD LIKE TO OBTAIN THIS INFORMATION IN SPANISH, VISIT [WWW.EMWD.ORG/CCR](http://WWW.EMWD.ORG/CCR) AND SELECT "ESPAÑOL" OR CALL (951) 928-3777 EXTENSION 4326 FOR A SPANISH COPY BY MAIL.

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE CON SOBRE LA CALIDAD DE SU AGUA. SI USTED DESEA OBTENER INFORMACIÓN EN ESPAÑOL, VISITA [WWW.EMWD.ORG/CCR](http://WWW.EMWD.ORG/CCR) Y SELECCIONE "ESPAÑOL" O LLAME (951) 928-3777, EXTENSIÓN 4326 PARA SOLICITAR UNA COPIA POR CORREO.