State of California
Division of Drinking Water

State Water Resources Control Board
Riverside District

Stage 2 DBPR TTHM and HAA5 Report for Disinfection Byproducts Compliance (in µg/L or ppb)

For Systems Monitoring Annually or Every Three Years

System Name: **Home Gardens County WD** System No.: **3310018** Year: **2018** Quarter: **3rd**

TTHM MCL = 0.080 mg/L or 80 ug/L
HAA5 MCL = 0.060 mg/L or 60 ug/L

Year:		2014	2015	2015	2016	2017	2018	2019	2020	2021	2022
Sample Date (month/day):		7/1	6/15	7/23	7/7	7/11	7/18				
#	Monitoring Location	TTHM Results (ug/L)									
1	4150 Temescal	1.9	0.0	5.0	19.0	18.0	20.0				
2	3473 Andover	2.5	1.2	9.6	26.0	17.0	18.0				
Number of Samples Taken		2	2	2	2	2	2				
Meets standard for all monitoring locations (i.e., TTHM results ≤ MCL)?		yes	yes	yes	yes	yes	yes				
If no, list monitoring location # where MCL not met (a)											
#	Monitoring Location	HAA5 Results (ug/L)									
1	4150 Temescal	7.2	2.7	11.0	6.6	4.8	7.3				
2	3473 Andover	0.0	0.0	4.5	7.9	4.9	7.3				
Number of Samples Taken		2	2	2	2	2	2				
Meets standard for all monitoring locations (i.e., HAA5 results ≤ MCL)?		yes	yes	yes	yes	yes	yes				
If no, list monitoring location # where MCL not met (a)											

(a) If a TTHM sample is greater than the TTHM MCL or a HAA5 sample is greater than the HAA5 MCL at any monitoring location, system is required to increase monitoring to dual sample sets once per quarter (taken every 90 days) at all locations. A quarterly reporting form is available from the local District Office. Compliance with the MCLs shall then be determined by the average of the sample that triggered the quarterly monitoring and the following three quarters of monitoring. The average for each monitoring location is called a Locational Running Annual Average (LRAA). If the results of fewer than four quarters of monitoring will cause the LRAA to exceed the TTHM MCL or HAA5 MCL, system is in violation immediately.

Signature

Date