

2018 Consumer Confidence Report

Water System
Name:

Rosa Morada Mutual Water Company

Report Date: **July 1, 2019**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Rosa Morada Mutual Water Company a (831) 245-6250 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Rosa Morada Mutual Water Company 以获得中文的帮助: [Enter Water System's Address Here] [Enter Water System's Phone Number Here]

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Enter Water System's Name and Address Here] o tumawag sa [Enter Water System's Phone Number Here] para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Rosa Morada Mutual Water Company tại (831) 245-6250 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Rosa Morada Mutual Water Company ntawm (831) 245-6250 rau kev pab hauv lus Askiv.

Type of water source(s) in use: **Well (Groundwater, no surface waters used)**

Name & general location of source(s):

Dooling Road Well (-002) – Primary water supply

Morada Lane Well (-004) – Standby Supply (fire, back-up drinking water)

Drinking Water Source Assessment information: **July 2001 assessments for both wells are available upon Request.**

Time and place of regularly scheduled board meetings for public participation:

Yearly in July and other meetings as scheduled. Contact Larry Slonaker for more information.

For more information,
contact:

**Janet Serrano
Larry Slonaker**

Phone: **(831) 630-9421
(831) 245-6250**

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a mo.) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	8/6/18	5	0.007	0	15	0.2		Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	8/6/18	5	0.62	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Note: There are no schools in our distribution system, and therefore, no schools have requested that we conduct additional lead sampling.

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	12/27/16	26	NA (1 sample)	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	12/27/16	160	NA (1 sample)	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
MICROBIOLOGICAL CONTAMINANTS						
Total Coliform Bacteria (Total Coliform Rule)	The Dooling well is monitored quarterly and the Morada well is monitored annually. No samples contained coliform bacteria. No E. coli was detected.					Naturally present in the environment
INORGANIC CONTAMINANTS						
Aluminum (ppb)	11/19/13 9/14/10	ND 0.056	1 sample 1 sample	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Arsenic (ppb)	12/27/16 11/19/13 09/14/10	3.8 3.2 4.0	1 sample 1 sample 1 sample	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Fluoride (ppm)	12/27/16 11/19/13 9/14/10	0.14 0.21 0.15	1 sample 1 sample	2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as nitrogen, N) (ppm)	12/5/18 9/13/17 12/27/16 3/4/16	0.71 0.78 0.81 0.90	1 sample 1 sample 1 sample 1 sample	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Turbidity	12/27/16 09/14/10	0.24 2.6	1 sample 1 sample	TT	N/A	Soil runoff
RADIOACTIVE CONTAMINANTS 0.24						
Gross Alpha	12/18/12	1.16	1 sample	15	0	Erosion of natural deposits
Radium-228 MDA95 (pCi/L)	02/28/17	2.98	1 sample	5	0.019	Erosion of natural deposits
Radium-226 (pCi/L)	02/28/17	0.56	1 sample	5	0.05	Erosion of natural deposits
DISINFECTION BYPRODUCTS, DISINFECTION RESIDUALS, AND DISINFECTION BYPRODUCT PRECURSORS						
TTHMs (Total Trihalomethanes) (ppb)	8/6/18	16	1 sample	80	N/A	By-product of drinking water disinfection
Haloacetic Acids (ppb)	8/6/18	ND	1 sample	60	N/A	Byproduct of drinking water disinfection
Chlorine (ppm)	Monthly Samples	0.42	12 samples	MRDL = 4.0 (as Cl ²)	MRDLG = 4.0 (as Cl ²)	Drinking water disinfectant added for treatment

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD^(a)

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Aluminum (ppb)	9/14/10	.056	1 sample	200	n/a	Erosion of natural deposits; residual from some surface water treatment processes
Color (units)	9/14/10	5	1 sample	15	n/a	Naturally-occurring organic materials
Iron (ppb)	9/14/10	190	1 sample	300	n/a	Leaching from natural deposits; industrial wastes
Manganese (ppb)	9/14/10	32	1 sample	50	n/a	Leaching from natural deposits
Odor Threshold (units)	11/19/13	1	1 sample	3		Naturally-occurring organic materials
Turbidity (units)	12/27/16 9/14/10	0.24 2.6	1 sample 1 sample	5	n/a	Soil runoff
Total Dissolved Solids (TDS) (ppm)	12/27/16 11/19/13 9/14/10	290 280 280	1 sample 1 sample 1 sample	1000	n/a	Runoff/leaching from natural deposits
Specific Conductance (umho)	12/27/16 11/19/13 9/14/10 6/22/10 12/21/09	390 370 400 380 410	1 sample 1 sample 1 sample 1 sample 1 sample	1600	n/a	Substances that form ions when in water; seawater influence
Chloride (ppm)	12/27/16 11/19/13 9/14/10	24 23 24	1 sample 1 sample 1 sample	500	n/a	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	12/27/16 11/19/13 9/14/10	27 28 27	1 sample 1 sample 1 sample	500	n/a	Runoff/leaching from natural deposits; industrial wastes

(a) There are no PHGs, MCLGs, or mandatory standard health effects language for these constituents because secondary MCLs are set on the basis of aesthetics.

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
N/A					

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/

Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rosa Morada Mutual Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [**OPTIONAL:** If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Residents Please Note:

This report, as mandated by the state Water Resources Control Board, provides information only for the potential drinking water contaminants for which measurable levels were detected in 2009 through 2018.

Rosa Morada collects samples for the detection of many more water contaminants than those reflected in this report. The analyses for these are reported as “no detectable levels found” and hence are not reported in this document.

A more complete understanding of the quality of the water provided to the residents is gained by looking at the complete data set. If you have questions, or would like to review the water monitoring data, please contact me.

—Janet Serrano

For Water Systems Providing Groundwater as a Source of Drinking Water

**TABLE 7 – SAMPLING RESULTS SHOWING
FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLES**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	None (In the year)		0	(0)	Human and animal fecal waste
Enterococci	None (In the year)		TT	N/A	Human and animal fecal waste
Coliphage	None (In the year)		TT	N/A	Human and animal fecal waste