

December 2021

2020 Annual Drinking Water Quality Report

(Consumer Confidence Report)

San Justo Mutual Water Company (System No. CA 3500550)

Attached is the annual drinking water quality report to consumers of the water provided by San Justo Mutual Water Company. We are pleased to report that our drinking water is safe and meets all federal and state requirements. San Justo Mutual Water Company routinely monitors for contaminants in your drinking water according to federal and state laws. This report shows the results of our monitoring for calendar year 2020. All drinking water may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily pose a health risk. Our water chemistry is in compliance with federal and state standards for Organic and Inorganic analysis, Radiological, General Mineral and General Physical Water Quality, Lead and Copper analysis and Microbiological monthly monitoring.

If you have any questions please contact Paul Schweiger at (831) 245-8044

2020 Consumer Confidence Report

Water System Information

Water System Name: San Justo Mutual Water Company

Report Date: December 29th, 2021

Type of Water Source(s) in Use: Well

Name and General Location of Source(s): 3000 Cienega Road, Hollister, CA; PWS Number CA3500550-001

Drinking Water Source Assessment Information:

A source water assessment was conducted for the **WELL 01 - RAW** of the **SAN JUSTO MUTUAL WATER COMPANY** water system in August, 2002.

The source is considered most vulnerable to the following activities associated with contaminants detected in the water supply:

Crops, irrigated [Berries, hops, mint, orchards, sod, greenhouses,
Fertilizer/Pesticide/Herbicide Application

The source is considered most vulnerable to the following activities not associated with any detected contaminants:

Transportation corridors - Roads/Streets

Discussion of Vulnerability

Well 01 is considered most vulnerable to Fertilizer, Pesticide/Herbicide Application and Crops, irrigated. These activities are associated with the contaminant nitrate, which has been detected in the water supply. Many pesticide products are highly toxic and quite mobile on the subsurface; therefore, posing a potential risk to reach the ground water supply.

A copy of the complete assessment may be viewed at:

San Justo Mutual Water Company
155 Hilltop Dr.
Hollister, CA 95023

You may request a summary of the assessment be sent to you by contacting:

Paul Schweiger
President
(831) 245-8044

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Call Paul Schweiger

For More Information, Contact: Paul Schweiger (831) 245-8044

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2020 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Enter Water System's Name] a [Enter Water System's Address or Phone Number] para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Enter Water System Name] 以获得中文的帮助: [Enter Water System's Address][Enter Water System's Phone Number].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Enter Water System's Name and Address] o tumawag sa [Enter Water System's Phone Number] para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Enter Water System's Name] tại [Enter Water System's Address or Phone Number] để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Enter Water System's Name] ntawm [Enter Water System's Address or Phone Number] rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Term	Definition
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (State Total Coliform Rule)	(In a month) 0	0	1 positive monthly sample ^(a)	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (State Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is	None	Human and animal fecal waste

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
			also fecal coliform or <i>E. coli</i> positive		
<i>E. coli</i> (Federal Revised Total Coliform Rule)	(In the year) 0	0	(b)	0	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	7/16/2019	5	ND	0	15	0.2	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	7/16/2019	5	0.094	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	3/1/2019	140		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	3/1/2019	450		None	None	Sum of polyvalent cations present in the water, generally magnesium and

						calcium, and are usually naturally occurring
--	--	--	--	--	--	----------------------------------------------

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Turbidity (NTU)	3/1/2019	0.2		5	N/A	Soil runoff
Gross Alpha Particle Activity (pCi/L)	5/9/2018	2.51		15	(0)	Erosion of natural deposits
Radium-226 & 228 (pCi/L)	3/10/2016	0.028		5	(0)	Erosion of natural deposits
Combined Uranium (pCi/L)	5/9/2018	2.7		20	0.43	Erosion of natural deposits
Arsenic (µg/L)	3/1/2019	1.2		10	0.004	Erosion of natural deposits; glass and electronics production wastes
Barium (mg/L)	3/1/2019	0.025		1	2	Discharge of oil drilling wastes and rom metal refineries; erosion of natural deposits
Chromium (µg/L)	3/1/2019	9.2		50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (mg/L)	3/1/2019	0.38		2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and

						aluminum factories
Nitrate (mg/L)	12/22/2020	3		10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (µg/L)	3/1/2019	2.7		50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufactures; runoff from livestock lots (feed additive)
TTHMs (µg/L)	8/27/2019	6.2		80	N/A	Byproduct of drinking water disinfection

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Iron (µg/L)	3/1/2019	69		300	N/A	Leaching of natural deposits; industrial wastes
Zinc (mg/L)	3/1/2019	1		5.0	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	3/1/2019	870		1,000	N/A	Runoff/leaching from natural deposits
Specific Conductance (µS/cm)	3/25/2020	1,200		1,600	N/A	Substances that form ions when in water; seawater influence

Chloride (mg/L)	3/1/2019	110		500	N/A	Runoff/leaching from natural deposits; seawater influence
Sulfate (mg/L)	3/1/2019	270		500	N/A	Runoff/leaching from natural deposits; industrial wastes

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. San Justo Mutual Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: N/A

Federal Revised Total Coliform Rule (RTCR): N/A

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
0				

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Not Applicable to San Justo Mutual Water Company

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year)		0	(0)	Human and animal fecal waste
Enterococci	(In the year)		TT	N/A	Human and animal fecal waste
Coliphage	(In the year)		TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A

Special Notice for Uncorrected Significant Deficiencies: N/A

Table 9. Violation of Groundwater TT

Not Applicable to San Justo Mutual Water Company

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language

For Systems Providing Surface Water as a Source of Drinking Water

Table 10. Sampling Results Showing Treatment of Surface Water Sources

Not Applicable to San Justo Mutual Water Company

Treatment Technique ^(a) (Type of approved filtration technology used)	[Enter Treatment Technique]
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	<p>Turbidity of the filtered water must:</p> <p>1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month.</p> <p>2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours.</p> <p>3 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded at Any Time] NTU at any time.</p>
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	[Enter No.]
Highest single turbidity measurement during the year	[Enter No.]
Number of violations of any surface water treatment requirements	[Enter No.]

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

Table 11. Violation of Surface Water TT

Not Applicable to San Justo Mutual Water Company

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language

Summary Information for Operating Under a Variance or Exemption

N/A

Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

N/A

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

N/A