

2019 Consumer Confidence Report

Water System Name: BETABEL RV RESORT Report Date: 06/28/20

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Well

Name & location of source(s): Well 3500836-001 in the Park

Drinking Water Source Assessment information: A source water assessment was conducted at the source. A copy of the complete assessment may be viewed by contacting the State Water Resources Control Board, Division of Drinking Water, Monterey District, 1 Lower Ragsdale Dr., Bldg.1, Suite 120, Monterey CA 93940 (831) 655-6939

For more information, contact Charles S. Keen, Operator (408) 968-0767
Phone: _____

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA and the state Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

| Microbiological Contaminants (complete if bacteria detected) | Highest No. of Detectio ns | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria |
|---|----------------------------------|-------------------------------------|--|------|--------------------------------------|
| Total Coliform Bacteria (state Total Coliform Rule) | (In a month) 0 | 0 | 1 positive monthly sample | 0 | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule) | (In the year) 0 | 0 | A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive | | Human and animal fecal waste |
| <i>E. coli</i> (federal Revised Total Coliform Rule) | (In the year) 0 | 0 | (a) | 0 | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

| Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set) | No. of samples collected | 90 th percentile level detected | No. Sites exceeding AL | AL | PHG | Typical Source of Contaminant |
|---|--------------------------------|---|------------------------------|-------|-----|--|
| Lead (mg/l) 09/2019 | 5 | 0.059 | 0 | 0.015 | 0.2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits. |
| Copper (mg/l) 09/2019 | 5 | 0.345 | 0 | 1.3 | 0.3 | Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives. |

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|--|----------------|-------------------|------------------------|------|---------------|--|
| Sodium (mg/l) | 12/17 | 65 | n/a | none | none | Salt present in the water and is generally naturally occurring |
| Hardness (mg/l) | 12/17 | 370 | n/a | none | none | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

* Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided on the next page.

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|--|----------------|-------------------|------------------------|---------------|--------------------------|---|
| Arsenic (ug/l) | 12/17 | 3.4 | N/A | 10.0 | 0.004 | Erosion of natural deposits; runoff from orchards; glass and electronics production wastes |
| Fluoride (mg/l) | 12/17 | 0.24 | N/A | 2 | 1 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Gross Alpha Activity pCi/L | 07/15 | 3.26 | 0.0 - 6.9 | 15 | 0 | Erosion of natural deposits. |
| Nitrate as nitrogen, N (mg/l) | 06/19 | 1.1 | N/A | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Nitrite as nitrogen, N (mg/l) | 12/17 | ND | N/A | 1 | 1 | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Uranium (pCi/L) | 02/15 | 3.4 | N/A | 20 | 0.43 | Erosion of natural deposits |

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|--|----------------|-------------------|------------------------|------|---------------|---|
| Total Dissolved Solids (mg/l) | 12/17 | 510 | N/A | 1000 | N/A | Runoff/leaching from natural deposits |
| Specific Conductance (micromhos) | 12/17 | 870 | N/A | 1600 | N/A | Substances that form ions when in water; seawater influence |
| Turbidity (NTU) | 12/17 | 0.12 | N/A | 5 | N/A | Soil runoff |
| Chloride (mg/l) | 12/17 | 51 | N/A | 500 | N/A | Runoff/leaching from natural deposits; seawater influence |
| Manganese (ug/l) * | 2019 | 150 | 120-150 | 50 | N/A | Leaching from natural deposits |
| Sulfate (mg/l) | 12/17 | 92 | N/A | 500 | N/A | Runoff/leaching from natural deposits; industrial wastes |

* Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided below.

Manganese Feb., May, Aug., Nov. 2019. We test quarterly. The MCL is 50. The results for 2019 were:
Feb 120, May 150, Aug 150, Nov 150

In July 2015, we tested our well water for Volatile Organic Chemicals, including MTBE. In June 2014 we tested for Synthetic Organic Chemicals. All of these chemicals were "Non Detected"

We tested for Trichloropropane (1,2,3 - TCP) in 2/18, 5/18, 8/18, 11/18 - all were "Non Detected".

Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).