



2167 DARBY ST.
SAN BERNARDINO, CA 92407
(909) 887-2964 FAX (909) 880-1976

2025 Consumer Confidence Report

Water System Information

Water System Name: Muscoy Mutual Water Company No 1

Report Date: July 1, 2026

Type of Water Source(s) in Use: Ground Water Wells

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Board Meetings are held the 2nd Thursday of every month, at 9:00 a.m. at our office, 2167 Darby Street, San Bernardino, California.

Name and General Location of Source(s): 4 wells located in the Cajon Basin and a 5th well located approximately 200 yards East of Cajon Creek, 2680 Reservoir Rd, San Bernardino.

For More Information, Contact: Muscoy Mutual Water (909) 887-2964

Source Water Assessment

In September 2001, Muscoy Mutual Water and the California Department of Public Health conducted Source Water Assessments (SWA) for Wells 1,2,3,4, and 5. The assessments include a section listing the vulnerability to activities associated with contaminants detected in water supplies.

Below is a list identifying potential activities that can contribute to groundwater contamination:

- Chemical/Petroleum Pipelines
- Septic Systems
- Wells - Water Supply
- Railroads
- Roads/Streets

Muscoy Mutual Water (MMW) continues to closely monitor contaminants that are associated with these activities, and no contaminants have been detected above the Maximum Contaminant Levels (MCL) set by the State Water Resources Control Board (State Water Board).

The SWA is available in our office, please contact MMW for further information at (909) 887-2964.

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025 and may include earlier monitoring data.

Importance of This Report

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Muscoy Mutual Water Company No.1 a (909) 887-2964 para asistirlo en español.

Terms Used in This Report

Term	Definition
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
NL	Notification Level: California or U.S. EPA health advisory level to indicate concern.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or microgram per liter (ug/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables on the following pages list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding a violation if one occurred is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Microbiological Contaminants	Sample Date	Highest No. of Detections	Violation Y/N	TT (MCL)	MCLG	Typical Source of Bacteria
Fecal coliform and E.coli (State Total Coliform Rule)	2025	0	No	(Routine and repeat samples are total coliform-positive and either is E. coli-positive or system fails to take repeat samples following E. coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli.)	0	Human and animal fecal waste

Table 2. Lead and Copper at Residential Taps Sampled in 2023 - Lead and Copper Samples are collected on a tri-annual basis. The next monitoring will be conducted in 2026.

LEAD and COPPER	No. of Sites Sampled	AL	90 th Percentile Level Detected	No. of Sites Exceeding AL	Range of Detections	PHG	Violation	No. of Schools Requesting Lead Sampling	Typical Source Of Contaminant
Lead (ppb) ug/L	20	15	ND	0	ND - ND	0.2	No	3	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	20	1.3	0.130	0	ND - 0.240	0.3	No	Not Applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2024	17.6	17 - 19	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2024	228	220 - 230	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Alpha Activity Gross (pCi/L)	2025	ND	ND - 3.3	15	0	Erosion of natural deposits
Uranium (pCi/L)	2025	2.6	2.5 - 2.8	20	0	Erosion of natural deposits
Radium 228 (pCi/L)	2025	ND	ND - 1.45	5	0	Erosion of natural deposits
Fluoride (mg/L)	2024	0.48	0.42 - 0.55	2	1	Erosion of natural deposits; discharge from fertilizer and aluminum factories
Nitrate (as NO ₃) mg/L	2025	3.1	2.8 - 3.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Hexavalent Chromium (Chromium VI) (ug/L)	2024	ND	ND - 1.3	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities, erosion of natural deposits
Haloacetic Acids (HAA5) (ug/L)	2025	ND	ND	60	NS	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ug/L)	2025	2.65	ND - 5.3	80	NS	By-product of drinking water disinfection
Chlorine (mg/L)	2025	0.60	0.30 - 1.50	4	4	Drinking water disinfectant added for treatment

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride(mg/L)	2024	9.70	8.5 - 11.0	500	NS	Runoff/leaching from natural deposits
Iron (ug/L)	2024	ND	ND	300	NS	Leaching from natural deposits; industrial wastes
Sulfate(mg/L)	2024	39.8	38 - 42	500	NS	Runoff/leaching from natural deposits; industrial wastes
Specific Conductance (uS/cm)	2024	500	490 - 510	1600	NS	Substances that form ions when in water; seawater influence

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved (mg/L)	2024	296	280 - 310	1000	NS	Runoff leaching from natural deposits
Odor-Threshold(units)	2024	1	1.0 - 1.0	3	NS	Naturally occurring organic materials
Turbidity(NTU)	2024	ND	ND	5	NS	Soil runoff

Table 6. Detection of Unregulated Contaminants

Unregulated contaminant monitoring helps U.S. EPA and the State Water Resources Control Board to determine where certain contaminants occur and whether the contaminants need to be regulated.

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
PFHxS (ng/L)	2025	NS	ND - 4.5	3	Perfluorohexane sulfonic acid exposures resulted in decreased total thyroid hormone in male rats.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. MMW is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact MMW at (909) 887-2964.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Lead Service Line Inventory (LSLI)

Protecting our customers' health and safety is our highest priority. As part of this commitment, we have been working to identify any old water service lines and fittings that may contain lead so that customers can make necessary replacements. This effort complies with EPA's 2021 Lead and Copper Rule Revisions, which require that public water systems comply with the regulations starting on October 16, 2024. These requirements include an initial service line inventory.

MMW completed its service line inventory in August of 2024 and is available to the public by contacting our office at (909) 887-2964. Based upon information gathered at the time of the survey(s), MMW has determined to the best of its knowledge that it has no known lead service lines in its water system.