

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	BIG WHEEL MOBILE HOME PARK
Water System Number:	CA3900637

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Jim Wunderlich	
	Signature:	Jim Wunderlich	
	Title:	CDO	
	Phone Number:	(209) 403-1547	Date: 4-28-2022

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://> _____
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations) *Post in mail boxes*
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2021 Consumer Confidence Report

Water System Name: BIG WHEEL MOBILE HOME PARK

Report Date: April 2022

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2021.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): NORTH WELL and SOUTH WELL

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not being held.

For more information about this report, or any questions relating to your drinking water, please call (209)462-8939 and ask for Betty Warford.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/year (2021)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021)	20	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021)	222	221 - 223	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2021)	4	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2021)	0.15	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits

Hexavalent Chromium (ug/L)	(2014)	4.56	4.18 - 4.94		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Fluoride (mg/L)	(2021)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2021)	6	5.2 - 7.3	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2021)	5.7	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2020 - 2021)	8.31	6.51 - 10.1	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2020 - 2021)	3.844	3.60 - 4.087	20	0.43	Erosion of natural deposits

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2021)	12	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2021)	526	521 - 530	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021)	24.8	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021)	355	350 - 360	1000	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (ug/L)	(2021)	24	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2021)	50	49 - 50	n/a	n/a
Magnesium (mg/L)	(2021)	24	n/a	n/a	n/a
pH (units)	(2021)	7.2	n/a	n/a	n/a
Alkalinity (mg/L)	(2021)	210	n/a	n/a	n/a
Aggressiveness Index	(2021)	11.6	n/a	n/a	n/a
Langelier Index	(2021)	-0.2	n/a	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2021)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Big Wheel Mobile Home Park* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

About your Nitrate as N: Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also

affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

2021 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the NORTH WELL and for the SOUTH WELL of the BIG WHEEL MOBILE HOME PARK water system in July, 2002.

NORTH WELL - is considered most vulnerable to the following activities not associated with any detected contaminants:
Railroad yards/maintenance/fueling areas

SOUTH WELL - is considered most vulnerable to the following activities not associated with any detected contaminants:
Automobile - Gas stations

Discussion of Vulnerability

North Well - There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

South Well - There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source

Acquiring Information

A copy of the complete assessment may be viewed at:

San Joaquin County
Environmental Health Department
304 E. Weber Ave, 3rd Floor
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems
SJ Co Environmental Health Department
(209) 468-3420

Big Wheel Mobile Home Park Analytical Results By FGL - 2021

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
Site #12	STK2158308-2					2021-12-23	<1.0		
Site #63	STK2158308-1					2021-12-23	<1.0		
Site #63	STK2158071-1					2021-12-21	Present		
Site #63	STK2156142-1					2021-11-09	Absent		
Site #63	STK2154800-1					2021-10-14	Absent		
Site #63	STK2153319-1					2021-09-16	Absent		
Site #63	STK2152072-1					2021-08-24	Absent		
Site #63	STK2150090-1					2021-07-19	Absent		
Site #63	STK2138302-1					2021-06-14	Absent		
Site #63	STK2137004-1					2021-05-20	Absent		
Site #63	STK2135023-1					2021-04-15	Absent		
Site #63	STK2133310-1					2021-03-10	Absent		
Site #63	STK2132246-1					2021-02-16	Absent		
Site #63	STK2130772-1					2021-01-18	Absent		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			20	20 - 20
North Well	STK2132249-1	mg/L				2021-02-16	20		
South Well	STK2132248-1	mg/L				2021-02-16	20		
Hardness		mg/L		none	none			222	221 - 223
North Well	STK2132249-1	mg/L				2021-02-16	223		
South Well	STK2132248-1	mg/L				2021-02-16	221		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			4	4 - 4
North Well	STK2132249-1	ug/L				2021-02-16	4		
South Well	STK2132248-1	ug/L				2021-02-16	4		
Barium		mg/L	2	1	2			0.15	0.15 - 0.15
North Well	STK2132249-1	mg/L				2021-02-16	0.15		
South Well	STK2132248-1	mg/L				2021-02-16	0.15		
Hexavalent Chromium		ug/L			0.02			4.56	4.18 - 4.94
North Well	STK1450793-1	ug/L				2014-10-20	4.18		
South Well	STK1450793-2	ug/L				2014-10-20	4.94		
Fluoride		mg/L		2	1			0.1	0.1 - 0.1
North Well	STK2132249-1	mg/L				2021-02-16	0.1		
South Well	STK2132248-1	mg/L				2021-02-16	0.1		
Nitrate as N		mg/L		10	10			6.0	5.2 - 7.3
North Well	STK2156140-1	mg/L				2021-11-09	5.2		
North Well	STK2153318-1	mg/L				2021-09-16	5.22		
North Well	STK2137002-1	mg/L				2021-05-20	5.4		
North Well	STK2132249-1	mg/L				2021-02-16	5.7		
South Well	STK2156141-1	mg/L				2021-11-09	7.0		
South Well	STK2152071-1	mg/L				2021-08-24	7.3		
South Well	STK2137003-1	mg/L				2021-05-20	6.8		
South Well	STK2132248-1	mg/L				2021-02-16	5.7		
Nitrate + Nitrite as N		mg/L		10	10			5.7	5.7 - 5.7
North Well	STK2132249-1	mg/L				2021-02-16	5.7		
South Well	STK2132248-1	mg/L				2021-02-16	5.7		

Gross Alpha		pCi/L		15	(0)			8.31	6.51 - 10.1
North Well	STK2031186-1	pCi/L				2020-01-22	6.51		
South Well	STK2133724-1	pCi/L				2021-03-22	10.1		
Uranium		pCi/L		20	0.43			3.844	3.60 - 4.087
North Well	STK2031186-1	pCi/L				2020-01-22	4.087		
South Well	STK2133724-1	pCi/L				2021-03-22	3.60		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			12	12 - 12
North Well	STK2132249-1	mg/L				2021-02-16	12		
South Well	STK2132248-1	mg/L				2021-02-16	12		
Specific Conductance		umhos/cm		1600	n/a			526	521 - 530
North Well	STK2132249-1	umhos/cm				2021-02-16	521		
South Well	STK2132248-1	umhos/cm				2021-02-16	530		
Sulfate		mg/L		500	n/a			24.8	24.8 - 24.8
North Well	STK2132249-1	mg/L				2021-02-16	24.8		
South Well	STK2132248-1	mg/L				2021-02-16	24.8		
Total Dissolved Solids		mg/L		1000	n/a			355	350 - 360
North Well	STK2132249-1	mg/L				2021-02-16	350		
South Well	STK2132248-1	mg/L				2021-02-16	360		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ug/L		NS	n/a			24	24 - 24
North Well	STK2132249-1	ug/L				2021-02-16	24		
South Well	STK2132248-1	ug/L				2021-02-16	24		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			50	49 - 50
North Well	STK2132249-1	mg/L				2021-02-16	50		
South Well	STK2132248-1	mg/L				2021-02-16	49		
Magnesium		mg/L			n/a			24	24 - 24
North Well	STK2132249-1	mg/L				2021-02-16	24		
South Well	STK2132248-1	mg/L				2021-02-16	24		
pH		units			n/a			7.2	7.2 - 7.2
North Well	STK2132249-1	units				2021-02-16	7.2		
South Well	STK2132248-1	units				2021-02-16	7.2		
Alkalinity		mg/L			n/a			210	210 - 210
North Well	STK2132249-1	mg/L				2021-02-16	210		
South Well	STK2132248-1	mg/L				2021-02-16	210		
Aggressiveness Index					n/a			11.6	11.6 - 11.6
North Well	STK2132249-1					2021-02-16	11.6		
South Well	STK2132248-1					2021-02-16	11.6		
Langelier Index					n/a			-0.2	-0.2 - -0.2
North Well	STK2132249-1					2021-02-16	-0.2		
South Well	STK2132248-1					2021-02-16	-0.2		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chlorine		mg/L		4.0	4.0			0.00	ND -
NORTH WELL	STK2158308-3	mg/L				2021-12-23	ND		
Average NORTH WELL								0	
SOUTH WELL	STK2158308-4	mg/L				2021-12-23	ND		

Big Wheel Mobile Home Park CCR Login Linkage - 2021

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
North Well	STK1450793-1	2014-10-20	Wet Chemistry	North Well	Chrome 6 Monitoring
	STK2031186-1	2020-01-22	Metals, Total	North Well	North Well Radio Monitoring
	STK2031186-1	2020-01-22	Radio Chemistry	North Well	North Well Radio Monitoring
	STK2132249-1	2021-02-16	General Mineral	North Well	3 Year Monitoring-Well #1 (North Well)
	STK2132249-1	2021-02-16	Metals, Total	North Well	3 Year Monitoring-Well #1 (North Well)
	STK2137002-1	2021-05-20	Wet Chemistry	North Well	3 Year Monitoring-Well #1 (North Well)
	STK2153318-1	2021-09-16	Wet Chemistry	North Well	3 Year Monitoring-Well #1 (North Well)
	STK2156140-1	2021-11-09	Wet Chemistry	North Well	3 Year Monitoring-Well #1 (North Well)
	STK2158308-3	2021-12-23	Field Test	NORTH WELL	BIG WHEEL MOBILE HOME PARK
	Bacti-Rpt-ss01	STK2052194-4	2020-08-26	Coliform	North Well/Well #1
Bacti-Rout-Even	STK2158308-2	2021-12-23	Coliform	Site #12	Routine Bacteriological Monitoring-Even
Bacti-Rout-Odd	STK2130772-1	2021-01-18	Coliform	Site #63	Bacti Monitoring-Odd
	STK2132246-1	2021-02-16	Coliform	Site #63	Bacti Monitoring-Odd
	STK2133310-1	2021-03-10	Coliform	Site #63	Bacti Monitoring-Odd
	STK2135023-1	2021-04-15	Coliform	Site #63	Bacti Monitoring-Odd
	STK2137004-1	2021-05-20	Coliform	Site #63	Bacti Monitoring-Odd
	STK2138302-1	2021-06-14	Coliform	Site #63	Bacti Monitoring-Odd
	STK2150090-1	2021-07-19	Coliform	Site #63	Bacti Monitoring-Odd
	STK2152072-1	2021-08-24	Coliform	Site #63	Bacti Monitoring-Odd
	STK2153319-1	2021-09-16	Coliform	Site #63	Bacti Monitoring-Odd
	STK2154800-1	2021-10-14	Coliform	Site #63	Bacti Monitoring-Odd
	STK2156142-1	2021-11-09	Coliform	Site #63	Bacti Monitoring-Odd
	STK2158071-1	2021-12-21	Coliform	Site #63	Bacti Monitoring-Odd
	STK2158308-1	2021-12-23	Coliform	Site #63	Routine Bacteriological Monitoring-Odd
	South Well	STK1450793-2	2014-10-20	Wet Chemistry	South Well
STK2132248-1		2021-02-16	Metals, Total	South Well	3 Year Monitoring-Well #2 (South Well)
STK2132248-1		2021-02-16	General Mineral	South Well	3 Year Monitoring-Well #2 (South Well)
STK2133724-1		2021-03-22	Radio Chemistry	South Well	South Well Radio Monitoring
STK2133724-1		2021-03-22	Metals, Total	South Well	South Well Radio Monitoring
STK2137003-1		2021-05-20	Wet Chemistry	South Well	3 Year Monitoring-Well #2 (South Well)
STK2152071-1		2021-08-24	Wet Chemistry	South Well	3 Year Monitoring-Well #2 (South Well)
STK2156141-1		2021-11-09	Wet Chemistry	South Well	3 Year Monitoring-Well #2 (South Well)
STK2158308-4		2021-12-23	Field Test	SOUTH WELL	BIG WHEEL MOBILE HOME PARK
Bacti-Rpt-ss02		STK2052119-5	2020-08-24	Coliform	South Well/Well #2
SP. 12	STK2050352-2	2020-07-22	Coliform	Space #12	Bacti Monitoring
CA3900637_LCR	STK2138460-3	2021-06-16	Metals, Total	Space #14	Water Monitoring
	STK2138460-4	2021-06-16	Metals, Total	Space #15	Water Monitoring
	STK2138460-2	2021-06-16	Metals, Total	Space #50	Water Monitoring
	STK2138460-1	2021-06-16	Metals, Total	Space #61	BIG WHEEL MOBILE HOME PARK
	STK2138460-5	2021-06-16	Metals, Total	Space #63	Bacti Monitoring
Space 13	STK2154535-1	2021-10-08	Metals, Total	Space 13	Copper & Lead Monitoring
Space 14	STK2154535-2	2021-10-08	Metals, Total	Space 14	Copper & Lead Monitoring
Space 2	STK2154535-3	2021-10-08	Metals, Total	Space 2	Copper & Lead Monitoring
Space 50	STK2154535-4	2021-10-08	Metals, Total	Space 50	Copper & Lead Monitoring
Space 63	STK2154535-5	2021-10-08	Metals, Total	Space 63	Copper & Lead Monitoring