


# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>DELICATO VINEYARDS</b>
Water System Number:	<b>CA3900815</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Andrea Angela Vasquez	
	Signature:		
	Title:	Environmental Manager	
	Phone Number:	(209)824-3675	Date: 6/30/2023

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:  
Emailed directly to users and posted in public places for those without email.

- ☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> \_\_\_\_\_
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☒ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

# 2022 Consumer Confidence Report

Water System Name: DELICATO VINEYARDS

Report Date: March 2023

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 2 source(s):** Well #7 and Well #8

**Opportunities for public participation in decisions that affect drinking water quality:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

For more information about this report, or any questions relating to your drinking water, please call (209) 824-3675 and ask for Andrea Vasque .

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2021)	5	0.04	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Hardness (mg/L)	(2017)	93.7	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2022)	9	8 - 12	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2022)	ND	ND - 0.12	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits

Hexavalent Chromium (ug/L)	(2014)	2.43	ND - 4.86		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2022)	4	ND - 7.9	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2018)	3.19	1.56 - 4.82	15	(0)	Erosion of natural deposits.
1,2,3-Trichloropropane (1,2,3-TCP) (ug/L)	(2018)	ND	ND - 0.01	0.005	0.0007	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.

**Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Turbidity (NTU)	(2017)	0.3	n/a	5	n/a	Soil runoff

**Table 5 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (ug/L)	(2022)	14	ND - 28	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

**Table 6 - ADDITIONAL DETECTIONS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2017)	26	n/a	n/a	n/a
Magnesium (mg/L)	(2017)	7	n/a	n/a	n/a

**Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2022)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at

risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Delicato Vineyard-DW* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Arsenic				Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
1,2,3-Trichloropropane (1,2,3-TCP)				Some people who use water containing 1,2,3-trichloropropane in excess of the action level over many years may have an increased risk of getting cancer, based on studies in laboratory animals.

**About your Arsenic:** For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

## 2022 Consumer Confidence Report Drinking Water Assessment Information

### Assessment Information

A source water assessment was conducted for the WELL #7 of the DELICATO VINEYARDS water system in July, 2013. A source water assessment was conducted for the WELL #8 of the DELICATO VINEYARDS water system in October, 2013.

Well #7 - is considered most vulnerable to the following activities not associated with any detected contaminants:

Transportation corridors - Freeways/state highways

Wells - Water supply

Well #8 - is considered most vulnerable to the following activities not associated with any detected contaminants:

Transportation corridors - Freeways/state highways

Wells - Water supply

### **Discussion of Vulnerability**

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

### **Acquiring Information**

A copy of the complete assessment may be viewed at:

San Joaquin County

Environmental Health Department

1868 E. Hazelton Ave.

Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems

SJ Co Environmental Health Department

(209) 468-3420

# Delicato Vineyard-DW

## Analytical Results By FGL - 2022

### LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Copper</b>		mg/L		1.3	.3			0.035	5
Analytical Lab	STK2153191-3	mg/L				2021-09-16	ND		
Cellar Breakroom	STK2153191-2	mg/L				2021-09-16	ND		
Chard West Bathroom	STK2153191-4	mg/L				2021-09-16	ND		
Main Office Breakroom	STK2153191-5	mg/L				2021-09-16	ND		
Tasting Room Sink	STK2153191-1	mg/L				2021-09-16	0.07		

### SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Hardness</b>		mg/L		none	none			93.7	93.7 - 93.7
WELL #7	STK1737411-1	mg/L				2017-06-15	93.7		

### PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Arsenic</b>		ug/L		10	0.004			9	8 - 12
WELL #7	STK2239030-1	ug/L				2022-07-05	12		
WELL #8	STK2257120-1	ug/L				2022-12-06	8		
WELL #8	STK2255537-1	ug/L				2022-11-01	8		
WELL #8	STK2253973-1	ug/L				2022-10-04	8		
WELL #8	STK2252524-1	ug/L				2022-09-07	8		
WELL #8	STK2250617-1	ug/L				2022-08-02	11		
WELL #8	STK2239031-1	ug/L				2022-07-05	9		
WELL #8	STK2237741-1	ug/L				2022-06-07	9		
WELL #8	STK2235919-1	ug/L				2022-05-03	10		
WELL #8	STK2234388-1	ug/L				2022-04-05	9		
WELL #8	STK2232745-1	ug/L				2022-03-01	10		
WELL #8	STK2231396-1	ug/L				2022-02-01	9		
WELL #8	STK2230017-1	ug/L				2022-01-04	10		
<b>Barium</b>		mg/L	2	1	2			ND	ND - 0.12
WELL #7	STK2239030-1	mg/L				2022-07-05	0.12		
WELL #8	STK2250617-1	mg/L				2022-08-02	ND		
<b>Hexavalent Chromium</b>		ug/L			0.02			2.43	ND - 4.86
WELL #7	STK1439892-4	ug/L				2014-09-29	4.86		
WELL #8	STK1439892-5	ug/L				2014-09-29	ND		
<b>Nitrate as N</b>		mg/L		10	10			4.0	ND - 7.9
WELL #7	STK2239030-1	mg/L				2022-07-05	7.9		
WELL #8	STK2250617-1	mg/L				2022-08-02	ND		
<b>Gross Alpha</b>		pCi/L		15	(0)			3.19	1.56 - 4.82
WELL #7	STK1850416-1	pCi/L				2018-07-24	4.82		
WELL #8	STK1855346-1	pCi/L				2018-10-22	1.56		
<b>1,2,3-Trichloropropane (1,2,3-TCP)</b>		ug/L		0.005	0.0007			ND	ND - 0.01
WELL #7	STK1858100-1	ug/L				2018-12-20	0.007		
WELL #7	STK1853718-1	ug/L				2018-09-24	0.008		
WELL #7	STK1838877-1	ug/L				2018-06-26	0.006		
WELL #7	STK1833810-1	ug/L				2018-03-26	0.01		
WELL #8	STK1858102-1	ug/L				2018-12-20	ND		
WELL #8	STK1853719-1	ug/L				2018-09-24	ND		
WELL #8	STK1838940-1	ug/L				2018-06-26	ND		
WELL #8	STK1833811-1	ug/L				2018-03-26	ND		

### SECONDARY DRINKING WATER STANDARDS (SDWS)





# Delicato Vineyard-DW

## CCR Login Linkage - 2022

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Analytical Lab	STK2153191-3	2021-09-16	Metals, Total	Analytical Lab	Copper & Lead Monitoring
Bacti-Rout-02	STK2231397-1	2022-02-01	Coliform	Cellar Break Rm. w/s Test Port	Bacteriological Sampling - 2
	STK2234385-1	2022-04-05	Coliform	Cellar Break Rm. w/s Test Port	Bacteriological Sampling - 2
	STK2237813-1	2022-06-07	Coliform	Cellar Break Rm. w/s Test Port	Bacteriological Sampling - 2
	STK2250675-1	2022-08-02	Coliform	Cellar Break Rm. w/s Test Port	Bacteriological Sampling - 2
	STK2254039-1	2022-10-04	Coliform	Cellar Break Rm. w/s Test Port	Bacteriological Sampling - 2
	STK2257122-1	2022-12-06	Coliform	Cellar Break Rm. w/s Test Port	Bacteriological Sampling - 2
Cellar Breakroo	STK2153191-2	2021-09-16	Metals, Total	Cellar Breakroom	Copper & Lead Monitoring
Chard West Bath	STK2153191-4	2021-09-16	Metals, Total	Chard West Bathroom	Copper & Lead Monitoring
Main Office Bre	STK2153191-5	2021-09-16	Metals, Total	Main Office Breakroom	Copper & Lead Monitoring
Bacti-Rout-01	STK2230020-1	2022-01-04	Coliform	Main Office Taste Rm.	Bacteriological Sampling - 1
	STK2232839-1	2022-03-01	Coliform	Main Office Taste Rm.	Bacteriological Sampling - 1
	STK2235920-1	2022-05-03	Coliform	Main Office Taste Rm.	Bacteriological Sampling - 1
	STK2239033-1	2022-07-05	Coliform	Main Office Taste Rm.	Bacteriological Sampling - 1
	STK2252525-1	2022-09-07	Coliform	Main Office Taste Rm.	Bacteriological Sampling - 1
	STK2255538-1	2022-11-01	Coliform	Main Office Taste Rm.	Bacteriological Sampling - 1
Tasting Room Si	STK2153191-1	2021-09-16	Metals, Total	Tasting Room Sink	Copper & Lead Monitoring
Well #7	STK1439892-4	2014-09-29	Wet Chemistry	WELL #7	Chrome 6 Monitoring
WELL07	STK1630926-1	2016-01-27	Sampling	WELL #7	Well 7 - Water Quality
	STK1632119-1	2016-02-25	Coliform	WELL #7	Well 7 - Water Quality
	STK1632119-1	2016-02-25	Field Test	WELL #7	Well 7 - Water Quality
	STK1632119-1	2016-02-25	Sampling	WELL #7	Well 7 - Water Quality
	STK1633321-1	2016-03-31	Coliform	WELL #7	Well 7 - Water Quality
	STK1737411-1	2017-06-15	Metals, Total	WELL #7	DELICATO VINEYARDS
	STK1737411-1	2017-06-15	Wet Chemistry	WELL #7	DELICATO VINEYARDS
	STK1833810-1	2018-03-26	SRL 524M-TCP	WELL #7	Well 07 - TCP Monitoring
	STK1838877-1	2018-06-26	SRL 524M-TCP	WELL #7	Well 07 - TCP Monitoring
	STK1850416-1	2018-07-24	Radio Chemistry	WELL #7	Well 7 - Radio
	STK1853718-1	2018-09-24	SRL 524M-TCP	WELL #7	Well 07 - TCP Monitoring
	STK1858100-1	2018-12-20	SRL 524M-TCP	WELL #7	Well 07 - TCP Monitoring
	STK2230016-1	2022-01-04	Field Test	WELL #7	Well 7 - Water Quality
	STK2231395-1	2022-02-01	Field Test	WELL #7	Well 7 - Water Quality
	STK2232744-1	2022-03-01	Field Test	WELL #7	Well 7 - Water Quality
	STK2234386-1	2022-04-05	Field Test	WELL #7	Well 7 - Water Quality
	STK2235918-1	2022-05-03	Field Test	WELL #7	Well 7 - Water Quality
	STK2237740-1	2022-06-07	Field Test	WELL #7	Well 7 - Water Quality
	STK2239030-1	2022-07-05	Field Test	WELL #7	Well 7 - Water Quality
	STK2239030-1	2022-07-05	Wet Chemistry	WELL #7	Well 7 - Water Quality
	STK2239030-1	2022-07-05	Metals, Total	WELL #7	Well 7 - Water Quality
	STK2250616-1	2022-08-02	Field Test	WELL #7	Well 7 - Water Quality
	STK2252483-1	2022-09-07	Field Test	WELL #7	Well 7 - Water Quality
	STK2253972-1	2022-10-04	Field Test	WELL #7	Well 7 - Water Quality
	STK2255461-1	2022-11-01	Field Test	WELL #7	Well 7 - Water Quality
	STK2257119-1	2022-12-06	Field Test	WELL #7	Well 7 - Water Quality
Well #8	STK1439892-5	2014-09-29	Wet Chemistry	WELL #8	Chrome 6 Monitoring
WELL08	STK1632120-1	2016-02-25	Sampling	WELL #8	Well 8 - Water Quality
	STK1632120-1	2016-02-25	Coliform	WELL #8	Well 8 - Water Quality
	STK1833811-1	2018-03-26	SRL 524M-TCP	WELL #8	Well 08 - TCP Monitoring
	STK1838940-1	2018-06-26	SRL 524M-TCP	WELL #8	Well 08 - TCP Monitoring
	STK1853719-1	2018-09-24	SRL 524M-TCP	WELL #8	Well 08 - TCP Monitoring
	STK1855346-1	2018-10-22	Radio Chemistry	WELL #8	Well 8 - Radio
	STK1858102-1	2018-12-20	SRL 524M-TCP	WELL #8	Well 08 - TCP Monitoring
	STK2150791-1	2021-08-03		WELL #8	PFAS Monitoring
	STK2154138-1	2021-10-05		WELL #8	PFAS Monitoring
	STK2230019-1	2022-01-04	Field Test	WELL #8	Well 8 - Water Quality

	STK2230017-1	2022-01-04	Metals, Total	WELL #8	Non-Reportable Well 8 Arsenic
	STK2231396-1	2022-02-01	Field Test	WELL #8	Well 8 - Water Quality
	STK2231396-1	2022-02-01	Metals, Total	WELL #8	Well 8 - Water Quality
	STK2232838-1	2022-03-01	Field Test	WELL #8	Well 8 - Water Quality
	STK2232745-1	2022-03-01	Metals, Total	WELL #8	Non-Reportable Well 8 Arsenic
Well 8	STK2234388-1	2022-04-05	Metals, Total	WELL #8	Non-Reportable Well 8 Arsenic
WELL08	STK2234387-1	2022-04-05	Field Test	WELL #8	Well 8 - Water Quality
	STK2235919-1	2022-05-03	Metals, Total	WELL #8	Well 8 - Water Quality
	STK2235919-1	2022-05-03	Field Test	WELL #8	Well 8 - Water Quality
Well 8	STK2237741-1	2022-06-07	Metals, Total	WELL #8	Non-Reportable Well 8 Arsenic
WELL08	STK2237742-1	2022-06-07	Field Test	WELL #8	Well 8 - Water Quality
	STK2239032-1	2022-07-05	Field Test	WELL #8	Well 8 - Water Quality
	STK2239031-1	2022-07-05	Metals, Total	WELL #8	Non-Reportable Well 8 Arsenic
	STK2250617-1	2022-08-02	Field Test	WELL #8	Well 8 - Water Quality
	STK2250617-1	2022-08-02	Wet Chemistry	WELL #8	Well 8 - Water Quality
	STK2250617-1	2022-08-02	Metals, Total	WELL #8	Well 8 - Water Quality
Well 8	STK2252524-1	2022-09-07	Metals, Total	WELL #8	Non-Reportable Well 8 Arsenic
WELL08	STK2252484-1	2022-09-07	Field Test	WELL #8	Well 8 - Water Quality
	STK2254038-1	2022-10-04	Field Test	WELL #8	Well 8 - Water Quality
Well 8	STK2253973-1	2022-10-04	Metals, Total	WELL #8	Non-Reportable Well 8 Arsenic
WELL08	STK2255537-1	2022-11-01	Field Test	WELL #8	Well 8 - Water Quality
	STK2255537-1	2022-11-01	Metals, Total	WELL #8	Well 8 - Water Quality
	STK2257121-1	2022-12-06	Field Test	WELL #8	Well 8 - Water Quality
Well 8	STK2257120-1	2022-12-06	Metals, Total	WELL #8	Non-Reportable Well 8 Arsenic