

2025 Consumer Confidence Report

Water System Name: LODI USD-TURNER ACADEMY AT TOKAY COLONY Report Date: June 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Ground water is sourced from the unadjudicated Eastern San Joaquin Valley Sub basin (NO. 5-022.01). Well No. 3901085-001 is located on the North side of parcel APN#: 085-17-020.

Your water comes from 1 source(s): Wellhead

Opportunities for public participation in decisions that affect drinking water quality: Please call Maintenance & Operations if you have questions regarding the water.

For more information about this report, or any questions relating to your drinking water, please call (209) 331-7181 and ask for LodiUSD M&O or visit our website at www.lodiUSD.net.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3 and 4 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER								
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	Range	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2025)	5	0	0	ND - 1	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2025)	5	0.03	0	0.00 - 0.05	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2021 - 2024)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Chromium (ug/L)	(2024)	21	n/a	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Hexavalent Chromium (ug/L)	(2025)	4.3	n/a	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2023 - 2025)	1.3	1.1 - 1.3	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2024)	5	n/a	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)

Table 4 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ug/L)	(2021 - 2024)	12	8 - 15	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 5 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine, Total (mg/L)	(2023)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Lodi Unified School District* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for

30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2025 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL of the LODI USD-TOKAY COLONY SCHOOL of the water system in October, 2002.

Wellhead - is considered most vulnerable to the following activities not associated with any detected contaminants:
Housing - high density [>1 house/0.5 acres]

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

A copy of the complete assessment may be viewed at:

San Joaquin County
Environmental Health Department
1868 E Hazelton Ave,
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems
SJ Co Environmental Health Department
(209) 468-3420

Lodi Unified School District

Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
TCS-Bldg.A EastSide by DF	STK2558790-1					2025-12-15	Absent		
TCS-Bldg.A EastSide by DF	STK2555849-1					2025-10-15	Absent		
TCS-Bldg.A EastSide by DF	STK2552459-1					2025-08-20	Absent		
TCS-Bldg.A EastSide by DF	STK2538928-1					2025-06-18	Absent		
TCS-Bldg.A EastSide by DF	STK2535312-1					2025-04-17	Absent		
TCS-Bldg.A EastSide by DF	STK2532552-1					2025-02-21	Absent		
TCS-Bldg.B EastSide by DF	STK2557782-1					2025-11-19	Absent		
TCS-Bldg.B EastSide by DF	STK2554098-1					2025-09-17	Absent		
TCS-Bldg.B EastSide by DF	STK2550223-1					2025-07-16	Absent		
TCS-Bldg.B EastSide by DF	STK2537272-1					2025-05-22	Absent		
TCS-Bldg.B EastSide by DF	STK2533876-1					2025-03-19	Absent		
TCS-Bldg.B EastSide by DF	STK2531090-1					2025-01-24	Absent		
Fecal coliform and E. coli				0	n/a			ND	-
TCS-Bldg.A EastSide by DF	STK2558790-1					2025-12-15	Absent		
TCS-Bldg.A EastSide by DF	STK2555849-1					2025-10-15	Absent		
TCS-Bldg.A EastSide by DF	STK2552459-1					2025-08-20	Absent		
TCS-Bldg.A EastSide by DF	STK2538928-1					2025-06-18	Absent		
TCS-Bldg.A EastSide by DF	STK2535312-1					2025-04-17	Absent		
TCS-Bldg.A EastSide by DF	STK2532552-1					2025-02-21	Absent		
TCS-Bldg.B EastSide by DF	STK2557782-1					2025-11-19	Absent		
TCS-Bldg.B EastSide by DF	STK2554098-1					2025-09-17	Absent		
TCS-Bldg.B EastSide by DF	STK2550223-1					2025-07-16	Absent		
TCS-Bldg.B EastSide by DF	STK2537272-1					2025-05-22	Absent		
TCS-Bldg.B EastSide by DF	STK2533876-1					2025-03-19	Absent		
TCS-Bldg.B EastSide by DF	STK2531090-1					2025-01-24	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
TCS-D/F by Rms. 01 & 02	STK2539868-1	ug/L				2025-06-25	ND		
TCS-D/F East Between Restrooms	STK2539868-3	ug/L				2025-06-25	ND		
TCS-Room 02	STK2539868-2	ug/L				2025-06-25	ND		
TCS-Room 04	STK2539868-5	ug/L				2025-06-25	ND		
TCS-Teachers Room	STK2539868-4	ug/L				2025-06-25	ND		
Copper		mg/L		1.3	.3			0.027	5
TCS-D/F by Rms. 01 & 02	STK2539868-1	mg/L				2025-06-25	ND		
TCS-D/F East Between Restrooms	STK2539868-3	mg/L				2025-06-25	0.05		
TCS-Room 02	STK2539868-2	mg/L				2025-06-25	ND		
TCS-Room 04	STK2539868-5	mg/L				2025-06-25	ND		
TCS-Teachers Room	STK2539868-4	mg/L				2025-06-25	ND		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			2	2 - 2
Wellhead	STK2433641-1	ug/L				2024-03-14	2		
WELLHEAD	STK2133681-1	ug/L				2021-03-18	2		
Chromium		ug/L	100	50.0	n/a			21	21 - 21
Wellhead	STK2433641-1	ug/L				2024-03-14	21		
Hexavalent Chromium		ug/L		10	0.02			4.3	4.3 - 4.3

Lodi Unified School District

CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
TCS-Even	STK1631777-1	2016-02-16	Coliform	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
	STK1631777-1	2016-02-16	Sampling	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
	STK1633960-1	2016-04-12	Sampling	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
	STK2532552-1	2025-02-21	Coliform	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
	STK2535312-1	2025-04-17	Coliform	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
	STK2538928-1	2025-06-18	Coliform	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
	STK2552459-1	2025-08-20	Coliform	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
	STK2555849-1	2025-10-15	Coliform	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
	STK2558790-1	2025-12-15	Coliform	TCS-Bldg.A EastSide by DF	Tokay Colony School - Bacteriological-Even
TCS-Odd	STK1530360-1	2015-01-08	Sampling	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK1630135-1	2016-01-05	Sampling	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK1630135-1	2016-01-05	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK1632565-1	2016-03-08	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK1632565-1	2016-03-08	Sampling	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK1635337-1	2016-05-05	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK1730211-1	2017-01-05	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK1730211-1	2017-01-05	Sampling	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK2531090-1	2025-01-24	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK2533876-1	2025-03-19	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK2537272-1	2025-05-22	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK2550223-1	2025-07-16	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK2554098-1	2025-09-17	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
	STK2557782-1	2025-11-19	Coliform	TCS-Bldg.B EastSide by DF	Tokay Colony School - Bacteriological-Odd
CA3900848_LCR	STK2539868-1	2025-06-25	Metals, Total	TCS-D/F by Rms. 01 & 02	Tokay Colony - Copper & Lead Monitoring
	STK2539868-3	2025-06-25	Metals, Total	TCS-D/F East Between Restrooms	Tokay Colony - Copper & Lead Monitoring
	STK2539868-2	2025-06-25	Metals, Total	TCS-Room 02	Tokay Colony - Copper & Lead Monitoring
	STK2539868-5	2025-06-25	Metals, Total	TCS-Room 04	Tokay Colony - Copper & Lead Monitoring
	STK2539868-4	2025-06-25	Metals, Total	TCS-Teachers Room	Tokay Colony - Copper & Lead Monitoring
1TCS-Wellhead	STK1632563-1	2016-03-08	Sampling	WELLHEAD	Tokay Colony School - Radio Monitoring
	STK1632564-1	2016-03-08	Wet Chemistry	WELLHEAD	Tokay Colony School-3 Year
	STK1632564-1	2016-03-08	Sampling	WELLHEAD	Tokay Colony School-3 Year
	STK1632563-1	2016-03-08	Radio Chemistry	WELLHEAD	Tokay Colony School - Radio Monitoring
	STK2133681-1	2021-03-18	Metals, Total	WELLHEAD	Tokay Colony School-3 Year
	STK2333053-1	2023-03-09	Wet Chemistry	WELLHEAD	Tokay Colony School-3 Year

	STK2355994-3	2023-11-20	Field Test	WELLHEAD	LODI USD-TOKAY COLONY SCHOOL
	STK2433641-1	2024-03-14	Metals, Total	Wellhead	Tokay Colony School-3 Year
	STK2533874-1	2025-03-19	Wet Chemistry	Wellhead	Tokay Colony School-3 Year
	STK2533873-1	2025-03-19	Wet Chemistry	WELLHEAD	Tokay Colony - Chromium VI