

## APPENDIX B: eCCR Certification Form (Suggested Format)


### Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	Cherry Lane Trailer Park
Water System Number:	3900983

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 07-24-2023 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: Marty Bolter	Title: Water Tech
Signature: 	Date: 07-24-2023
Phone number: (209) 479-6801	

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
  - ☐ Posting the CCR at the following URL: www.
  - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
  - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - ☒ Posted the CCR in public places (In front of the Mail Box)

# 2022 Consumer Confidence Report

Water System Name: Cherry Lane Trailer Park

Report Date: June 2023

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** This info is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

**Your water comes from 2 source(s):** WELL #2 and WELL #3

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call 209-406-6069 and ask for Sam Hedge or email [samhedge@caldsl.net](mailto:samhedge@caldsl.net).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022)	15	11 - 19	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	110	68.7 - 151	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2022)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2022)	ND	ND - 0.11	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Hexavalent Chromium (ug/L)	(2014)	5.7	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Fluoride (mg/L)	(2022)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.



Nitrate as N (mg/L)	(2022)	2.1	ND - 4.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2022)	2.1	ND - 4.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
1,2,3-Trichloropropane (1,2,3-TCP) (ug/L)	(2022)	0.02	ND - 0.068	0.005	0.0007	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.

**Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2022)	28	5 - 50	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2022)	377	219 - 535	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022)	7.1	3.8 - 10.3	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022)	255	170 - 340	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2022)	0.3	0.1 - 0.4	5	n/a	Soil runoff
Zinc (mg/L)	(2022)	ND	ND - 0.05	5	n/a	Runoff/leaching from natural deposits

**Table 4 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (ug/L)	(2022)	12	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

**Table 5 - ADDITIONAL DETECTIONS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022)	25	16 - 34	n/a	n/a
Magnesium (mg/L)	(2022)	12	7 - 16	n/a	n/a
pH (units)	(2022)	7.63	7.05 - 8.2	n/a	n/a
Alkalinity (mg/L)	(2022)	125	90 - 160	n/a	n/a
Aggressiveness Index	(2022)	11.5	10.6 - 12.3	n/a	n/a
Langelier Index	(2022)	-0.4	-1.2 - 0.5	n/a	n/a

**Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2022)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Cherry Lane Trailer Park* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

### Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
1,2,3-Trichloropropane (1,2,3-TCP)				Some people who use water containing 1,2,3-trichloropropane in excess of the action level over many years may have an increased risk of getting cancer, based on studies in laboratory animals.

### 2022 Consumer Confidence Report Drinking Water Assessment Information

#### Assessment Information

A Source Water Assessment has not been completed for the source WELL #2 of the CHERRY LANE TRAILER PARK water system.

WELL #2 - does not have a completed assessment on file.

WELL #3 - does not have a completed assessment on file.

#### Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

☐ The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.

☐ The source is not active. It may be out of service, or new and not yet in service.

☐ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

### **Acquiring Information**

For more info you may visit [https://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/DWSAP.html](https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html) or contact the health department in the county to which the water system belongs as indicated on this following link: [https://www.waterboards.ca.gov/drinking\\_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf](https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf)

# Cherry Lane Trailer Park

## Analytical Results By FGL - 2022

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			15	11 - 19
WELL #2	STK2255031-1	mg/L				2022-10-24	19		
WELL #3	STK2252013-1	mg/L				2022-08-25	11		
Hardness		mg/L		none	none			109.9	68.7 - 151
WELL #2	STK2255031-1	mg/L				2022-10-24	151		
WELL #3	STK2252013-1	mg/L				2022-08-25	68.7		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			2	2 - 2
WELL #2	STK2255031-1	ug/L				2022-10-24	2		
WELL #3	STK2252013-1	ug/L				2022-08-25	2		
Barium		mg/L	2	1	2			ND	ND - 0.11
WELL #2	STK2255031-1	mg/L				2022-10-24	0.11		
WELL #3	STK2252013-1	mg/L				2022-08-25	ND		
Hexavalent Chromium		ug/L			0.02			5.70	5.70 - 5.70
WELL #2	STK1439680-1	ug/L				2014-09-23	5.70		
Fluoride		mg/L		2	1			0.1	0.1 - 0.1
WELL #2	STK2255031-1	mg/L				2022-10-24	0.1		
WELL #3	STK2252013-1	mg/L				2022-08-25	0.1		
Nitrate as N		mg/L		10	10			2.1	ND - 4.2
WELL #2	STK2255031-1	mg/L				2022-10-24	4.2		
WELL #3	STK2252013-1	mg/L				2022-08-25	ND		
Nitrate + Nitrite as N		mg/L		10	10			2.1	ND - 4.2
WELL #2	STK2255031-1	mg/L				2022-10-24	4.2		
WELL #3	STK2252013-1	mg/L				2022-08-25	ND		
1,2,3-Trichloropropane (1,2,3-TCP)		ug/L		0.005	0.0007			0.020	ND - 0.068
WELL #2	STK2256716-1	ug/L				2022-11-22	0.014		
WELL #2	STK2252014-1	ug/L				2022-08-25	0.068		
WELL #2	STK2236663-1	ug/L				2022-05-11	0.026		
WELL #2	STK2231807-1	ug/L				2022-02-07	0.010		
WELL #3	STK2256715-1	ug/L				2022-11-22	ND		
WELL #3	STK2252013-1	ug/L				2022-08-25	ND		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			28	5 - 50
WELL #2	STK2255031-1	mg/L				2022-10-24	50		
WELL #3	STK2252013-1	mg/L				2022-08-25	5		
Specific Conductance		umhos/cm		1600	n/a			377	219 - 535
WELL #2	STK2255031-1	umhos/cm				2022-10-24	535		
WELL #3	STK2252013-1	umhos/cm				2022-08-25	219		
Sulfate		mg/L		500	n/a			7.1	3.8 - 10.3
WELL #2	STK2255031-1	mg/L				2022-10-24	10.3		
WELL #3	STK2252013-1	mg/L				2022-08-25	3.8		
Total Dissolved Solids		mg/L		1000	n/a			255	170 - 340
WELL #2	STK2255031-1	mg/L				2022-10-24	340		
WELL #3	STK2252013-1	mg/L				2022-08-25	170		
Turbidity		NTU		5	n/a			0.3	0.1 - 0.4
WELL #2	STK2255031-1	NTU				2022-10-24	0.1		
WELL #3	STK2252013-1	NTU				2022-08-25	0.4		





# Cherry Lane Trailer Park

## CCR Login Linkage - 2022

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Rout-Even	STK2231806-1	2022-02-07	Coliform	Space #45	Bacteriological Monitoring - Even
	STK2234571-1	2022-04-06	Coliform	Space #45	Bacteriological Monitoring - Even
	STK2237553-1	2022-06-01	Coliform	Space #45	Bacteriological Monitoring - Even
	STK2252015-1	2022-08-25	Coliform	Space #45	Bacteriological Monitoring - Even
	STK2255032-1	2022-10-24	Coliform	Space #45	Bacteriological Monitoring - Even
	STK2257748-1	2022-12-15	Coliform	Space #45	Bacteriological Monitoring - Even
Bacti-Rout-Odd	STK2230390-1	2022-01-10	Coliform	Store Sink	Bacteriological Monitoring - Odd
	STK2233508-1	2022-03-15	Coliform	Store Sink	Bacteriological Monitoring - Odd
	STK2236465-1	2022-05-09	Coliform	Store Sink	Bacteriological Monitoring - Odd
	STK2250500-1	2022-07-28	Coliform	Store Sink	Bacteriological Monitoring - Odd
	STK2252601-1	2022-09-07	Coliform	Store Sink	Bacteriological Monitoring - Odd
	STK2256713-1	2022-11-22	Coliform	Store Sink	Bacteriological Monitoring - Odd
Well #2	STK1439680-1	2014-09-23	Wet Chemistry	WELL #2	Chrome 6 Monitoring
WELL02	STK2231807-1	2022-02-07	SRL 524M-TCP	WELL #2	TCP Monitoring
	STK2236663-1	2022-05-11	SRL 524M-TCP	WELL #2	TCP Monitoring
	STK2252014-1	2022-08-25	SRL 524M-TCP	WELL #2	TCP Monitoring
	STK2255031-1	2022-10-24	Wet Chemistry	WELL #2	Well #2 - Water Quality Monitoring
	STK2255031-1	2022-10-24	Metals, Total	WELL #2	Well #2 - Water Quality Monitoring
	STK2255031-1	2022-10-24	General Mineral	WELL #2	Well #2 - Water Quality Monitoring
	STK2256716-1	2022-11-22	SRL 524M-TCP	WELL #2	TCP Monitoring
WELL#3	STK2252013-1	2022-08-25	SRL 524M-TCP	WELL #3	CHERRY LANE TRAILER PARK
	STK2252013-1	2022-08-25	Metals, Total	WELL #3	CHERRY LANE TRAILER PARK
	STK2252013-1	2022-08-25	Wet Chemistry	WELL #3	CHERRY LANE TRAILER PARK
	STK2252013-1	2022-08-25	Field Test	WELL #3	CHERRY LANE TRAILER PARK
	STK2252013-1	2022-08-25	General Mineral	WELL #3	CHERRY LANE TRAILER PARK
	STK2255491-1	2022-10-27	Field Test	WELL #3	CHERRY LANE TRAILER PARK
	STK2255743-1	2022-11-02	Field Test	WELL #3	CHERRY LANE TRAILER PARK
	STK2256248-1	2022-11-10	Field Test	WELL #3	CHERRY LANE TRAILER PARK
	STK2256715-1	2022-11-22	SRL 524M-TCP	WELL #3	Well #3 - TCP Monitoring