

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	MUSD-NEW HAVEN SCHOOL
Water System Number:	CA3901163

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	()	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> _____
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2025 Consumer Confidence Report

Water System Name: MUSD-NEW HAVEN SCHOOL

Report Date: June 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use:

Your water comes from 1 source(s): WELL

For more information about this report, or any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service, Inc..

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1 and 2 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	Range	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2024)	5	4	0	ND - 8	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2024)	5	0.38	0	0.02 - 0.41	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2025)	5	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2025)	0.13	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (ug/L)	(2025)	12	n/a	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (mg/L)	(2025)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Hexavalent Chromium (ug/L)	(2025)	4.5	n/a	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2025)	14	12.6 - 15.6	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2022)	9.1	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Uranium (pCi/L)	(2022)	5.3	n/a	20	0.43	Erosion of natural deposits

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *MUSD-New Haven School* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT

Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Nitrate as N	The water system has elevated levels of nitrate. The system has been monitoring nitrate levels and received a compliance order for its exceedance. Compliance Order No. 03_69_25R_003 was received July 2025.	2024 – current	The system provides bulk water to staff and students. Testing occurs quarterly, along with a monthly notification of nitrate concentrations in the system. The system is working with the county and state to adopt a plan to return to compliance with the nitrate MCL.	Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of Pregnant women.

About your Arsenic: For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

About your Nitrate as N: Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

2025 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment (DWSAP) has not been completed for the WELL of the MUSD- NEW HAVEN SCHOOL water system.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- ☐ The Assessment has not been completed. Contact the local DDW district office or the water system to find out when the Assessment is scheduled to be done.
- ☐ The source is not active. It may be out of service, or new and not yet in service.
- ☐ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

A copy of the assessment may be viewed at:

San Joaquin County Environmental Health Department
1868 E Hazelton Ave
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems
San Joaquin County Environmental Health Department
209-468-3420

MUSD-New Haven School

Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
Kitchen HB	STK2557194-1					2025-11-06	Absent		
Kitchen HB	STK2553367-1					2025-09-03	Absent		
Kitchen HB	STK2539960-1					2025-07-08	Absent		
Kitchen HB	STK2537017-1					2025-05-14	Absent		
Kitchen HB	STK2534171-1					2025-03-24	Absent		
Kitchen HB	STK2531150-1					2025-01-23	Absent		
Library HB	STK2558414-1					2025-12-03	Absent		
Library HB	STK2556496-1					2025-10-23	Absent		
Library HB	STK2551975-1					2025-08-12	Absent		
Library HB	STK2538817-1					2025-06-16	Absent		
Library HB	STK2535253-1					2025-04-14	Absent		
Library HB	STK2532567-1					2025-02-19	Absent		
Middle Bulk Tank	STK2558414-4					2025-12-03	Absent		
Middle Bulk Tank	STK2557194-4					2025-11-06	Absent		
Middle Tank	STK2556500-3					2025-10-23	Absent		
South End Bulk Tank	STK2558414-3					2025-12-03	Absent		
South End Bulk Tank	STK2557194-3					2025-11-06	Absent		
South End Tank	STK2556500-2					2025-10-23	Absent		
Teacher's Lounge	STK2556500-1					2025-10-23	Absent		
Teachers Lounge Bulk Tank	STK2558414-2					2025-12-03	Absent		
Teachers Lounge Bulk Tank	STK2557194-2					2025-11-06	Absent		
Fecal coliform and E. coli				0	n/a			ND	-
Kitchen HB	STK2557194-1					2025-11-06	Absent		
Kitchen HB	STK2553367-1					2025-09-03	Absent		
Kitchen HB	STK2539960-1					2025-07-08	Absent		
Kitchen HB	STK2537017-1					2025-05-14	Absent		
Kitchen HB	STK2534171-1					2025-03-24	Absent		
Kitchen HB	STK2531150-1					2025-01-23	Absent		
Library HB	STK2558414-1					2025-12-03	Absent		
Library HB	STK2556496-1					2025-10-23	Absent		
Library HB	STK2551975-1					2025-08-12	Absent		
Library HB	STK2538817-1					2025-06-16	Absent		
Library HB	STK2535253-1					2025-04-14	Absent		
Library HB	STK2532567-1					2025-02-19	Absent		
Middle Bulk Tank	STK2558414-4					2025-12-03	Absent		
Middle Bulk Tank	STK2557194-4					2025-11-06	Absent		
Middle Tank	STK2556500-3					2025-10-23	Absent		
South End Bulk Tank	STK2558414-3					2025-12-03	Absent		
South End Bulk Tank	STK2557194-3					2025-11-06	Absent		
South End Tank	STK2556500-2					2025-10-23	Absent		
Teacher's Lounge	STK2556500-1					2025-10-23	Absent		
Teachers Lounge Bulk Tank	STK2558414-2					2025-12-03	Absent		
Teachers Lounge Bulk Tank	STK2557194-2					2025-11-06	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			4	5
Kitchen	STK2453313-5	ug/L				2024-09-03	ND		
Library	STK2453313-1	ug/L				2024-09-03	8		
Room #1	STK2453313-4	ug/L				2024-09-03	ND		
Staff Men's Room	STK2453313-2	ug/L				2024-09-03	ND		
Staff Woman's Room	STK2453313-3	ug/L				2024-09-03	ND		

Copper		mg/L		1.3	.3			0.375	5
Kitchen	STK2453313-5	mg/L				2024-09-03	ND		
Library	STK2453313-1	mg/L				2024-09-03	0.18		
Room #1	STK2453313-4	mg/L				2024-09-03	ND		
Staff Men's Room	STK2453313-2	mg/L				2024-09-03	0.34		
Staff Woman's Room	STK2453313-3	mg/L				2024-09-03	0.41		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg-Result(a)	Range (b)
Arsenic		ug/L		10	0.004			5	5 - 5
WELL	STK2557197-1	ug/L				2025-11-06	5		
Barium		mg/L	2	1	2			0.13	0.13 - 0.13
WELL	STK2557197-1	mg/L				2025-11-06	0.13		
Chromium		ug/L	100	50.0	n/a			12	12 - 12
WELL	STK2557197-1	ug/L				2025-11-06	12		
Fluoride		mg/L		2	1			0.1	0.1 - 0.1
WELL	STK2557195-1	mg/L				2025-11-06	0.1		
Hexavalent Chromium		ug/L		10	0.02			4.5	4.5 - 4.5
WELL	STK2534393-1	ug/L				2025-03-27	4.5		
Nitrate as N		mg/L		10	10			14.0	12.6 - 15.6
WELL	STK2557195-1	mg/L				2025-11-06	14.9		
WELL	STK2551976-1	mg/L				2025-08-12	15.6		
WELL	STK2537015-1	mg/L				2025-05-14	12.9		
WELL	STK2532568-1	mg/L				2025-02-19	12.6		
Nitrate + Nitrite as N		mg/L		10	10			9.1	9.1 - 9.1
WELL	STK2357760-22	mg/L				2022-05-18	9.1		
Uranium		pCi/L		20	0.43			5.3	5.3 - 5.3
WELL	STK2357760-15	pCi/L				2022-12-07	5.3		
WELL	STK2357760-15	pCi/L				2022-12-07	5.3		
WELL	STK2357760-15	pCi/L				2022-12-07	5.3		
WELL	STK2357760-15	pCi/L				2022-12-07	5.3		
WELL	STK2357760-15	pCi/L				2022-12-07	5.3		

MUSD-New Haven School

CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
DST_LCR	STK2453313-5	2024-09-03	Metals, Total	Kitchen	Lead and Copper Monitoring
ROU1	STK2531150-1	2025-01-23	Coliform	Kitchen HB	Bacteriological Monitoring - Odd
	STK2534171-1	2025-03-24	Coliform	Kitchen HB	Bacteriological Monitoring - Odd
	STK2537017-1	2025-05-14	Coliform	Kitchen HB	Bacteriological Monitoring - Odd
	STK2539960-1	2025-07-08	Coliform	Kitchen HB	Bacteriological Monitoring - Odd
	STK2553367-1	2025-09-03	Coliform	Kitchen HB	Bacteriological Monitoring - Odd
ROU1-1	STK2557194-1	2025-11-06	Coliform	Kitchen HB	Bacteriological Monitoring - Odd
DST_LCR	STK2453313-1	2024-09-03	Metals, Total	Library	Lead and Copper Monitoring
ROU2	STK2532567-1	2025-02-19	Coliform	Library HB	Bacteriological Monitoring - Even
	STK2535253-1	2025-04-14	Coliform	Library HB	Bacteriological Monitoring - Even
	STK2538817-1	2025-06-16	Coliform	Library HB	Bacteriological Monitoring - Even
	STK2551975-1	2025-08-12	Coliform	Library HB	Bacteriological Monitoring - Even
	STK2556496-1	2025-10-23	Coliform	Library HB	Bacteriological - Even
ROU2-1	STK2558414-1	2025-12-03	Coliform	Library HB	Bacteriological Monitoring - Even
ROU1-4	STK2557194-4	2025-11-06	Coliform	Middle Bulk Tank	Bacteriological Monitoring - Odd
ROU2-4	STK2558414-4	2025-12-03	Coliform	Middle Bulk Tank	Bacteriological Monitoring - Even
Middle Tank	STK2556500-3	2025-10-23	Coliform	Middle Tank	Bacteriological Sampling
DST_LCR	STK2453313-4	2024-09-03	Metals, Total	Room #1	Lead and Copper Monitoring
ROU1-3	STK2557194-3	2025-11-06	Coliform	South End Bulk Tank	Bacteriological Monitoring - Odd
ROU2-3	STK2558414-3	2025-12-03	Coliform	South End Bulk Tank	Bacteriological Monitoring - Even
South End Tank	STK2556500-2	2025-10-23	Coliform	South End Tank	Bacteriological Sampling
DST_LCR	STK2453313-2	2024-09-03	Metals, Total	Staff Men's Room	Lead and Copper Monitoring
	STK2453313-3	2024-09-03	Metals, Total	Staff Woman's Room	Lead and Copper Monitoring
Teacher's Loung	STK2556500-1	2025-10-23	Coliform	Teacher's Lounge	Bacteriological Sampling
ROU1-2	STK2557194-2	2025-11-06	Coliform	Teachers Lounge Bulk Tank	Bacteriological Monitoring - Odd
ROU2-2	STK2558414-2	2025-12-03	Coliform	Teachers Lounge Bulk Tank	Bacteriological Monitoring - Even
WELL	STK2357760-22	2022-05-18		WELL	CCR 2023
	STK2357760-15	2022-12-07		WELL	CCR 2023
	STK2532568-1	2025-02-19	Wet Chemistry	WELL	Water Quality Monitoring
	STK2534393-1	2025-03-27	Wet Chemistry	WELL	Chromium VI Monitoring
	STK2537015-1	2025-05-14	Wet Chemistry	WELL	Water Quality Monitoring
	STK2551976-1	2025-08-12	Wet Chemistry	WELL	Water Quality Monitoring
	STK2557197-1	2025-11-06	Metals, Total	WELL	IOC Metals Monitoring
	STK2557195-1	2025-11-06	Wet Chemistry	WELL	Water Quality Monitoring