

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name: **HAYNES BOARD & CARE HOME**

Water System Number: **3901217**

The water system above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:    Name \_\_\_\_\_  
                         Signature \_\_\_\_\_  
                         Title \_\_\_\_\_  
                         Phone Number (     ) \_\_\_\_\_ Date \_\_\_\_\_

---

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

\_\_\_\_\_ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

\_\_\_\_\_ Posted the CCR on the internet at http:// \_\_\_\_\_

\_\_\_\_\_ Mailed the CCR to postal patrons within the service area (attach zip codes used)

\_\_\_\_\_ Advertised the availability of the CCR in news media (attach a copy of press release)

\_\_\_\_\_ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

\_\_\_\_\_ Posted the CCR in public places (attach a list of locations)

\_\_\_\_\_ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

\_\_\_\_\_ Delivery to community organizations (attach a list of organizations)

\_\_\_\_\_ Other (attach a list of other methods used)

\_\_\_\_\_ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// \_\_\_\_\_

\_\_\_\_\_ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

# 2019 Consumer Confidence Report

Water System Name: HAYNES BOARD & CARE HOME

Report Date: March 2020

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** WELL HEAD

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service Inc..

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

<b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA</b>					
<b>Microbiological Contaminants</b> (complete if bacteria detected)	<b>Highest No. of Detections</b>	<b>No. of Months in Violation</b>	<b>MCL</b>	<b>MCLG</b>	<b>Typical Sources of Contaminant</b>
Total Coliform Bacteria	1/mo. (2019)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	5 (2017)	0.07	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

<b>Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Sodium (mg/L)	(2017)	27	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2017)	48	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

<b>Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>
Arsenic (ug/L)	(2017)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Hexavalent Chromium (ug/L)	(2014)	6.1	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Fluoride (mg/L)	(2017)	0.2	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2019)	2.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2017)	2.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

<b>Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Chloride (mg/L)	(2017)	23	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2017)	227	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2017)	1.6	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2017)	200	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2017)	0.2	n/a	5	n/a	Soil runoff

<b>Table 6 - ADDITIONAL DETECTIONS</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Typical Sources of Contaminant</b>	
Calcium (mg/L)	(2017)	11	n/a	n/a	n/a	
Magnesium (mg/L)	(2017)	5	n/a	n/a	n/a	
pH (units)	(2017)	7	n/a	n/a	n/a	
Alkalinity (mg/L)	(2017)	60	n/a	n/a	n/a	
Aggressiveness Index	(2017)	10.2	n/a	n/a	n/a	
Langelier Index	(2017)	-1.6	n/a	n/a	n/a	

<b>Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE</b>							
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL (MRDL)</b>	<b>PHG (MCLG)</b>	<b>Violation</b>	<b>Typical Sources of Contaminant</b>
Chlorine (mg/L)	(2019)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

## **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/ Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Haynes Board & Care Home* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## **2019 Consumer Confidence Report**

### **Drinking Water Assessment Information**

#### **Assessment Information**

A source water assessment was conducted for the WELL HEAD of the HAYNES BOARD & CARE HOME water system in April, 2002.

WELL HEAD - is considered most vulnerable to the following activities not associated with any detected contaminants:

- Animal Feeding Operations as defined in federal regulation 2
- Concentrated Animal Feeding Operations [CAFOs] as defined in
- Septic systems - high density [ $>1/\text{acre}$ ]
- Chemical/petroleum processing/storage
- Historic gas stations
- Historic waste dumps/landfills
- Injection wells/dry wells/ sumps
- Known Contaminant Plumes
- Landfills/dumps
- Metal plating/ finishing/fabricating
- Mining operations - Historic
- Underground Injection of Commercial/Industrial Discharges
- Underground storage tanks - Confirmed leaking tanks

#### **Discussion of Vulnerability**

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

#### **Acquiring Information**

A copy of the complete assessment may be viewed at:

San Joaquin County  
Environmental Health Department  
304 E. Weber Ave, 3rd Floor  
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems  
SJ Co Environmental Health Department  
(209) 468-3420

# Haynes Board & Care Home

## Analytical Results By FGL - 2019

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
After Pressure Tank	STK1958323-4					2019-12-17	<1.0		
After PT	STK1957320-3					2019-11-22	<1.0		
Laundry Room	STK1958323-3					2019-12-17	<1.0		
Laundry Room	STK1957320-1					2019-11-22	<1.0		
Laundry Room Tap	STK1957223-1					2019-11-20	Present		
Laundry Room Tap	STK1953951-1					2019-09-17	Absent		
Laundry Room Tap	STK1950400-1					2019-07-16	Absent		
Laundry Room Tap	STK1937204-1					2019-05-21	Absent		
Laundry Room Tap	STK1933734-1					2019-03-19	Absent		
Laundry Room Tap	STK1931231-1					2019-01-24	Absent		
S.E. Side of Building	STK1957320-2					2019-11-22	<1.0		
South East Corner Main Bldg	STK1958323-1					2019-12-17	<1.0		
South East Corner Main Bldg	STK1958323-2					2019-12-17	<1.0		
South East Corner Main Bldg	STK1955759-1					2019-10-22	Absent		
South East Corner Main Bldg	STK1952438-1					2019-08-20	Absent		
South East Corner Main Bldg	STK1938863-1					2019-06-18	Absent		
South East Corner Main Bldg	STK1935213-1					2019-04-16	Absent		
South East Corner Main Bldg	STK1932441-1					2019-02-19	Absent		
Well	STK1958323-5					2019-12-17	<1.0		
Wellhead	STK1957320-4					2019-11-22	<1.0		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.07	5
Bathroom #1	STK1739324-2	mg/L				2017-07-20	ND		
Bathroom #2	STK1739324-3	mg/L				2017-07-20	ND		
Bathroom #3	STK1739324-4	mg/L				2017-07-20	0.05		
Bathroom #4	STK1739324-5	mg/L				2017-07-20	0.06		
Kitchen	STK1739324-1	mg/L				2017-07-20	0.08		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			27	27 - 27
Well Head	STK1738968-1	mg/L				2017-07-18	27		
Hardness		mg/L		none	none			48.0	48.0 - 48.0
Well Head	STK1738968-1	mg/L				2017-07-18	48.0		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			2	2 - 2
Well Head	STK1738968-1	ug/L				2017-07-18	2		
Hexavalent Chromium		ug/L			0.02			6.1	6.1 - 6.1
Well Head	STK1451692-1	ug/L				2014-11-18	6.1		
Fluoride		mg/L		2	1			0.2	0.2 - 0.2
Well Head	STK1738968-1	mg/L				2017-07-18	0.2		
Nitrate as N		mg/L		10	10			2.5	2.5 - 2.5
Well Head	STK1950399-1	mg/L				2019-07-16	2.5		
Nitrate + Nitrite as N		mg/L		10	10			2.5	2.5 - 2.5
Well Head	STK1738968-1	mg/L				2017-07-18	2.5		



# Haynes Board & Care Home

## CCR Login Linkage - 2019

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
After Pressure	STK1958323-4	2019-12-17	Coliform	After Pressure Tank	Bacteriological Sampling-Even
AFTER PT	STK1957320-3	2019-11-22	Coliform	After PT	Bacteriological Sampling
BTHRM #1	STK1739324-2	2017-07-20	Metals, Total	Bathroom #1	State Copper & Lead Monitoring
BTHRM #2	STK1739324-3	2017-07-20	Metals, Total	Bathroom #2	State Copper & Lead Monitoring
BTHRM #3	STK1739324-4	2017-07-20	Metals, Total	Bathroom #3	State Copper & Lead Monitoring
BTHRM #4	STK1739324-5	2017-07-20	Metals, Total	Bathroom #4	State Copper & Lead Monitoring
KIT	STK1739324-1	2017-07-20	Metals, Total	Kitchen	State Copper & Lead Monitoring
Laundry RM	STK1957320-1	2019-11-22	Coliform	Laundry Room	Bacteriological Sampling
Laundry Room	STK1958323-3	2019-12-17	Coliform	Laundry Room	Bacteriological Sampling-Even
Laundry RM Tap	STK1931231-1	2019-01-24	Coliform	Laundry Room Tap	Bacteriological Sampling-Odd
	STK1933734-1	2019-03-19	Coliform	Laundry Room Tap	Bacteriological Sampling-Odd
	STK1937204-1	2019-05-21	Coliform	Laundry Room Tap	Bacteriological Sampling-Odd
	STK1950400-1	2019-07-16	Coliform	Laundry Room Tap	Bacteriological Sampling-Odd
	STK1953951-1	2019-09-17	Coliform	Laundry Room Tap	Bacteriological Sampling-Odd
	STK1957223-1	2019-11-20	Coliform	Laundry Room Tap	Bacteriological Sampling-Odd
S.E. Side of Bu	STK1957320-2	2019-11-22	Coliform	S.E. Side of Building	Bacteriological Sampling
SE CornerMain B	STK1932441-1	2019-02-19	Coliform	South East Corner Main Bldg	Bacteriological Sampling-Even
	STK1935213-1	2019-04-16	Coliform	South East Corner Main Bldg	Bacteriological Sampling-Even
	STK1938863-1	2019-06-18	Coliform	South East Corner Main Bldg	Bacteriological Sampling-Even
	STK1952438-1	2019-08-20	Coliform	South East Corner Main Bldg	Bacteriological Sampling-Even
	STK1955759-1	2019-10-22	Coliform	South East Corner Main Bldg	Bacteriological Sampling-Even
	STK1958323-1	2019-12-17	Coliform	South East Corner Main Bldg	Bacteriological Sampling-Even
South East Corn	STK1958323-2	2019-12-17	Coliform	South East Corner Main Bldg	Bacteriological Sampling-Even
Well	STK1958323-5	2019-12-17	Coliform	Well	Bacteriological Sampling-Even
	STK1958323-5	2019-12-17	Field Test	Well	Bacteriological Sampling-Even
WELL HEAD	STK1451692-1	2014-11-18	Wet Chemistry	Well Head	Chrome 6 Monitoring
	STK1738968-1	2017-07-18	Metals, Total	Well Head	3 & 6 Year DHS Monitoring
	STK1738968-1	2017-07-18	Wet Chemistry	Well Head	3 & 6 Year DHS Monitoring
	STK1738968-1	2017-07-18	General Mineral	Well Head	3 & 6 Year DHS Monitoring
	STK1950399-1	2019-07-16	Wet Chemistry	Well Head	3 & 6 Year DHS Monitoring
Wellhead	STK1957320-4	2019-11-22	Coliform	Wellhead	Bacteriological Sampling
	STK1957320-4	2019-11-22	Field Test	Wellhead	Bacteriological Sampling