

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name: **BRIGHTVIEW TREE CO**

Water System Number: **3901343**

The water system above hereby certifies that its Consumer Confidence Report was distributed on 5/6/2020 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name	<u>VICTOR VEGA</u>	
	Signature	<u></u>	
	Title	<u>SUPERVISOR</u>	
	Phone Number	<u>( 209 ) 606-0740</u>	Date <u>5/6/2020</u>

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

ANNOUNCED AT EMPLOYEE GROUP MEETINGS AND POSTED AT MEETING  
LOCATIONS.

☒ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

☐ Posted the CCR on the internet at http://

☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)

☐ Advertised the availability of the CCR in news media (attach a copy of press release)

☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

☒ Posted the CCR in public places (attach a list of locations)

☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

☐ Delivery to community organizations (attach a list of organizations)

☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http://

☐ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2019 Consumer Confidence Report

Water System Name: BRIGHTVIEW TREE CO

Report Date: April 2020

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Well

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call 925-437-3355 and ask for Francisco Reyes or email [francisco.reyes@brightview.com](mailto:francisco.reyes@brightview.com) or visit our website at [www.vctree.com](http://www.vctree.com).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

<b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA</b>					
<b>Microbiological Contaminants</b> (complete if bacteria detected)	<b>Highest No. of Detections</b>	<b>No. of Months in Violation</b>	<b>MCL</b>	<b>MCLG</b>	<b>Typical Sources of Contaminant</b>
Total Coliform Bacteria	1/mo. (2019)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

<b>Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>
Hexavalent Chromium (ug/L)	(2014)	1.5	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Fluoride (mg/L)	(2019)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2019)	3.4	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 3 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (mg/L)	(2017)	0.018	n/a	0.05	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 4 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2019)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Brightview Tree Company* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## 2019 Consumer Confidence Report

### Drinking Water Assessment Information

#### Assessment Information

A source water assessment was conducted for the WELL of the BRIGHTVIEW TREE CO water system in May, 2001

Well - is considered most vulnerable to the following activities not associated with any detected contaminants:

- Animal Feeding Operations as defined in federal regulation 2
- Automobile - Gas stations
- Chemical/petroleum processing/storage

**Acquiring Information**

A copy of the complete assessment may be viewed at:

San Joaquin County  
Environmental Health Division  
304 E. Weber Ave, 3rd Floor  
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Willy Ng, REHS  
SJ Co Environmental Health Division  
(209) 468-3448  
[wng@phs.hs.co.san-joaquin.ca.us](mailto:wng@phs.hs.co.san-joaquin.ca.us)

## Analytical Results By FGL - 2019

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
By OakTree	STK1937932-2					2019-06-05	<1.0		
H.B. By OakTree PicnicTable Br	STK1950709-3					2019-07-22	<1.0		
H.B. By OakTree PicnicTable Br	STK1950709-4					2019-07-22	<1.0		
Office Sample Tap-Admin/Sales	STK1958016-1					2019-12-10	Absent		
Office Sample Tap-Admin/Sales	STK1957080-1					2019-11-18	Absent		
Office Sample Tap-Admin/Sales	STK1954777-1					2019-10-02	Absent		
Office Sample Tap-Admin/Sales	STK1953707-1					2019-09-12	Absent		
Office Sample Tap-Admin/Sales	STK1951249-1					2019-08-05	Absent		
Office Sample Tap-Admin/Sales	STK1950709-1					2019-07-22	<1.0		
Office Sample Tap-Admin/Sales	STK1950709-2					2019-07-22	<1.0		
Office Sample Tap-Admin/Sales	STK1937775-1					2019-06-03	Present		
Office Sample Tap-Admin/Sales	STK1936734-1					2019-05-14	Absent		
Office Sample Tap-Admin/Sales	STK1934220-1					2019-04-01	Absent		
Office Sample Tap-Admin/Sales	STK1933329-1					2019-03-08	Absent		
Office Sample Tap-Admin/Sales	STK1931643-1					2019-02-04	Absent		
Office Sample Tap-Admin/Sales	STK1930649-1					2019-01-14	Absent		
Office Tap Sample	STK1937932-1					2019-06-05	<1.0		
Office Tap Sample	STK1937932-3					2019-06-05	<1.0		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Hexavalent Chromium		ug/L			0.02			1.5	1.5 - 1.5
Well	STK1451568-1	ug/L				2014-11-18	1.5		
Fluoride		mg/L		2	1			0.1	0.1 - 0.1
Well	STK1931642-1	mg/L				2019-02-04	0.1		
Nitrate as N		mg/L		10	10			3.4	3.4 - 3.4
Well	STK1931641-1	mg/L				2019-02-04	3.4		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		mg/L		NS	n/a			0.018	0.018 - 0.018
Well	STK1731459-1	mg/L				2017-02-06	0.018		

[illegible]

# Brightview Tree Company

## CCR Login Linkage - 2019

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Rpt-ss01	STK1937932-2	2019-06-05	Coliform	By OakTree	Repeat Bacteriological Monitoring
CuPb-Div.#406	STK1938221-4	2019-06-05	Metals, Total	Div. #406	Copper & Lead Monitoring
Div. #415	STK1938221-5	2019-06-05	Metals, Total	Div. #415	Copper & Lead Monitoring
Div. #500	STK1938221-3	2019-06-05	Metals, Total	Div. #500	Copper & Lead Monitoring for System# 3901343
HB By OakTree	STK1950709-3	2019-07-22	Coliform	H.B. By OakTree PicnicTable Br	Bacteriological Monitoring
	STK1950709-4	2019-07-22	Coliform	H.B. By OakTree PicnicTable Br	Bacteriological Monitoring
CuPb-LoadingD	STK1938221-1	2019-06-05	Metals, Total	Loading Dock	Copper & Lead Monitoring
CuPb-Main Off-D	STK1938221-2	2019-06-05	Metals, Total	Main Office	Copper & Lead Monitoring
Bacti-ss04	STK1930649-1	2019-01-14	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1931643-1	2019-02-04	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1933329-1	2019-03-08	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1934220-1	2019-04-01	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1936734-1	2019-05-14	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1937775-1	2019-06-03	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1950709-1	2019-07-22	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Monitoring
	STK1950709-2	2019-07-22	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Monitoring
	STK1951249-1	2019-08-05	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1953707-1	2019-09-12	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1954777-1	2019-10-02	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1957080-1	2019-11-18	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
	STK1958016-1	2019-12-10	Coliform	Office Sample Tap-Admin/Sales	Bacteriological Sampling
Bacti-Rout-ss01	STK1937932-1	2019-06-05	Coliform	Office Tap Sample	Routine Bacteriological Monitoring
	STK1937932-3	2019-06-05	Coliform	Office Tap Sample	Routine Bacteriological Monitoring
STW-1	STK1451568-1	2014-11-18	Wet Chemistry	Well	Chrome 6 Monitoring
WELL 01	STK1731459-1	2017-02-06	Metals, Total	Well	Water Monitoring (3 year)
	STK1931642-1	2019-02-04	Wet Chemistry	Well	Fluoride Monitoring
	STK1931641-1	2019-02-04	Wet Chemistry	Well	Water Monitoring (3 year)
	STK1937932-4	2019-06-05	Field Test	Well	VALLEY CREST TREE CO
	STK1950709-5	2019-07-22	Field Test	Well	VALLEY CREST TREE CO