


**Consumer Confidence Report  
Certification Form**  
(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Water Board's website at [http://www.swrcb.ca.gov/drinking\\_water/cert/cdr/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/cert/cdr/drinkingwater/CCR.shtml))

Water System Name:	Basalite Concrete Products LLC
Water System Number:	3901369

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 04/08/2021 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by:	Name:	Sam Hedge	
	Signature:		
	Title:	Water Operator	
	Phone Number:	(209-406-6069)	Date: 05/28/2021

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was Posted on Company Billboards.
- ☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- ☐ Posting the CCR on the Internet at [www.\\_\\_\\_\\_\\_](http://www._____)
  - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
  - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - ☐ Posted the CCR in public places (locations)
  - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
  - ☐ Delivery to community organizations (attach a list of organizations)
  - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: [www.\\_\\_\\_\\_\\_](http://www._____)
- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

*This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).*

# 2020 Consumer Confidence Report

Water System Name: BASALITE CONCRETE PRODUCTS LLC

Report Date: April 2021

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Well Head

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call 2094066069 and ask for Sam Hedge or email [samhedge@caldsl.net](mailto:samhedge@caldsl.net) or visit our website at [www.Basalite.com](http://www.Basalite.com).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.



**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	3/mo. (2020)	3	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2020)	5	0.08	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2019)	3	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Hexavalent Chromium (ug/L)	(2014)	3.61	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.

Nitrate as N (mg/L)	(2020)	9.2	8.8 - 9.6	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2016)	1.56	n/a	15	(0)	Erosion of natural deposits.

**Table 4 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (mg/L)	(2019)	0.008	n/a	0.05	Vanadium exposures resulted in developmental and reproductive effects in rats.

**Table 5 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2020)	0.00	ND - 0.00	4.0	4.0	No	Drinking water disinfectant added for treatment.

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Basalite* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.



## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

**About your Nitrate as N:** Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

## 2020 Consumer Confidence Report

### Drinking Water Assessment Information

#### Assessment Information

A source water assessment was conducted for the WELL HEAD of the BASALITE water system in April, 2002.

Well Head - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Cement/concrete plants

#### Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

#### Acquiring Information

A copy of the complete assessment may be viewed at:

San Joaquin County  
Environmental Health Department  
304 E. Weber Ave, 3rd Floor  
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems  
SJ Co Environmental Health Department  
(209) 468-3420

# Basalite

## Analytical Results By FGL - 2020

MICROBIOLOGICAL CONTAMINANTS								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Total Coliform Bacteria</b>			0	5%	n/a			3 1 - 3.1
Block Plant HB	STK2055734-1					2020-11-09	Absent	
Block Plant HB	STK2037768-4					2020-06-04	<1.0	
Lab Sink	STK2039687-3					2020-07-10	3.1	
Lab Sink	STK2039490-1					2020-07-08	Present	
Lab Sink	STK2037768-3					2020-06-04	<1.0	
Lab Sink	STK2036455-1					2020-05-12	<1.0	
Lab Sink	STK2036196-1					2020-05-07	<1.0	
Lab Sink	STK2035980-1					2020-05-05	Present	
N. Entrance/ Office Spigot	STK2056749-1					2020-12-02	Absent	
N. Entrance/ Office Spigot	STK2054685-1					2020-10-14	Absent	
N. Entrance/ Office Spigot	STK2053529-1					2020-09-22	<1.0	
N. Entrance/ Office Spigot	STK2053529-2					2020-09-22	<1.0	
N. Entrance/ Office Spigot	STK2052030-2					2020-08-21	<1.0	
N. Entrance/ Office Spigot	STK2051968-1					2020-08-20	2	
N. Entrance/ Office Spigot	STK2051968-2					2020-08-20	1	
N. Entrance/ Office Spigot	STK2039687-1					2020-07-10	<1.0	
N. Entrance/ Office Spigot	STK2037768-1					2020-06-04	<1.0	
N. Entrance/ Office Spigot	STK2037768-2					2020-06-04	<1.0	
N. Entrance/ Office Spigot	STK2036455-2					2020-05-12	<1.0	
N. Entrance/ Office Spigot	STK2036196-3					2020-05-07	1	
N. Entrance/ Office Spigot	STK2034469-1					2020-04-06	Absent	
N. Entrance/ Office Spigot	STK2031759-1					2020-02-05	Absent	
NE Corner/ Block Plant Spigot	STK2053529-3					2020-09-22	<1.0	
NE Corner/ Block Plant Spigot	STK2053529-4					2020-09-22	<1.0	
NE Corner/ Block Plant Spigot	STK2052030-3					2020-08-21	<1.0	
NE Corner/ Block Plant Spigot	STK2051968-3					2020-08-20	2	
NE Corner/ Block Plant Spigot	STK2051968-4					2020-08-20	<1.0	
NE Corner/ Block Plant Spigot	STK2039687-2					2020-07-10	<1.0	
NE Corner/ Block Plant Spigot	STK2036455-3					2020-05-12	<1.0	
NE Corner/ Block Plant Spigot	STK2036196-2					2020-05-07	<1.0	
NE Corner/ Paver Plant Spigot	STK2032886-1					2020-03-02	Absent	
NE Corner/ Paver Plant Spigot	STK2030716-1					2020-01-15	Absent	

LEAD AND COPPER RULE								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile # Samples
<b>Copper</b>		mg/L		1.3	.3			0.075 5
CuPb- Block Lab	STK2052247-3	mg/L				2020-08-12	0.15	
CuPb- Block Restroom	STK2052247-2	mg/L				2020-08-12	ND	
CuPb- Mens Admin. Office	STK2052247-4	mg/L				2020-08-12	ND	
CuPb- Mens Sales Office	STK2052247-5	mg/L				2020-08-12	ND	
CuPb- Sack Plant Restroom	STK2052247-1	mg/L				2020-08-12	ND	

PRIMARY DRINKING WATER STANDARDS (PDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Arsenic</b>		ug/L		10	0.004			3 3 - 3
Well Head	STK1953237-1	ug/L				2019-09-06	3	
<b>Hexavalent Chromium</b>		ug/L			0.02			3.61 3.61 - 3.61
Well Head	STK1439583-1	ug/L				2014-09-18	3.61	
<b>Nitrate as N</b>		mg/L		10	10			9.2 8.8 - 9.6
Well Head	STK2055733-1	mg/L				2020-11-09	9.6	



# Basalite

## CCR Login Linkage - 2020

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Blk Plant HB	STK2037768-4	2020-06-04	Coliform	Block Plant HB	Bacteriological Sampling
	STK2055734-1	2020-11-09	Coliform	Block Plant HB	Bacteriological Sampling
CuPb-ss03	STK2052247-3	2020-08-12	Metals, Total	CuPb- Block Lab	Copper & Lead Monitoring
CuPb-ss02	STK2052247-2	2020-08-12	Metals, Total	CuPb- Block Restroom	Copper & Lead Monitoring
CuPb-ss04	STK2052247-4	2020-08-12	Metals, Total	CuPb- Mens Admin. Office	Copper & Lead Monitoring
CuPb-ss05	STK2052247-5	2020-08-12	Metals, Total	CuPb- Mens Sales Office	Copper & Lead Monitoring
CuPb-ss01	STK2052247-1	2020-08-12	Metals, Total	CuPb- Sack Plant Restroom	Copper & Lead Monitoring
Bacti-Rout-ss02	STK2035980-1	2020-05-05	Coliform	Lab Sink	Bacteriological Monitoring - Odd
Lab Sink	STK2036196-1	2020-05-07	Coliform	Lab Sink	Bacteriological Monitoring
Bacti-Rout-ss02	STK2036455-1	2020-05-12	Coliform	Lab Sink	Bacteriological Monitoring - Odd
	STK2037768-3	2020-06-04	Coliform	Lab Sink	Bacteriological Monitoring - Odd
	STK2039490-1	2020-07-08	Coliform	Lab Sink	Bacteriological Monitoring - Odd
	STK2039687-3	2020-07-10	Coliform	Lab Sink	Repeat Bacteriological Sampling
Bacti-Rout-ss01	STK2031759-1	2020-02-05	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2034469-1	2020-04-06	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
N. Entrance/ Of	STK2036196-3	2020-05-07	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring
Bacti-Rout-ss01	STK2036455-2	2020-05-12	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2037768-1	2020-06-04	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2037768-2	2020-06-04	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2039687-1	2020-07-10	Coliform	N. Entrance/ Office Spigot	Repeat Bacteriological Sampling
	STK2051968-1	2020-08-20	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2051968-2	2020-08-20	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2052030-2	2020-08-21	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2053529-1	2020-09-22	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2053529-2	2020-09-22	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2054685-1	2020-10-14	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
	STK2056749-1	2020-12-02	Coliform	N. Entrance/ Office Spigot	Bacteriological Monitoring - Even
NE Corner/ Bloc	STK2036196-2	2020-05-07	Coliform	NE Corner/ Block Plant Spigot	Bacteriological Sampling
Bacti-Rout-ss03	STK2036455-3	2020-05-12	Coliform	NE Corner/ Block Plant Spigot	Bacteriological Sampling
	STK2039687-2	2020-07-10	Coliform	NE Corner/ Block Plant Spigot	Repeat Bacteriological Sampling
	STK2051968-3	2020-08-20	Coliform	NE Corner/ Block Plant Spigot	Bacteriological Sampling
	STK2051968-4	2020-08-20	Coliform	NE Corner/ Block Plant Spigot	Bacteriological Sampling
	STK2052030-3	2020-08-21	Coliform	NE Corner/ Block Plant Spigot	Bacteriological Sampling
	STK2053529-3	2020-09-22	Coliform	NE Corner/ Block Plant Spigot	Bacteriological Sampling
	STK2053529-4	2020-09-22	Coliform	NE Corner/ Block Plant Spigot	Bacteriological Sampling
Bacti-Rout-ss02	STK2030716-1	2020-01-15	Coliform	NE Corner/ Paver Plant Spigot	Bacteriological Monitoring - Odd
	STK2032886-1	2020-03-02	Coliform	NE Corner/ Paver Plant Spigot	Bacteriological Monitoring - Odd
WELL01	STK1439583-1	2014-09-18	Wet Chemistry	Well Head	Chrome 6 Monitoring
	STK1636216-1	2016-05-24	Radio Chemistry	Well Head	Radio Monitoring
	STK1953237-1	2019-09-06	Metals, Total	Well Head	Water Quality Monitoring
	STK2031760-1	2020-02-05	Wet Chemistry	Well Head	Nitrate Monitoring
	STK2035997-1	2020-05-05	Wet Chemistry	Well Head	Nitrate Monitoring
Well Head	STK2036196-4	2020-05-07	Field Test	Well Head	Bacteriological Monitoring
WELL01	STK2036455-4	2020-05-12	Field Test	Well Head	BASALITE - TRACY
	STK2037768-5	2020-06-04	Field Test	Well Head	BASALITE - TRACY
	STK2039687-4	2020-07-10	Field Test	Well Head	Repeat Bacteriological Sampling
	STK2051969-1	2020-08-20	Wet Chemistry	Well Head	Nitrate Monitoring
	STK2051968-5	2020-08-20	Field Test	Well Head	BASALITE - TRACY
	STK2052030-4	2020-08-21	Field Test	Well Head	BASALITE - TRACY
	STK2053529-5	2020-09-22	Field Test	Well Head	BASALITE - TRACY
	STK2055733-1	2020-11-09	Wet Chemistry	Well Head	Nitrate Monitoring