

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	O-G Packing Company
Water System Number:	CA3901382

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	<i>Jim Wunderlich</i>	
	Signature:	<i>Jim Wunderlich</i>	
	Title:	<i>CDO</i>	
	Phone Number:	<i>(209) 403-1547</i>	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:
Posted in break room + hand outs

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://> _____
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2023 Consumer Confidence Report

Water System Name: O-G Packing Company

Report Date: _____

April 2024

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, the source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): WELL #1 and WELL #3

Opportunities for public participation in decisions that affect drinking water quality: Meetings are held on an as needed basis. Fliers are hand delivered to consumer announcing the meeting's location, date, and time.

For more information about this report, or any questions relating to your drinking water, please call (209) 931-4392 and ask for David Sutton.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/year (2023)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2022)	5	11	1	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2015)	7	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2015)	52.1	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2022 - 2023)	3	2 - 3	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Chromium (ug/L)	(2022 - 2023)	ND	ND - 11	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Nitrate as N (mg/L)	(2023)	1.4	1.2 - 1.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2020)	1.03	n/a	15	(0)	Erosion of natural deposits.

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2015)	2	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2015)	110	n/a	300	n/a	Leaching from natural deposits; Industrial wastes
Specific Conductance (umhos/cm)	(2015)	147	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2015)	4	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2015)	130	n/a	1000	n/a	Runoff/leaching from natural deposits
Zinc (mg/L)	(2015)	0.62	n/a	5	n/a	Runoff/leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (ug/L)	(2022 - 2023)	19	16 - 21	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 7 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2015)	11	n/a	n/a	n/a
Magnesium (mg/L)	(2015)	6	n/a	n/a	n/a
pH (units)	(2015)	7.7	n/a	n/a	n/a
Alkalinity (mg/L)	(2015)	50	n/a	n/a	n/a
Aggressiveness Index	(2015)	10.8	n/a	n/a	n/a
Langelier Index	(2015)	-1	n/a	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2022)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *O-G Packing Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Lead				<p>Infants and children who drink water containing lead in excess of the action level may experience delays in their physical or mental development. Children may show slight deficits in attention span and learning abilities. Adults who drink this water over many years may develop kidney problems or high blood pressure.</p>
------	--	--	--	--

2023 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL #1 of the O-G PACKING CO water system in October, 2002. A source water assessment has not been completed for the WELL #3 of the O-G PACKING CO water system.

WELL #1 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Wells - Agricultural/ Irrigation

WELL #3 - does not have a completed Source Water Assessment on file.

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

A copy of the complete assessment may be viewed at:

San Joaquin County
Environmental Health Department
304 E. Weber Ave, 3rd Floor
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems
SJ Co Environmental Health Department
(209) 468-3420

For more info you may visit <http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp> or contact the health department in the county to which the water system belongs.

O-G Packing Co.

Analytical Results By FGL - 2023

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	4.1 - 4.1
HB - S.E. Corner of Office	STK2357399-1					2023-12-21	Absent		
HB - S.E. Corner of Office	STK2355806-1					2023-11-15	Absent		
HB - S.E. Corner of Office	STK2354534-1					2023-10-18	Absent		
HB - S.E. Corner of Office	STK2352885-1					2023-09-19	Absent		
HB - S.E. Corner of Office	STK2351048-1					2023-08-14	Absent		
HB - S.E. Corner of Office	STK2339504-1					2023-07-18	Absent		
HB - S.E. Corner of Office	STK2337933-1					2023-06-20	Absent		
HB - S.E. Corner of Office	STK2336070-1					2023-05-16	Absent		
HB - S.E. Corner of Office	STK2334562-1					2023-04-13	Absent		
HB - S.E. Corner of Office	STK2333326-1					2023-03-15	Absent		
HB - S.E. Corner of Office	STK2332071-1					2023-02-16	Absent		
HB - S.E. Corner of Office	STK2330765-1					2023-01-18	Absent		
Huller	STK2354942-1					2023-10-26	<1.0		
North Corner Shop	STK2357398-1					2023-12-21	<1		
North Corner Shop	STK2355805-1					2023-11-15	<1		
North Corner Shop	STK2354533-1					2023-10-18	<1		
North Corner Shop	STK2352884-1					2023-09-19	<1		
North Corner Shop	STK2351047-1					2023-08-14			
North Corner Shop	STK2339503-1					2023-07-18	<1		
North Corner Shop	STK2337932-1					2023-06-20	4.1		
North Corner Shop	STK2336069-1					2023-05-16	<1		
North Corner Shop	STK2334561-1					2023-04-13	<1		
North Corner Shop	STK2333327-1					2023-03-15	<1		
North Corner Shop	STK2332070-1					2023-02-16	<1		
North Corner Shop	STK2330764-1					2023-01-18	<1		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			10.5	5
CuPb- Bldg. A Drink Fountain	STK2232618-1	ug/L				2022-02-22	ND		
CuPb- Bldg. A Sample Outlet	STK2232618-2	ug/L				2022-02-22	ND		
CuPb- Bldg. C Drink Fountain	STK2232618-5	ug/L				2022-02-22	ND		
CuPb- Bldg. C Sample Spout	STK2232618-4	ug/L				2022-02-22	21.0		
CuPb- JapanRoom Drink Fountain	STK2232618-3	ug/L				2022-02-22	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			7	7 - 7
WELL #1	STK1551246-1	mg/L				2015-10-08	7		
Hardness		mg/L		none	none			52.1	52.1 - 52.1
WELL #1	STK1551246-1	mg/L				2015-10-08	52.1		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			3	2 - 3
WELL #1	STK2233616-1	ug/L				2022-03-16	2		
WELL #3	STK2339607-1	ug/L				2023-07-24	3		
Chromium		ug/L	100	50.0	n/a			ND	ND - 11

O-G Packing Co.
CCR Login Linkage - 2023

FGL Code	Lab ID	Date Sampled	Method	Description	Property
CuPb-ss01	STK2232618-1	2022-02-22	Metals, Total	CuPb- Bldg. A Drink Fountain	Copper & Lead Monitoring
CuPb-ss02	STK2232618-2	2022-02-22	Metals, Total	CuPb- Bldg. A Sample Outlet	Copper & Lead Monitoring
CuPb-ss05	STK2232618-5	2022-02-22	Metals, Total	CuPb- Bldg. C Drink Fountain	Copper & Lead Monitoring
CuPb-ss04	STK2232618-4	2022-02-22	Metals, Total	CuPb- Bldg. C Sample Spout	Copper & Lead Monitoring
CuPb-ss03	STK2232618-3	2022-02-22	Metals, Total	CuPb- JapanRoom Drink Fountain	Copper & Lead Monitoring
Bacti-Rout-ss01	STK2330765-1	2023-01-18	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2332071-1	2023-02-16	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2333326-1	2023-03-15	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2334562-1	2023-04-13	Coliform	HB - S.E. Corner of Office	Bacteriological Sampling
	STK2336070-1	2023-05-16	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2337933-1	2023-06-20	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2339504-1	2023-07-18	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2351048-1	2023-08-14	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2352885-1	2023-09-19	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2354534-1	2023-10-18	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2355806-1	2023-11-15	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
	STK2357399-1	2023-12-21	Coliform	HB - S.E. Corner of Office	Routine Bacteriological Sampling
Huller	STK2354942-1	2023-10-26	Coliform	Huller	Goteli
N. Corner Shop	STK2330764-1	2023-01-18	Coliform	North Corner Shop	Bacteriological Sampling
North Corner Sh	STK2332070-1	2023-02-16	Coliform	North Corner Shop	Food Safety
	STK2333327-1	2023-03-15	Coliform	North Corner Shop	Food Safety
	STK2334561-1	2023-04-13	Coliform	North Corner Shop	Food Safety
	STK2336069-1	2023-05-16	Coliform	North Corner Shop	Food Safety
	STK2337932-1	2023-06-20	Coliform	North Corner Shop	Food Safety
	STK2339503-1	2023-07-18	Coliform	North Corner Shop	Food Safety
	STK2351047-1	2023-08-14	Coliform	North Corner Shop	Food Safety
	STK2352884-1	2023-09-19	Coliform	North Corner Shop	Food Safety
	STK2354533-1	2023-10-18	Coliform	North Corner Shop	Food Safety
	STK2355805-1	2023-11-15	Coliform	North Corner Shop	Food Safety
	STK2357398-1	2023-12-21	Coliform	North Corner Shop	Food Safety
WELL 01 South	STK1551246-1	2015-10-08	General Mineral	WELL #1	Locke
	STK2233616-1	2022-03-16	Metals, Total	WELL #1	Well 1 - IOC Metals
	STK2238337-2	2022-06-14		WELL #1	Atrazine and Simazine Monitoring
	STK2333492-1	2023-03-20		Well #1	Well 1 - Water Quality
	STK2333492-1	2023-03-20	Wet Chemistry	WELL #1	Well 1 - Water Quality
WELL 03	STK1730928-5	2017-01-24	Coliform	WELL #3	O-G PACKING CO
	STK1730928-5	2017-01-24	Field Test	WELL #3	O-G PACKING CO
	STK2038636-1	2020-06-17	Radio Chemistry	WELL #3	Well #3 - Radio
	STK2238338-1	2022-06-14		WELL #3	Well #3 - Water Quality
	STK2238337-1	2022-06-14		WELL #3	Atrazine and Simazine Monitoring
	STK2253192-4	2022-09-16	Field Test	WELL #3	Bacteriological Sampling
	STK2339607-1	2023-07-24	Metals, Total	WELL #3	Well #3-Perchlorate/IOC Metals
	STK2339606-1	2023-07-24	Wet Chemistry	WELL #3	Well #3 - Water Quality