


# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>FRANK C ALEGRE TRUCKING INC WS</b>
Water System Number:	<b>CA3901390</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on April 25, 2022 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	<b>Micki Schultz</b>	
	Signature:		
	Title:	<b>General Manager</b>	
	Phone Number:	<b>( 209 ) 340-4723</b>	Date: <b>April 25, 2022</b>

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:  
The report has been posted in conspicuous locations (ie: employee breakrooms, hallways with other required employee postings) and is had delivered to any tenants. A copy is also made available at the CA Drinking Water Watch site.
- ☒ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:
- ☒ Posted the CCR on the internet at http:// sdwis.waterboards.ca.gov
  - ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
  - ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
  - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
  - ☒ Posted the CCR in public places (attach a list of locations) **Employee breakrooms and hallways with other employee postings**
  - ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
  - ☐ Delivery to community organizations (attach a list of organizations)
  - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http://
- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

# 2021 Consumer Confidence Report

Water System Name: FRANK C ALEGRE TRUCKING INC WS

Report Date: April 2022

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2021.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Well Head  
**and from 1 treated location(s):** TREATMENT

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service Inc..

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

<b>Table 1 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>
Arsenic (ug/L)	(2021)	19	18 - 20	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2019)	0.25	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Nitrate as N (mg/L)	(2021)	3	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2019)	7.47	n/a	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2019)	4.53	n/a	20	0.43	Erosion of natural deposits

<b>Table 2 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>
Arsenic (ug/L)	(2021)	ND	ND - 3	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

<b>Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Manganese (ug/L)	(2021)	184	n/a	50	n/a	Leaching from natural deposits

<b>Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Manganese (ug/L)	(2021)	ND	n/a	50	n/a	Leaching from natural deposits

<b>Table 5 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE</b>							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2021)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/ Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Frank C Alegre Trucking Inc.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

**About your Arsenic:** The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Arsenic				Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
Manganese				Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

## 2021 Consumer Confidence Report

### Drinking Water Assessment Information

#### Assessment Information

A source water assessment was conducted for the WELL HEAD of the FRANK C ALEGRE TRUCKING, INC water system in April, 2002.

Well Head - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Fleet/truck/bus terminals

#### Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

#### Acquiring Information

A copy of the complete assessment may be viewed at:  
San Joaquin County  
Environmental Health Department  
304 E. Weber Ave, 3rd Floor  
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:  
Small Public Water Systems  
SJ Co Environmental Health Department  
(209) 468-3420

**Frank C Alegre Trucking Inc.**  
**Analytical Results By FGL - 2021**

PRIMARY DRINKING WATER STANDARDS (PDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Arsenic</b>		ug/L		10	0.004			19 18 - 20
Well Head	STK2154315-1	ug/L				2021-10-05	18	
Well Head	STK2139374-1	ug/L				2021-07-06	19	
Well Head	STK2134372-1	ug/L				2021-04-05	20	
Well Head	STK2130417-1	ug/L				2021-01-07	19	
<b>Barium</b>		mg/L	2	1	2			0.25 0.25 - 0.25
Well Head	STK1935554-1	mg/L				2019-04-22	0.25	
<b>Nitrate as N</b>		mg/L		10	10			3.0 3.0 - 3.0
Well Head	STK2134372-1	mg/L				2021-04-05	3.0	
<b>Gross Alpha</b>		pCi/L		15	(0)			7.47 7.47 - 7.47
Well Head	STK1935556-1	pCi/L				2019-04-22	7.47	
<b>Uranium</b>		pCi/L		20	0.43			4.53 4.53 - 4.53
Well Head	STK1935556-1	pCi/L				2019-04-22	4.53	

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Arsenic</b>		ug/L		10	0.004			ND ND - 3
TREATMENT	STK2157374-1	ug/L				2021-12-06	ND	
TREATMENT	STK2155922-1	ug/L				2021-11-03	ND	
TREATMENT	STK2154316-1	ug/L				2021-10-05	ND	
TREATMENT	STK2152510-1	ug/L				2021-09-01	ND	
TREATMENT	STK2150885-1	ug/L				2021-08-02	ND	
TREATMENT	STK2139385-1	ug/L				2021-07-06	2	
TREATMENT	STK2137787-1	ug/L				2021-06-02	ND	
TREATMENT	STK2136058-1	ug/L				2021-05-04	ND	
TREATMENT	STK2134371-1	ug/L				2021-04-05	ND	
TREATMENT	STK2132804-1	ug/L				2021-03-01	3	
TREATMENT	STK2131455-1	ug/L				2021-02-01	ND	
TREATMENT	STK2130416-1	ug/L				2021-01-07	ND	

SECONDARY DRINKING WATER STANDARDS (SDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Manganese</b>		ug/L		50	n/a			184 184 - 184
Well Head	STK2134372-1	ug/L				2021-04-05	184	

TREATED SECONDARY DRINKING WATER STANDARDS (SDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Manganese</b>		ug/L		50	n/a			ND ND - ND
TREATMENT	STK2134371-1	ug/L				2021-04-05	ND	

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Chlorine</b>		mg/L		4.0	4.0			0.00 ND -
Well Head	STK2157373-2	mg/L				2021-12-06	ND	
Well Head	STK2155921-2	mg/L				2021-11-03	ND	
Well Head	STK2154314-2	mg/L				2021-10-05	ND	
Well Head	STK2152497-2	mg/L				2021-09-01	ND	
Well Head	STK2150884-2	mg/L				2021-08-02	ND	
Well Head	STK2139386-2	mg/L				2021-07-06	ND	



# Frank C Alegre Trucking Inc.

## CCR Login Linkage - 2021

FGL Code	Lab ID	Date Sampled	Method	Description	Property
Kitchen Trailer	STK1954165-2	2019-09-08	Metals, Total	Kitchen Trailer	Cu & Pb Monitoring
Main Off. Kitch	STK1954165-4	2019-09-08	Metals, Total	Main Off. Kitchen	Cu & Pb Monitoring
Main Off. Mens	STK1954165-3	2019-09-08	Metals, Total	Main Off. Mens Rest Room	Cu & Pb Monitoring
Bacti-Rout-ss01	STK2130418-1	2021-01-07	Coliform	Office Kitchen	Bacteriological Sampling
	STK2131454-1	2021-02-01	Coliform	Office Kitchen	Bacteriological Sampling
	STK2132803-1	2021-03-01	Coliform	Office Kitchen	Bacteriological Sampling
	STK2134370-1	2021-04-05	Coliform	Office Kitchen	Bacteriological Sampling
	STK2136057-1	2021-05-04	Coliform	Office Kitchen	Bacteriological Sampling
	STK2137786-1	2021-06-02	Coliform	Office Kitchen	Bacteriological Sampling
	STK2139386-1	2021-07-06	Coliform	Office Kitchen	Bacteriological Sampling
	STK2150884-1	2021-08-02	Coliform	Office Kitchen	Bacteriological Sampling
	STK2152497-1	2021-09-01	Coliform	Office Kitchen	Bacteriological Sampling
	STK2154314-1	2021-10-05	Coliform	Office Kitchen	Bacteriological Sampling
	STK2155921-1	2021-11-03	Coliform	Office Kitchen	Bacteriological Sampling
	STK2157373-1	2021-12-06	Coliform	Office Kitchen	Bacteriological Sampling
Safety Office	STK1954165-1	2019-09-08	Metals, Total	Safety Office	Cu & Pb Monitoring
Trailer Bathroo	STK1954165-5	2019-09-08	Metals, Total	Trailer Bathroom	Cu & Pb Monitoring
AsTrtmnt-ss01	STK2130416-1	2021-01-07	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2131455-1	2021-02-01	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2132804-1	2021-03-01	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2134371-1	2021-04-05	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2136058-1	2021-05-04	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2137787-1	2021-06-02	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2139385-1	2021-07-06	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2150885-1	2021-08-02	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2152510-1	2021-09-01	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2154316-1	2021-10-05	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2155922-1	2021-11-03	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2157374-1	2021-12-06	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
WELL HEAD	STK1935556-1	2019-04-22	Radio Chemistry	Well Head	Water Quality - Radio
Wellhead Sample	STK1935554-1	2019-04-22	Metals, Total	Well Head	Water Quality Monitoring
WELL HEAD	STK2130417-1	2021-01-07	Metals, Total	Well Head	Water Quality Monitoring
	STK2130418-2	2021-01-07	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2131454-2	2021-02-01	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2132803-2	2021-03-01	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2134372-1	2021-04-05	Wet Chemistry	Well Head	Water Quality Monitoring
	STK2134372-2	2021-04-05	Metals, Total	Well Head	Water Quality Monitoring
	STK2134370-2	2021-04-05	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2136057-2	2021-05-04	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2137786-2	2021-06-02	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2139374-1	2021-07-06	Metals, Total	Well Head	Water Quality Monitoring
	STK2139386-2	2021-07-06	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2150884-2	2021-08-02	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2152497-2	2021-09-01	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2154315-1	2021-10-05	Metals, Total	Well Head	Water Quality Monitoring
	STK2154314-2	2021-10-05	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2155921-2	2021-11-03	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2157373-2	2021-12-06	Field Test	Well Head	Bacteriological Sampling - Odd