

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	FRANK C ALEGRE TRUCKING INC WS
Water System Number:	CA3901390

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:		
	Signature:		
	Title:		
	Phone Number:	()	Date:

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

- "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://> _____
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

- For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2024 Consumer Confidence Report

Water System Name: FRANK C ALEGRE TRUCKING INC WS

Report Date: June 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): Well Head
and from 1 treated location(s): TREATMENT

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service Inc..

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2023 - 2024)	21	18 - 23	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2022)	0.22	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Nitrate as N (mg/L)	(2023 - 2024)	2.1	2.0 - 2.1	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2019)	7.47	n/a	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2019)	4.53	n/a	20	0.43	Erosion of natural deposits

Table 2 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2024)	ND	ND - 4	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Manganese (ug/L)	(2023 - 2024)	145	136 - 153	50	n/a	Leaching from natural deposits

Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Manganese (ug/L)	(2024)	ND	n/a	50	n/a	Leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ug/L)	(2022)	9	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.
Manganese (ug/L)	(2023 - 2024)	145	136 - 153	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine, Total (mg/L)	(2024)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.
Chlorine, Free (mg/L)	(2024)	1.29	0.0 - 3.69	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Frank C Alegre Trucking Inc.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or

Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Arsenic	This contaminant is treated for in the system due to a known exceedance at the wellhead. Treated levels are below the MCL.		This contaminant is treated for in the system.	Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
Manganese	This contaminant is treated for in the system due to a known exceedance at the wellhead. Treated levels are below the MCL.		This contaminant is treated for in the system.	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

About your Arsenic: The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

2024 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL HEAD of the FRANK C ALEGRE TRUCKING, INC water system in April, 2002.

Well Head - is considered most vulnerable to the following activities not associated with any detected contaminants:
Fleet/truck/bus terminals

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

A copy of the complete assessment may be viewed at:

San Joaquin County
Environmental Health Department
1868 E Hazelton Ave
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems
SJ Co Environmental Health Department
(209) 468-3420

Frank C Alegre Trucking Inc.

Analytical Results By FGL - 2024

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
Office Kitchen	STK2457828-1					2024-12-04	Absent		
Office Kitchen	STK2456318-1					2024-11-04	Absent		
Office Kitchen	STK2455462-1					2024-10-15	Absent		
Office Kitchen	STK2454306-1					2024-09-23	Absent		
Office Kitchen	STK2451712-1					2024-08-08	Absent		
Office Kitchen	STK2450658-1					2024-07-18	Absent		
Office Kitchen	STK2439285-1					2024-06-21	Absent		
Office Kitchen	STK2437080-1					2024-05-16	Absent		
Office Kitchen	STK2435474-1					2024-04-18	Absent		
Office Kitchen	STK2433997-1					2024-03-21	Absent		
Office Kitchen	STK2432383-1					2024-02-15	Absent		
Office Kitchen	STK2430623-1					2024-01-11	Absent		
Fecal coliform and E. coli			0		n/a			ND	-
Office Kitchen	STK2457828-1					2024-12-04	Absent		
Office Kitchen	STK2456318-1					2024-11-04	Absent		
Office Kitchen	STK2455462-1					2024-10-15	Absent		
Office Kitchen	STK2454306-1					2024-09-23	Absent		
Office Kitchen	STK2451712-1					2024-08-08	Absent		
Office Kitchen	STK2450658-1					2024-07-18	Absent		
Office Kitchen	STK2439285-1					2024-06-21	Absent		
Office Kitchen	STK2437080-1					2024-05-16	Absent		
Office Kitchen	STK2435474-1					2024-04-18	Absent		
Office Kitchen	STK2433997-1					2024-03-21	Absent		
Office Kitchen	STK2432383-1					2024-02-15	Absent		
Office Kitchen	STK2430623-1					2024-01-11	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
Kitchen Trailer	STK2239564-2	ug/L				2022-07-08	ND		
Main Office Kitchen	STK2239564-4	ug/L				2022-07-08	ND		
Main Office Mens	STK2239564-3	ug/L				2022-07-08	ND		
Safety Office	STK2239564-1	ug/L				2022-07-08	ND		
Trailer Bathroom	STK2239564-5	ug/L				2022-07-08	ND		
Copper		mg/L		1.3	.3			0	5
Kitchen Trailer	STK2239564-2	mg/L				2022-07-08	ND		
Main Office Kitchen	STK2239564-4	mg/L				2022-07-08	ND		
Main Office Mens	STK2239564-3	mg/L				2022-07-08	ND		
Safety Office	STK2239564-1	mg/L				2022-07-08	ND		
Trailer Bathroom	STK2239564-5	mg/L				2022-07-08	ND		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			21	18 - 23
Well Head	STK2455533-1	ug/L				2024-10-15	22		
Well Head	STK2450657-1	ug/L				2024-07-18	22		
Well Head	STK2435477-1	ug/L				2024-04-18	23		
Well Head	STK2430625-1	ug/L				2024-01-11	19		
WELL HEAD	STK2354321-1	ug/L				2023-10-12	22		
WELL HEAD	STK2338803-1	ug/L				2023-07-05	21		
WELL HEAD	STK2334276-1	ug/L				2023-04-07	18		

WELL HEAD	STK2330262-1	ug/L				2023-01-05	19		
Barium		mg/L	2	1	2			0.22	0.22 - 0.22
WELL HEAD	STK2234431-1	mg/L				2022-04-04	0.22		
Nitrate as N		mg/L		10	10			2.1	2.0 - 2.1
Well Head	STK2435477-1	mg/L				2024-04-18	2.1		
WELL HEAD	STK2334276-1	mg/L				2023-04-07	2.0		
Gross Alpha		pCi/L		15	(0)			7.47	7.47 - 7.47
WELL HEAD	STK1935556-1	pCi/L				2019-04-22	7.47		
Uranium		pCi/L		20	0.43			4.53	4.53 - 4.53
WELL HEAD	STK1935556-1	pCi/L				2019-04-22	4.53		

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			ND	ND - 4
TREATMENT	STK2457829-1	ug/L				2024-12-04	2		
TREATMENT	STK2456319-1	ug/L				2024-11-04	ND		
TREATMENT	STK2455535-1	ug/L				2024-10-15	3		
TREATMENT	STK2454307-1	ug/L				2024-09-23	ND		
TREATMENT	STK2451711-1	ug/L				2024-08-08	3		
TREATMENT	STK2450659-1	ug/L				2024-07-18	4		
TREATMENT	STK2439286-1	ug/L				2024-06-21	2		
TREATMENT	STK2437081-1	ug/L				2024-05-16	ND		
TREATMENT	STK2435476-1	ug/L				2024-04-18	ND		
TREATMENT	STK2433999-1	ug/L				2024-03-21	2		
TREATMENT	STK2432384-1	ug/L				2024-02-15	2		
TREATMENT	STK2430624-1	ug/L				2024-01-11	ND		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Manganese		ug/L		50	n/a			145	136 - 153
Well Head	STK2435477-1	ug/L				2024-04-18	136		
WELL HEAD	STK2334276-1	ug/L				2023-04-07	153		

TREATED SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Manganese		ug/L		50	n/a			ND	ND - ND
TREATMENT	STK2435476-1	ug/L				2024-04-18	ND		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ug/L		NS	n/a			9	9 - 9
WELL HEAD	STK2234431-1	ug/L				2022-04-04	9		
Manganese		ug/L		NS	n/a			145	136 - 153
Well Head	STK2435477-1	ug/L				2024-04-18	136		
WELL HEAD	STK2334276-1	ug/L				2023-04-07	153		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chlorine		mg/L		4.0	4.0			0.00	ND -
Well Head	STK2457828-2	mg/L				2024-12-04	ND		
Well Head	STK2456318-2	mg/L				2024-11-04	ND		
Well Head	STK2455462-2	mg/L				2024-10-15	ND		
Well Head	STK2454306-2	mg/L				2024-09-23	ND		
Well Head	STK2451712-2	mg/L				2024-08-08	ND		
Well Head	STK2450658-2	mg/L				2024-07-18	ND		

Frank C Alegre Trucking Inc.

CCR Login Linkage - 2024

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
KitTrailer	STK2239564-2	2022-07-08	Metals, Total	Kitchen Trailer	Cu & Pb Monitoring
Off Kit	STK2239564-4	2022-07-08	Metals, Total	Main Office Kitchen	Cu & Pb Monitoring
Main Off Mens	STK2239564-3	2022-07-08	Metals, Total	Main Office Mens	Cu & Pb Monitoring
Bacti-Rout-ss01	STK2430623-1	2024-01-11	Coliform	Office Kitchen	Bacteriological Sampling
	STK2430623-1	2024-01-11	Field Test	Office Kitchen	Bacteriological Sampling
	STK2432383-1	2024-02-15	Coliform	Office Kitchen	Bacteriological Sampling
	STK2432383-1	2024-02-15	Field Test	Office Kitchen	Bacteriological Sampling
	STK2433997-1	2024-03-21	Coliform	Office Kitchen	Bacteriological Sampling
	STK2433997-1	2024-03-21	Field Test	Office Kitchen	Bacteriological Sampling
	STK2435474-1	2024-04-18	Field Test	Office Kitchen	Bacteriological Sampling
	STK2435474-1	2024-04-18	Coliform	Office Kitchen	Bacteriological Sampling
	STK2437080-1	2024-05-16	Field Test	Office Kitchen	Bacteriological Sampling
	STK2437080-1	2024-05-16	Coliform	Office Kitchen	Bacteriological Sampling
	STK2439285-1	2024-06-21	Coliform	Office Kitchen	Bacteriological Sampling
	STK2439285-1	2024-06-21	Field Test	Office Kitchen	Bacteriological Sampling
	STK2450658-1	2024-07-18	Field Test	Office Kitchen	Bacteriological Sampling
	STK2450658-1	2024-07-18	Coliform	Office Kitchen	Bacteriological Sampling
	STK2451712-1	2024-08-08	Field Test	Office Kitchen	Bacteriological Sampling
	STK2451712-1	2024-08-08	Coliform	Office Kitchen	Bacteriological Sampling
	STK2454306-1	2024-09-23	Field Test	Office Kitchen	Bacteriological Sampling
	STK2454306-1	2024-09-23	Coliform	Office Kitchen	Bacteriological Sampling
	STK2455462-1	2024-10-15	Coliform	Office Kitchen	Bacteriological Sampling
	STK2455462-1	2024-10-15	Field Test	Office Kitchen	Bacteriological Sampling
	STK2456318-1	2024-11-04	Field Test	Office Kitchen	Bacteriological Sampling
	STK2456318-1	2024-11-04	Coliform	Office Kitchen	Bacteriological Sampling
	STK2457828-1	2024-12-04	Coliform	Office Kitchen	Bacteriological Sampling
	STK2457828-1	2024-12-04	Field Test	Office Kitchen	Bacteriological Sampling
Safety Off	STK2239564-1	2022-07-08	Metals, Total	Safety Office	Cu & Pb Monitoring
Trailer BathRm	STK2239564-5	2022-07-08	Metals, Total	Trailer Bathroom	Cu & Pb Monitoring
AsTrtmnt-ss01	STK2430624-1	2024-01-11	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2430624-1	2024-01-11	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2432384-1	2024-02-15	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2432384-1	2024-02-15	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2433999-1	2024-03-21	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2433999-1	2024-03-21	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2435476-1	2024-04-18	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2435476-1	2024-04-18	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2437081-1	2024-05-16	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2437081-1	2024-05-16	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2439286-1	2024-06-21	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2439286-1	2024-06-21	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2450659-1	2024-07-18	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2450659-1	2024-07-18	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2451711-1	2024-08-08	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2451711-1	2024-08-08	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2454307-1	2024-09-23	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2454307-1	2024-09-23	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2455535-1	2024-10-15	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2455535-1	2024-10-15	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2456319-1	2024-11-04	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
	STK2456319-1	2024-11-04	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2457829-1	2024-12-04	Field Test	TREATMENT	Arsenic Treatment Monitoring
	STK2457829-1	2024-12-04	Metals, Total	TREATMENT	Arsenic Treatment Monitoring
WELL HEAD	STK1935556-1	2019-04-22	Radio Chemistry	WELL HEAD	Water Quality - Radio
	STK2234431-1	2022-04-04	Metals, Total	WELL HEAD	Water Quality Monitoring
	STK2330262-1	2023-01-05	Metals, Total	WELL HEAD	Water Quality Monitoring

	STK2334276-1	2023-04-07	Metals, Total	WELL HEAD	Water Quality Monitoring
	STK2334276-1	2023-04-07	Wet Chemistry	WELL HEAD	Water Quality Monitoring
	STK2338803-1	2023-07-05	Metals, Total	WELL HEAD	Water Quality Monitoring
	STK2354321-1	2023-10-12	Metals, Total	WELL HEAD	Water Quality Monitoring
	STK2430625-1	2024-01-11	Metals, Total	Well Head	Water Quality Monitoring
	STK2430623-2	2024-01-11	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2432383-2	2024-02-15	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2433997-2	2024-03-21	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2435477-1	2024-04-18	Metals, Total	Well Head	Water Quality Monitoring
	STK2435477-1	2024-04-18	Wet Chemistry	Well Head	Water Quality Monitoring
	STK2435474-2	2024-04-18	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2437080-2	2024-05-16	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2439285-2	2024-06-21	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2450657-1	2024-07-18	Metals, Total	Well Head	Water Quality Monitoring
	STK2450658-2	2024-07-18	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2451712-2	2024-08-08	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2454306-2	2024-09-23	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2455533-1	2024-10-15	Metals, Total	Well Head	Water Quality Monitoring
	STK2455462-2	2024-10-15	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2456318-2	2024-11-04	Field Test	Well Head	Bacteriological Sampling - Odd
	STK2457828-2	2024-12-04	Field Test	Well Head	Bacteriological Sampling - Odd