

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at [http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>MORADA PRODUCE</b>
Water System Number:	<b>CA3901425</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Kristi Friis	
	Signature:	<i>Kristi Friis</i>	
	Title:	Compliance Manager	
	Phone Number:	( 209 ) 815-6375	Date: 2-28-25

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

---

---

- ☒ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> \_\_\_\_\_
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☒ Posted the CCR in public places (attach a list of locations) Front Office
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

# 2024 Consumer Confidence Report

Water System Name: MORADA PRODUCE Report Date: February 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** This info is not available, please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

**Your water comes from 1 source(s):** Well #3

**Opportunities for public participation in decisions that affect drinking water quality:** Notification of meetings are conducted by postings, email, radio and word of mouth.

For more information about this report, or any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service, Inc..

TERMS USED IN THIS REPORT	
<b>Maximum Contaminant Level (MCL):</b> The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.	<b>Secondary Drinking Water Standards (SDWS):</b> MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
<b>Maximum Contaminant Level Goal (MCLG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).	<b>Treatment Technique (TT):</b> A required process intended to reduce the level of a contaminant in drinking water.
<b>Public Health Goal (PHG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.	<b>Regulatory Action Level (AL):</b> The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
<b>Maximum Residual Disinfectant Level (MRDL):</b> The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.	<b>Level 1 Assessment:</b> A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
<b>Maximum Residual Disinfectant Level Goal (MRDLG):</b> The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.	<b>Level 2 Assessment:</b> A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
<b>Primary Drinking Water Standards (PDWS):</b> MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.	<b>ND:</b> not detectable at testing limit
	<b>mg/L:</b> milligrams per liter or parts per million (ppm)
	<b>ug/L:</b> micrograms per liter or parts per billion (ppb)
	<b>pCi/L:</b> picocuries per liter (a measure of radiation)
	<b>NTU:</b> Nephelometric Turbidity Units
	<b>umhos/cm:</b> micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

## Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Table(s) 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2024)	5	0	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021)	16	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021)	59.6	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2021 - 2024)	6	5 - 6	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Fluoride (mg/L)	(2021)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate as N (mg/L)	(2023 - 2024)	0.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2021)	0.4	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2023)	ND	ND - 1.22	15	(0)	Erosion of natural deposits.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2021)	6	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2021)	5	n/a	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2021)	110	n/a	300	n/a	Leaching from natural deposits; Industrial wastes
Odor Threshold at 60 °C (TON)	(2021)	1	n/a	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2021)	213	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021)	7.8	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021)	170	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2021)	6.4	n/a	5	n/a	Soil runoff

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ug/L)	(2021 - 2024)	13	12 - 14	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 6 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2021)	14	n/a	n/a	n/a
Magnesium (mg/L)	(2021)	6	n/a	n/a	n/a
pH (units)	(2021)	4.1	n/a	n/a	n/a
Alkalinity (mg/L)	(2021)	80	n/a	n/a	n/a
Aggressiveness Index	(2021)	11.5	n/a	n/a	n/a
Langelier Index	(2021)	-0.3	n/a	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine, Total (mg/L)	(2022)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More

information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Morada Produce WS* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

**Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Turbidity				Turbidity is Secondary Drinking Water Standards and has found no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

**About your Arsenic:** For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**2024 Consumer Confidence Report  
Drinking Water Assessment Information**

**Assessment Information**

A Source Water Assessment has not been completed for the source WELL#3 of the MORADA PERODUCE WATER

SYSTEM water system.

Well #3 - does not have a completed Source Water Assessment on file.

### **Discussion of Vulnerability**

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

### **Acquiring Information**

For more info you may visit [https://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/DWSAP.html](https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html) or contact the health department in the county to which the water system belongs as indicated on this following link: [https://www.waterboards.ca.gov/drinking\\_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf](https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf)

# Morada Produce WS

## Analytical Results By FGL - 2024

MICROBIOLOGICAL CONTAMINANTS								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Total Coliform Bacteria</b>			0	5%	n/a			ND -
NE Corner of New Bldg.	STK2457808-1					2024-12-05	Absent	
NE Corner of New Bldg.	STK2456638-1					2024-11-11	Absent	
NE Corner of New Bldg.	STK2455096-1					2024-10-09	Absent	
NE Corner of New Bldg.	STK2454062-1					2024-09-19	Absent	
NE Corner of New Bldg.	STK2451824-1					2024-08-13	Absent	
NE Corner of New Bldg.	STK2450580-1					2024-07-17	Absent	
NE Corner of New Bldg.	STK2438687-1					2024-06-13	Absent	
NE Corner of New Bldg.	STK2437062-1					2024-05-16	Absent	
NE Corner of New Bldg.	STK2435288-1					2024-04-17	Absent	
NE Corner of New Bldg.	STK2433069-1					2024-03-05	Absent	
NE Corner of New Bldg.	STK2432191-1					2024-02-19	Absent	
NE Corner of New Bldg.	STK2431068-1					2024-01-23	Absent	
<b>Fecal coliform and E. coli</b>			0	n/a				ND -
NE Corner of New Bldg.	STK2457808-1					2024-12-05	Absent	
NE Corner of New Bldg.	STK2456638-1					2024-11-11	Absent	
NE Corner of New Bldg.	STK2455096-1					2024-10-09	Absent	
NE Corner of New Bldg.	STK2454062-1					2024-09-19	Absent	
NE Corner of New Bldg.	STK2451824-1					2024-08-13	Absent	
NE Corner of New Bldg.	STK2450580-1					2024-07-17	Absent	
NE Corner of New Bldg.	STK2438687-1					2024-06-13	Absent	
NE Corner of New Bldg.	STK2437062-1					2024-05-16	Absent	
NE Corner of New Bldg.	STK2435288-1					2024-04-17	Absent	
NE Corner of New Bldg.	STK2433069-1					2024-03-05	Absent	
NE Corner of New Bldg.	STK2432191-1					2024-02-19	Absent	
NE Corner of New Bldg.	STK2431068-1					2024-01-23	Absent	

LEAD AND COPPER RULE								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile # Samples
<b>Lead</b>		ug/L	0	15	0.2			0 5
Main Kitchen Office	STK2450918-1	ug/L				2024-07-17	ND	
Onion Bathroom	STK2450918-5	ug/L				2024-07-17	ND	
Receiving Office Kitchen Sink	STK2450918-3	ug/L				2024-07-17	ND	
Restroom	STK2450918-2	ug/L				2024-07-17	ND	
Trucker's Lounge Kitchen Sink	STK2450918-4	ug/L				2024-07-17	ND	
<b>Copper</b>		mg/L		1.3	.3			0 5
Main Kitchen Office	STK2450918-1	mg/L				2024-07-17	ND	
Onion Bathroom	STK2450918-5	mg/L				2024-07-17	ND	
Receiving Office Kitchen Sink	STK2450918-3	mg/L				2024-07-17	ND	
Restroom	STK2450918-2	mg/L				2024-07-17	ND	
Trucker's Lounge Kitchen Sink	STK2450918-4	mg/L				2024-07-17	ND	

SAMPLING RESULTS FOR SODIUM AND HARDNESS								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
<b>Sodium</b>		mg/L		none	none			16 16 - 16
WELL #3	STK2154748-1	mg/L				2021-10-12	16	
<b>Hardness</b>		mg/L		none	none			59.6 59.6 - 59.6
WELL #3	STK2154748-1	mg/L				2021-10-12	59.6	

PRIMARY DRINKING WATER STANDARDS (PDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)

<b>Arsenic</b>		ug/L		10	0.004			6	5 - 6
Well #3	STK2437061-1	ug/L				2024-05-16	6		
WELL #3	STK2154748-1	ug/L				2021-10-12	5		
<b>Fluoride</b>		mg/L		2	1			0.1	0.1 - 0.1
WELL #3	STK2154748-1	mg/L				2021-10-12	0.1		
<b>Nitrate as N</b>		mg/L		10	10			0.5	0.5 - 0.5
Well #3	STK2437061-1	mg/L				2024-05-16	0.5		
WELL #3	STK2336150-1	mg/L				2023-05-12	0.5		
<b>Nitrate + Nitrite as N</b>		mg/L		10	10			0.4	0.4 - 0.4
WELL #3	STK2154748-1	mg/L				2021-10-12	0.4		
<b>Gross Alpha</b>		pCi/L		15	(0)			ND	ND - 1.22
WELL #3	STK2355960-1	pCi/L				2023-11-21	ND		
WELL #3	STK2351110-1	pCi/L				2023-08-15	1.22		
WELL #3	STK2336148-1	pCi/L				2023-05-12	ND		
WELL #3	STK2333494-1	pCi/L				2023-03-20	ND		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			6	6 - 6
WELL #3	STK2154748-1	mg/L				2021-10-12	6		
<b>Color</b>		Units		15	n/a			5	5 - 5
WELL #3	STK2154748-1	Units				2021-10-12	5		
<b>Iron</b>		ug/L		300	n/a			110	110 - 110
WELL #3	STK2154748-1	ug/L				2021-10-12	110		
<b>Odor Threshold at 60 °C</b>		TON		3	n/a			1	1 - 1
WELL #3	STK2154748-1	TON				2021-10-12	1		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			213	213 - 213
WELL #3	STK2154748-1	umhos/cm				2021-10-12	213		
<b>Sulfate</b>		mg/L		500	n/a			7.8	7.8 - 7.8
WELL #3	STK2154748-1	mg/L				2021-10-12	7.8		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			170	170 - 170
WELL #3	STK2154748-1	mg/L				2021-10-12	170		
<b>Turbidity</b>		NTU		5	n/a			6.4	6.4 - 6.4
WELL #3	STK2154748-1	NTU				2021-10-12	6.4		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Vanadium</b>		ug/L		NS	n/a			13	12 - 14
Well #3	STK2437061-1	ug/L				2024-05-16	14		
WELL #3	STK2154748-1	ug/L				2021-10-12	12		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			14	14 - 14
WELL #3	STK2154748-1	mg/L				2021-10-12	14		
<b>Magnesium</b>		mg/L			n/a			6	6 - 6
WELL #3	STK2154748-1	mg/L				2021-10-12	6		
<b>pH</b>		units			n/a			4.1	8.1 - 8.1
WELL #3	STK2154748-1	units				2021-10-12	8.1		
WELL #3	STK2154748-1	units				2021-10-12			
<b>Alkalinity</b>		mg/L			n/a			80	80 - 80
WELL #3	STK2154748-1	mg/L				2021-10-12	80		
<b>Aggressiveness Index</b>					n/a			11.5	11.5 - 11.5
WELL #3	STK2154748-1					2021-10-12	11.5		
<b>Langelier Index</b>					n/a			-0.3	-0.3 - -0.3
WELL #3	STK2154748-1					2021-10-12	-0.3		



[illegible]

# Morada Produce WS

## CCR Login Linkage - 2024

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Lead Copper Mor	STK2450918-1	2024-07-17	Metals, Total	Main Kitchen Office	MORADA PRODUCE
NE Corner	STK2431068-1	2024-01-23	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2432191-1	2024-02-19	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2433069-1	2024-03-05	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2435288-1	2024-04-17	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2437062-1	2024-05-16	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2438687-1	2024-06-13	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2450580-1	2024-07-17	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2451824-1	2024-08-13	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2454062-1	2024-09-19	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2455096-1	2024-10-09	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2456638-1	2024-11-11	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
	STK2457808-1	2024-12-05	Coliform	NE Corner of New Bldg.	Bacteriological Monitoring
Lead Copper Mor	STK2450918-5	2024-07-17	Metals, Total	Onion Bathroom	MORADA PRODUCE
	STK2450918-3	2024-07-17	Metals, Total	Receiving Office Kitchen Sink	MORADA PRODUCE
	STK2450918-2	2024-07-17	Metals, Total	Restroom	MORADA PRODUCE
	STK2450918-4	2024-07-17	Metals, Total	Trucker's Lounge Kitchen Sink	MORADA PRODUCE
Well #3	STK2154748-1	2021-10-12		WELL #3	Well #3 - Water Quality
	STK2154748-1	2021-10-12	Metals, Total	WELL #3	Well #3 - Water Quality
	STK2154748-1	2021-10-12	Wet Chemistry	WELL #3	Well #3 - Water Quality
	STK2154748-1	2021-10-12	General Mineral	WELL #3	Well #3 - Water Quality
	STK2234018-1	2022-03-24	Field Test	WELL #3	MORADA PRODUCE
	STK2234299-1	2022-03-31	Field Test	WELL #3	MORADA PRODUCE
	STK2237246-1	2022-05-24		WELL #3	Well #3 SOC Monitoring
	STK2333494-1	2023-03-20	Radio Chemistry	WELL #3	Well #3 - Radiological Monitoring
	STK2336150-1	2023-05-12	Wet Chemistry	WELL #3	Well #3 - Water Quality
	STK2336148-1	2023-05-12	Radio Chemistry	WELL #3	Well #3 - Radiological Monitoring
	STK2351110-1	2023-08-15	Radio Chemistry	WELL #3	Well #3 - Radiological Monitoring
	STK2355960-1	2023-11-21	Radio Chemistry	WELL #3	Well #3 - Radiological Monitoring
	STK2437061-1	2024-05-16	Metals, Total	Well #3	Well #3 - Water Quality
	STK2437061-1	2024-05-16	Wet Chemistry	Well #3	Well #3 - Water Quality