

**2020 Consumer Confidence Report
Certification Form**
(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: Heskett, Joe Water System
Water System Number: 3901474

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 7/21/21 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Jessica Nobles
Signature: Jessica Nobles
Title: Bookkeeper / Limited Partner
Phone Number: (209) 594-0091 Date: 7/21/21

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: Hand-delivered

☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- ☐ Posting the CCR on the Internet at www.
- ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertising the availability of the CCR in news media (attach copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools.
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly accessible internet site at the following address: www.

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).

2020 Consumer Confidence Report

Water System Name: HESKETT, JOE WATER SYSTEM

Report Date: July 2021

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Type of water source(s) in use: This information is not available, please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 1 source(s): WELL

Opportunities for public participation in decisions that affect drinking water quality: Monthly information meetings are not being scheduled at this time.

For more information about this report, or any questions relating to your drinking water, please call (209) 838 - 8742 and ask for Quality Service Inc..

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	4/mo. (2020)	2	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2020)	39	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2020)	349	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2020)	3	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2020)	0.29	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits

Hexavalent Chromium (ug/L)	(2014)	2.4	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2020)	10.1	9.6 - 11.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2020)	10.5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2020)	5.22	n/a	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2020)	4.04	n/a	20	0.43	Erosion of natural deposits

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2020)	34	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2020)	950	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2020)	33.9	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2020)	590	n/a	1000	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2020)	0.1	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2020)	79	n/a	n/a	n/a
Magnesium (mg/L)	(2020)	37	n/a	n/a	n/a
pH (units)	(2020)	7.4	n/a	n/a	n/a
Alkalinity (mg/L)	(2020)	360	n/a	n/a	n/a
Aggressiveness Index	(2020)	12.3	n/a	n/a	n/a
Langelier Index	(2020)	0.4	n/a	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2020)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Joe Heskett Water System* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Nitrate as N				Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of Pregnant women.
Nitrate + Nitrite as N				Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of Pregnant women.

About your Nitrate as N: Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

2020 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A Source Water Assessment has not been completed for the WELL 01 of the JOE HESKETT WATER SYSTEM water system.

WELL - does not have a completed a Source Water Assessment on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- ☐ The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- ☐ The source is not active. It may be out of service, or new and not yet in service.
- ☐ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

Joe Heskett Water System

Analytical Results By FGL - 2020

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			2	2 - 45.3
After Pressure Tank	STK2035005-3					2020-04-15	<1.0		
After Pressure Tank	STK2032554-4					2020-02-20	<1.0		
After Pressure Tank	STK2032093-3					2020-02-11	7.5		
After Pressure Tank	STK2031938-2					2020-02-07	<1.0		
After Pressure Tank	STK2031167-3					2020-01-22	9.9		
HB @ Pressure Tank	STK2032294-3					2020-02-14	<1.0		
HB S/S 3979	STK2056297-1					2020-11-19	Absent		
HB S/S 3979	STK2052915-1					2020-09-09	Absent		
HB S/S 3979	STK2050118-1					2020-07-21	Absent		
HB S/S 3979	STK2036906-1					2020-05-19	Absent		
HB S/S 3979	STK2035005-1					2020-04-15	<1.0		
HB S/S 3979	STK2033641-1					2020-03-17	Absent		
HB S/S 3979	STK2032554-3					2020-02-20	<1.0		
HB S/S 3979	STK2032294-2					2020-02-14	<1.0		
HB S/S 3979	STK2032093-1					2020-02-11	3.1		
HB S/S 3979	STK2031938-3					2020-02-07	2		
HB S/S 3979	STK2031167-1					2020-01-22	5.3		
HB S/S 3979	STK2030856-1					2020-01-20	Present		
HB S/S 3991	STK2057139-1					2020-12-09	Absent		
HB S/S 3991	STK2055166-1					2020-10-26	Absent		
HB S/S 3991	STK2052019-1					2020-08-20	Absent		
HB S/S 3991	STK2038101-1					2020-06-10	Absent		
HB S/S 3991	STK2035297-1					2020-04-21	Absent		
HB S/S 3991	STK2035005-2					2020-04-15	<1.0		
HB S/S 3991	STK2032554-1					2020-02-20	<1.0		
HB S/S 3991	STK2032554-2					2020-02-20	<1.0		
HB S/S 3991	STK2032294-1					2020-02-14	<1.0		
HB S/S 3991	STK2032093-2					2020-02-11	4.2		
HB S/S 3991	STK2031938-4					2020-02-07	<1.0		
HB S/S 3991	STK2031167-2					2020-01-22	45.3		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			39	39 - 39
WELL	STK2033642-1	mg/L				2020-03-17	39		
Hardness		mg/L		none	none			349	349 - 349
WELL	STK2033642-1	mg/L				2020-03-17	349		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			3	3 - 3
WELL	STK2033642-1	ug/L				2020-03-17	3		
Barium		mg/L	2	1	2			0.29	0.29 - 0.29
WELL	STK2033642-1	mg/L				2020-03-17	0.29		
Hexavalent Chromium		ug/L			0.02			2.4	2.4 - 2.4
WELL	STK1451782-1	ug/L				2014-11-18	2.4		
Nitrate as N		mg/L		10	10			10.1	9.6 - 11.0
WELL	STK2056517-1	mg/L				2020-11-24	9.6		
WELL	STK2056296-1	mg/L				2020-11-19	11.0		
WELL	STK2052020-1	mg/L				2020-08-20	9.6		

WELL	STK2036908-1	mg/L				2020-05-19	9.7		
WELL	STK2033642-1	mg/L				2020-03-17	10.5		
Nitrate + Nitrite as N		mg/L		10	10			10.5	10.5 - 10.5
WELL	STK2033642-1	mg/L				2020-03-17	10.5		
Gross Alpha		pCi/L		15	(0)			5.22	5.22 - 5.22
WELL	STK2036907-1	pCi/L				2020-05-19	5.22		
Uranium		pCi/L		20	0.43			4.04	4.04 - 4.04
WELL	STK2036907-1	pCi/L				2020-05-19	4.04		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			34	34 - 34
WELL	STK2033642-1	mg/L				2020-03-17	34		
Specific Conductance		umhos/cm		1600	n/a			950	950 - 950
WELL	STK2033642-1	umhos/cm				2020-03-17	950		
Sulfate		mg/L		500	n/a			33.9	33.9 - 33.9
WELL	STK2033642-1	mg/L				2020-03-17	33.9		
Total Dissolved Solids		mg/L		1000	n/a			590	590 - 590
WELL	STK2033642-1	mg/L				2020-03-17	590		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.1	0.1 - 0.1
WELL	STK2033642-1	mg/L				2020-03-17	0.1		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			79	79 - 79
WELL	STK2033642-1	mg/L				2020-03-17	79		
Magnesium		mg/L			n/a			37	37 - 37
WELL	STK2033642-1	mg/L				2020-03-17	37		
pH		units			n/a			7.4	7.4 - 7.4
WELL	STK2033642-1	units				2020-03-17	7.4		
Alkalinity		mg/L			n/a			360	360 - 360
WELL	STK2033642-1	mg/L				2020-03-17	360		
Aggressiveness Index					n/a			12.3	12.3 - 12.3
WELL	STK2033642-1					2020-03-17	12.3		
Langeller Index					n/a			0.4	0.4 - 0.4
WELL	STK2033642-1					2020-03-17	0.4		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chlorine		mg/L		4.0	4.0			0.00	ND -
WELL	STK2035005-4	mg/L				2020-04-15	ND		
WELL	STK2032554-5	mg/L				2020-02-20	ND		
WELL	STK2032294-4	mg/L				2020-02-14	ND		
Average WELL								0	
Well	STK2032093-4	mg/L				2020-02-11	ND		
Average Well								0	
WELL	STK2031938-1	mg/L				2020-02-07	ND		
WELL	STK2031167-4	mg/L				2020-01-22	ND		
Average WELL								0	

Joe Heskett Water System

CCR Login Linkage - 2020

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
HB@PressTank	STK2031167-3	2020-01-22	Coliform	After Pressure Tank	Bacti Monitoring
	STK2031938-2	2020-02-07	Coliform	After Pressure Tank	Bacti Monitoring
After P/T	STK2032093-3	2020-02-11	Coliform	After Pressure Tank	Water System Monitoring
After Pressure	STK2032554-4	2020-02-20	Coliform	After Pressure Tank	Water System Monitoring-Even
	STK2035005-3	2020-04-15	Coliform	After Pressure Tank	Pressure Loss
HB@PressTank	STK2032294-3	2020-02-14	Coliform	HB @ Pressure Tank	Bacti Monitoring
HBSS 3979	STK2030856-1	2020-01-20	Coliform	HB S/S 3979	Water System Monitoring-Odd
	STK2031167-1	2020-01-22	Coliform	HB S/S 3979	Water System Monitoring-Odd
Southside of 39	STK2031938-3	2020-02-07	Coliform	HB S/S 3979	Bacti Monitoring
HBSS 3979	STK2032093-1	2020-02-11	Coliform	HB S/S 3979	Water System Monitoring
Southside SS 39	STK2032294-2	2020-02-14	Coliform	HB S/S 3979	Water System Monitoring
HBSS 3979	STK2032554-3	2020-02-20	Coliform	HB S/S 3979	Water System Monitoring-Odd
	STK2033641-1	2020-03-17	Coliform	HB S/S 3979	Water System Monitoring-Odd
	STK2035005-1	2020-04-15	Coliform	HB S/S 3979	Pressure Loss
	STK2036906-1	2020-05-19	Coliform	HB S/S 3979	Water System Monitoring-Odd
	STK2050118-1	2020-07-21	Coliform	HB S/S 3979	Water System Monitoring-Odd
	STK2052915-1	2020-09-09	Coliform	HB S/S 3979	Water System Monitoring-Odd
	STK2056297-1	2020-11-19	Coliform	HB S/S 3979	Water System Monitoring-Odd
HBSS 3991	STK2031167-2	2020-01-22	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2031938-4	2020-02-07	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2032093-2	2020-02-11	Coliform	HB S/S 3991	Water System Monitoring
	STK2032294-1	2020-02-14	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2032554-1	2020-02-20	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2032554-2	2020-02-20	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2035005-2	2020-04-15	Coliform	HB S/S 3991	Pressure Loss
	STK2035297-1	2020-04-21	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2038101-1	2020-06-10	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2052019-1	2020-08-20	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2055166-1	2020-10-26	Coliform	HB S/S 3991	Water System Monitoring-Even
	STK2057139-1	2020-12-09	Coliform	HB S/S 3991	Water System Monitoring-Even
Well 01	STK1451782-1	2014-11-18	Wet Chemistry	WELL	Chrome 6 Monitoring
	STK2031167-4	2020-01-22	Field Test	WELL	HESKETT, JOE WATER SYSTEM
	STK2031938-1	2020-02-07	Field Test	WELL	HESKETT, JOE WATER SYSTEM
Well	STK2032093-4	2020-02-11	Field Test	Well	Water System Monitoring
Well 01	STK2032294-4	2020-02-14	Field Test	WELL	HESKETT, JOE WATER SYSTEM
	STK2032554-5	2020-02-20	Field Test	WELL	Water System Monitoring-Even
	STK2033642-1	2020-03-17	General Mineral	WELL	Water Quality Monitoring
	STK2033642-1	2020-03-17	Metals, Total	WELL	Water Quality Monitoring
	STK2035005-4	2020-04-15	Field Test	WELL	Pressure Loss
	STK2036908-1	2020-05-19	Wet Chemistry	WELL	Water Quality Monitoring
	STK2036907-1	2020-05-19	Radio Chemistry	WELL	Radio Monitoring
	STK2052020-1	2020-08-20	Wet Chemistry	WELL	Water Quality Monitoring
	STK2056296-1	2020-11-19	Wet Chemistry	WELL	Water Quality Monitoring
	STK2056517-1	2020-11-24	Wet Chemistry	WELL	Water Quality Monitoring