


Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	PICK N PULL AUTO DISMANTLERS
Water System Number:	3901481

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 06/29/2021 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Mohamed Ibrahim	
	Signature:		
	Title:	Regional Environmental Manager	
	Phone Number:	(916)223-3428	Date: 6/29/2021

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:
Reports will be posted in common areas. At a minimum, notification will be posted in the break room and common office area. Electronic copies were also provided via email. Information was also reviewed during staff meeting.

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://> _____
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2020 Consumer Confidence Report

Water System Name: PICK N PULL AUTO DISMANTLERS

Report Date: June 2021

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Information regarding the type of water source in use is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 2 source(s): Well #3 and Well #4

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are currently not held.

For more information about this report, or any questions relating to your drinking water, please call (209 - 838 - 7842 and ask for Quality Service, Inc..

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2 and 3 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2020)	7	6 - 8	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2020)	0.16	0.12 - 0.20	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Hexavalent Chromium (ug/L)	(2014)	3.5	1.0 - 5.9		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2020)	7.9	4.0 - 10.4	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 2 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2015)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Pick-N-Pull* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About your Arsenic: For Arsenic detected above 5 ug/L (50% of the MCL) but below 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

About your Nitrate as N: Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

2020 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment has not been completed for the WELL #3 and WELL #4 of the PICK N PULL AUTO DISMANTLERS water system.

Well #3 - does not have a completed assessment on file.

Well #4 - does not have a completed assessment on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local DDW district office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

Pick-N-Pull

CCR Login Linkage - 2020

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Rout-Odd	STK1830312-1	2018-01-05	Sampling	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1832792-1	2018-03-06	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1832792-1	2018-03-06	Sampling	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1930418-1	2019-01-09	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1932958-1	2019-03-04	Sampling	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1932958-1	2019-03-04	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1936346-1	2019-05-08	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1953248-1	2019-09-05	Sampling	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1953248-1	2019-09-05	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1956552-1	2019-11-07	Sampling	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK1956552-1	2019-11-07	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK2030135-1	2020-01-06	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK2033034-1	2020-03-04	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK2036073-1	2020-05-06	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK2039435-1	2020-07-08	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK2052817-1	2020-09-08	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
	STK2055521-1	2020-11-03	Coliform	HB East Side of Main Office	Bacteriological Monitoring-Odd
Bacti-Rout-Even	STK1831565-1	2018-02-06	Sampling	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1834210-1	2018-04-03	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1931653-1	2019-02-04	Sampling	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1934297-1	2019-04-01	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1938067-1	2019-06-05	Sampling	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1938067-1	2019-06-05	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1951574-1	2019-08-07	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1951574-1	2019-08-07	Sampling	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1957890-1	2019-12-05	Sampling	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK1957890-1	2019-12-05	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK2031701-1	2020-02-04	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK2034536-1	2020-04-07	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK2037472-1	2020-06-01	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK2050967-1	2020-08-04	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK2054902-1	2020-10-19	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
	STK2056737-1	2020-12-02	Coliform	HB West Side of Main Office	Bacteriological Monitoring-Even
CuPb-ss02	STK1850261-2	2018-07-17	Metals, Total	Main Kitchen Sink	Copper & Lead Monitoring
CuPb-ss03	STK1850261-1	2018-07-17	Metals, Total	Main Office Bathroom	Copper & Lead Monitoring
CuPb-ss04	STK1850261-3	2018-07-17	Metals, Total	Main Office Outside RR	Copper & Lead Monitoring
CuPb-ss05	STK1850261-5	2018-07-17	Metals, Total	Office Shower Head	Copper & Lead Monitoring
CuPb-ss08	STK1850261-4	2018-07-17	Metals, Total	Shop North Wall	Copper & Lead Monitoring
WELL#3	STK1452040-1	2014-11-25	Wet Chemistry	Well #3	Chrome 6 Monitoring
	STK1538184-4	2015-07-27	Field Test	Well #3	Pick-N-Pull
WELL 03	STK1831566-1	2018-02-06	SRL 524M-TCP	Well #3	TCP Monitoring
	STK1938066-1	2019-06-05	Wet Chemistry	Well #3	Well 3 - Water Quality
	STK1939330-1	2019-06-26	Wet Chemistry	Well #3	Fluoride Monitoring
	STK2037247-1	2020-06-01	Wet Chemistry	Well #3	Well 3 - Water Quality
	STK2037247-1	2020-06-01	Metals, Total	Well #3	Well 3 - Water Quality
WELL#4	STK1452040-2	2014-11-25	Wet Chemistry	Well #4	Chrome 6 Monitoring
	STK1538184-5	2015-07-27	Field Test	Well #4	Pick-N-Pull
WELL 04	STK1832793-1	2018-03-06	Wet Chemistry	Well #4	Well 4 - Water Quality
	STK1932957-1	2019-03-04	Wet Chemistry	Well #4	Well 4 - Water Quality
	STK1938065-1	2019-06-05	Wet Chemistry	Well #4	Well 4 - Water Quality
	STK1939330-2	2019-06-26	Wet Chemistry	Well #4	Fluoride Monitoring
	STK1951612-1	2019-08-08	Wet Chemistry	Well #4	Well 4 - Water Quality
	STK1956553-1	2019-11-07	Wet Chemistry	Well #4	Well 4 - Water Quality
	STK2031700-1	2020-02-04	Wet Chemistry	Well #4	Well 4 - Water Quality
	STK2036074-1	2020-05-06	Wet Chemistry	Well #4	Well 4 - Water Quality

	STK2036074-1	2020-05-06	Metals, Total	Well #4	Well 4 - Water Quality
	STK2050966-1	2020-08-04	Wet Chemistry	Well #4	Well 4 - Water Quality
	STK2052012-1	2020-08-21	Wet Chemistry	Well #4	PICK N PULL AUTO DISMANTLERS
	STK2055520-1	2020-11-03	Wet Chemistry	Well #4	Well 4 - Water Quality