

2023 Consumer Confidence Report

Water System Name: GICO MANAGEMENT & WATER SYSTEM

Report Date: May 2024

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Information regarding the type of water source in use is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 1 source(s): WELL #2

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (209)838-7842 and ask for Quality Service, Inc..

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	8/year (2023)	1	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2015)	54	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	63	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2023)	11	11 - 12	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Fluoride (mg/L)	(2021)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Hexavalent Chromium (ug/L)	(2021)	7.9	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2023)	2.2	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2015)	1.2	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2021)	2.28	1.89 - 2.78	15	(0)	Erosion of natural deposits.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2015)	56	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2015)	444	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2015)	10	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2015)	300	n/a	1000	n/a	Runoff/leaching from natural deposits

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2015)	0.2	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (ug/L)	(2022)	58	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.
Manganese (ug/L)	(2022)	0.8	n/a	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

Table 6 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022)	17	n/a	n/a	n/a
Magnesium (mg/L)	(2022)	5	n/a	n/a	n/a
pH (units)	(2022)	7.9	n/a	n/a	n/a
Alkalinity (mg/L)	(2022)	120	n/a	n/a	n/a
Aggressiveness Index	(2015)	11.6	n/a	n/a	n/a
Langelier Index	(2015)	-0.3	n/a	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Chlorine (mg/L)	(2023)	0.00	n/a	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Gico Management WS* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Arsenic				Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
---------	--	--	--	---

About your Arsenic: The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

2023 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A Drinking Water Source Assessment (DWSAP) has not been completed for the WELL #2 of the GICO MANAGEMENT & WATER SYSTEM water system.

WELL #2 - does not have a completed Source Water Assessment on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- ☐ The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- ☐ The source is not active. It may be out of service, or new and not yet in service.
- ☐ The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

For more info you may visit <http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp> or contact the health department in the county to which the water system belongs.

Gico Management WS

Analytical Results By FGL - 2023

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			1	1 - 5.3
Breakroom Sink	STK2352666-3					2023-09-14	3.1		
Breakroom Sink (Inside Bldg)	STK2355443-1					2023-11-08	Present		
Breakroom Sink (Inside Bldg)	STK2354683-2					2023-10-20	<1.0		
Breakroom Sink (Inside Bldg)	STK2352351-4					2023-09-08	4.2		
Breakroom Sink (Inside Bldg)	STK2352093-1					2023-09-06	Present		
Breakroom Sink (Inside Bldg)	STK2338815-1					2023-07-06	Absent		
Breakroom Sink (Inside Bldg)	STK2335511-1					2023-05-04	Absent		
Breakroom Sink (Inside Bldg)	STK2332453-1					2023-03-01	Absent		
Breakroom Sink (Inside Bldg)	STK2330047-1					2023-01-05	Absent		
Corn Room Sink	STK2355595-2					2023-11-10	<1.0		
Corn Room Sink	STK2354683-3					2023-10-20	<1.0		
Corn Room Sink	STK2352666-2					2023-09-14	1		
Corn Room Sink	STK2352351-3					2023-09-08	1		
Front Dock HB	STK2352666-4					2023-09-14	5.3		
Front Dock Loading Dock	STK2356535-1					2023-12-05	Absent		
Front Dock Loading Dock	STK2355595-3					2023-11-10	<1.0		
Front Dock Loading Dock	STK2354993-1					2023-10-31	Absent		
Front Dock Loading Dock	STK2354683-4					2023-10-20	<1.0		
Front Dock Loading Dock	STK2352351-2					2023-09-08	<1.0		
Front Dock Loading Dock	STK2350175-1					2023-08-02	Absent		
Front Dock Loading Dock	STK2336901-1					2023-06-01	Absent		
Front Dock Loading Dock	STK2334186-1					2023-04-07	Absent		
Front Dock Loading Dock	STK2331260-1					2023-02-01	Absent		
Handwash Sink	STK2355595-1					2023-11-10	<1.0		
Hydro Tank Outlet	STK2353110-3					2023-09-21	2		
Manifold HB	STK2353110-2					2023-09-21	<1.0		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			54	54 - 54
WELL #2	STK1550832-1	mg/L				2015-09-29	54		
Hardness		mg/L		none	none			63.0	63.0 - 63.0
WELL #2	STK2231637-1	mg/L				2022-02-03	63.0		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			11	11 - 12
WELL #2	STK2356536-1	ug/L				2023-12-05	11		
WELL #2	STK2352094-1	ug/L				2023-09-06	11		
WELL #2	STK2336902-1	ug/L				2023-06-01	11		
WELL #2	STK2332454-1	ug/L				2023-03-01	12		
Fluoride		mg/L		2	1			0.1	0.1 - 0.1
WELL #2	STK2152607-1	mg/L				2021-09-08	0.1		
Hexavalent Chromium		ug/L			0.02			7.9	7.9 - 7.9
WELL #2	STK2152607-1	ug/L				2021-09-08	7.9		
Nitrate as N		mg/L		10	10			2.2	2.2 - 2.2
WELL #2	STK2352094-1	mg/L				2023-09-06	2.2		
Nitrate + Nitrite as N		mg/L		10	10			1.2	1.2 - 1.2
WELL #2	STK1550832-1	mg/L				2015-09-29	1.2		
Gross Alpha		pCi/L		15	(0)			2.28	1.89 - 2.78

WELL #2	STK2152607-1	pCi/L				2021-09-08	2.78		
WELL #2	STK2137597-1	pCi/L				2021-06-02	2.17		
WELL #2	STK2132783-1	pCi/L				2021-03-02	1.89		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			56	56 - 56
WELL #2	STK1550832-1	mg/L				2015-09-29	56		
Specific Conductance		umhos/cm		1600	n/a			444	444 - 444
WELL #2	STK1550832-1	umhos/cm				2015-09-29	444		
Sulfate		mg/L		500	n/a			10	10 - 10
WELL #2	STK1550832-1	mg/L				2015-09-29	10		
Total Dissolved Solids		mg/L		1000	n/a			300	300 - 300
WELL #2	STK1550832-1	mg/L				2015-09-29	300		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.2	0.2 - 0.2
WELL #2	STK1550832-1	mg/L				2015-09-29	0.2		
Vanadium		ug/L		NS	n/a			58	58 - 58
WELL #2	STK2231637-1	ug/L				2022-02-03	58		
Manganese		ug/L		NS	n/a			0.8	0.8 - 0.8
WELL #2	STK2231637-1	ug/L				2022-02-03	0.8		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			17	17 - 17
WELL #2	STK2231637-1	mg/L				2022-02-03	17		
Magnesium		mg/L			n/a			5	5 - 5
WELL #2	STK2231637-1	mg/L				2022-02-03	5		
pH		units			n/a			7.9	7.9 - 7.9
WELL #2	STK2231637-1	units				2022-02-03	7.9		
Alkalinity		mg/L			n/a			120	120 - 120
WELL #2	STK2231637-1	mg/L				2022-02-03	120		
Aggressiveness Index					n/a			11.6	11.6 - 11.6
WELL #2	STK1550832-1					2015-09-29	11.6		
Langelier Index					n/a			-0.3	-0.3 - -0.3
WELL #2	STK1550832-1					2015-09-29	-0.3		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chlorine		mg/L		4.0	4.0			0.00	-
WELL #2	STK2355595-4	mg/L				2023-11-10			
WELL #2	STK2354683-1	mg/L				2023-10-20			
WELL #2	STK2353110-1	mg/L				2023-09-21			
WELL #2	STK2352666-1	mg/L				2023-09-14			
WELL #2	STK2352351-1	mg/L				2023-09-08			
Average WELL #2								0	

Gico Management WS

CCR Login Linkage - 2023

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
DST_LCR	STK2338531-5	2023-06-27	Metals, Total	Breakroom Sink	Lead & Copper Monitoring
Breakroom Sink	STK2352666-3	2023-09-14	Coliform	Breakroom Sink	Water Monitoring
Bacti-Rout-Odd	STK2330047-1	2023-01-05	Coliform	Breakroom Sink (Inside Bldg)	Routine Bacteriological Monitoring-Odd
	STK2332453-1	2023-03-01	Coliform	Breakroom Sink (Inside Bldg)	Routine Bacteriological Monitoring-Odd
	STK2335511-1	2023-05-04	Coliform	Breakroom Sink (Inside Bldg)	Routine Bacteriological Monitoring-Odd
	STK2338815-1	2023-07-06	Coliform	Breakroom Sink (Inside Bldg)	Routine Bacteriological Monitoring-Odd
	STK2352093-1	2023-09-06	Coliform	Breakroom Sink (Inside Bldg)	Routine Bacteriological Monitoring-Odd
	STK2352351-4	2023-09-08	Coliform	Breakroom Sink (Inside Bldg)	Routine Bacteriological Monitoring-Odd
	STK2354683-2	2023-10-20	Coliform	Breakroom Sink (Inside Bldg)	Routine Bacteriological Monitoring-Odd
	STK2355443-1	2023-11-08	Coliform	Breakroom Sink (Inside Bldg)	Routine Bacteriological Monitoring-Odd
DST_LCR	STK2338531-2	2023-06-27	Metals, Total	Corn Rm Sink	Lead & Copper Monitoring
Bacti-Rpt-ss01	STK2352351-3	2023-09-08	Coliform	Corn Room Sink	Repeat Bacteriological Monitoring
Corn Room Sink	STK2352666-2	2023-09-14	Coliform	Corn Room Sink	Repeat Bacteriological Monitoring
Bacti-Rpt-ss01	STK2354683-3	2023-10-20	Coliform	Corn Room Sink	Repeat Bacteriological Monitoring
	STK2355595-2	2023-11-10	Coliform	Corn Room Sink	Repeat Bacteriological Monitoring
Front Dock HB	STK2352666-4	2023-09-14	Coliform	Front Dock HB	Routine Bacteriological Monitoring-Even
Bacti-Rout-Even	STK2331260-1	2023-02-01	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
	STK2334186-1	2023-04-07	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
	STK2336901-1	2023-06-01	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
	STK2350175-1	2023-08-02	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
	STK2352351-2	2023-09-08	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
	STK2354683-4	2023-10-20	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
	STK2354993-1	2023-10-31	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
	STK2355595-3	2023-11-10	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
	STK2356535-1	2023-12-05	Coliform	Front Dock Loading Dock	Routine Bacteriological Monitoring-Even
Bacti-Rout-Odd	STK2355595-1	2023-11-10	Coliform	Handwash Sink	Routine Bacteriological Monitoring-Odd
Hydro Tank Outl	STK2353110-3	2023-09-21	Coliform	Hydro Tank Outlet	GICO MANAGEMENT & WATER SYSTEM
Manifold HB	STK2353110-2	2023-09-21	Coliform	Manifold HB	GICO MANAGEMENT & WATER SYSTEM
DST_LCR	STK2338531-3	2023-06-27	Metals, Total	Office Bathroom	Lead & Copper Monitoring
	STK2338531-1	2023-06-27	Metals, Total	Office Kitchen	Lead & Copper Monitoring
	STK2338531-4	2023-06-27	Metals, Total	Production Bath	Lead & Copper Monitoring
NEW WELL	STK1550832-1	2015-09-29	General Mineral	WELL #2	New Well Start up Monitoring
New Well	STK2132783-1	2021-03-02	Radio Chemistry	WELL #2	Well 2 - Water Quality
	STK2137597-1	2021-06-02	Radio Chemistry	WELL #2	Well 2 - Water Quality
	STK2152607-1	2021-09-08	Wet Chemistry	WELL #2	Well 2 - Water Quality
	STK2152607-1	2021-09-08	Radio Chemistry	WELL #2	Well 2 - Water Quality
NEW WELL	STK2231637-1	2022-02-03	Wet Chemistry	WELL #2	Well #2
	STK2231637-1	2022-02-03	Metals, Total	WELL #2	Well #2
New Well	STK2332454-1	2023-03-01	Metals, Total	WELL #2	Well 2 - Water Quality
	STK2336902-1	2023-06-01	Metals, Total	WELL #2	Well 2 - Water Quality
	STK2352094-1	2023-09-06	Wet Chemistry	WELL #2	Well 2 - Water Quality
	STK2352094-1	2023-09-06	Metals, Total	WELL #2	Well 2 - Water Quality
NEW WELL	STK2352351-1	2023-09-08	Field Test	WELL #2	GICO MANAGEMENT & WATER SYSTEM
	STK2352666-1	2023-09-14	Field Test	WELL #2	GICO MANAGEMENT & WATER SYSTEM
	STK2353110-1	2023-09-21	Field Test	WELL #2	GICO MANAGEMENT & WATER SYSTEM
	STK2354683-1	2023-10-20	Field Test	WELL #2	GICO MANAGEMENT & WATER SYSTEM
	STK2355595-4	2023-11-10	Field Test	WELL #2	GICO MANAGEMENT & WATER SYSTEM
New Well	STK2356536-1	2023-12-05	Metals, Total	WELL #2	Well 2 - Water Quality