


## CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Water System Name:	City of Ripon
Water System Number:	3010007

The water system named above hereby certifies that its 2022 Consumer Confidence Report was distributed on June 28, 2023 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: James Pease
Name: James Pease
Signature: 
Title: Public Works Director
Phone number: 209-599-2108
Date: 8-3-23

*To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:*

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: Website
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
  - ☒ Posting the CCR on the Internet at [https://cdns5-hosted.civicle.com/UserFiles/Servers/Server\\_1080027/File/Connect/Public%20Notices/CCR%20ripon%202022%20Final%2020230629.pdf](https://cdns5-hosted.civicle.com/UserFiles/Servers/Server_1080027/File/Connect/Public%20Notices/CCR%20ripon%202022%20Final%2020230629.pdf)
  - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
  - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - ☐ Posted the CCR in public places (attach a list of locations)
  - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
  - ☐ Delivery to community organizations (attach a list of organizations)
  - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address:
- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).



**Public Works Department**  
**259 N. Wilma Avenue**  
**Ripon, CA 95366**

BULK RATE  
U.S. POSTAGE PAID  
RIPON, CA  
PERMIT NO. 60



**NOTICE OF CORRECTION**  
**to the**  
**2022 Drinking Water**  
**Consumer Confidence Report**



Scan QR Code to access revised  
2022 Consumer Confidence Report

**Local Postal Customer**

## NOTICE OF CORRECTION

The City of Ripon 2022 Consumer Confidence Report was recently mailed out with a typographical error on the Contaminants with Secondary Drinking Water Standards tables. All fields under the column with the header 'In Compliance' should have read 'Yes' as the City of Ripon was in compliance for each of the contaminants listed. The corrected table is below. The corrected 2022 Consumer Confidence Report is available on-line at: [www.cityofripon.org/city\\_hall/city\\_government/forms\\_and\\_documents](http://www.cityofripon.org/city_hall/city_government/forms_and_documents)

### Contaminants with Secondary Drinking Water Standards

Contaminant (unit)	SMCL	Average	Range	Year Tested	In Compliance	Typical Source
Chloride (ppm)	500	71	12 - 200	2020 - 2021	Yes	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (µS/cm)	1,600	540	250 - 1,100	2020 - 2022	Yes	Substances that form ions when in water; seawater influence
Sulfate (ppm)	500	15	8.9 - 20	2020 - 2021	Yes	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	1,000	345	210 - 610	2020 - 2021	Yes	Runoff/leaching from natural deposits
Turbidity (NTU)	5	0.03	ND - 0.11	2020 - 2021	Yes	Soil runoff