





---

## 2020 Consumer Confidence Report for San Joaquin County Water Systems

---

### What is this report?

This report, prepared in cooperation with the State Water Resources Control Board, provides important information about San Joaquin County water systems and water quality. Test results for your water system's 2019 Water Quality Monitoring Program are summarized starting on Page 4 of this report. Before reviewing this water quality information, it is helpful to read the messages from the United States Environmental Protection Agency (USEPA) and from the San Joaquin County Department of Public Works Utilities Maintenance Division.

### Where does drinking water come from?

Drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban Stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban Stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban Stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

### What is drinking water quality?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791) or by emailing [safewater@epa.gov](mailto:safewater@epa.gov). You can also visit their website at [www.epa.gov/sdwa](http://www.epa.gov/sdwa)

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

## How is safe and affordable water delivered?

The San Joaquin County Department of Public Works Utility Maintenance Division is committed to the delivery of safe and affordable drinking water to approximately 6,000 service connections within San Joaquin County. This essential service is critically important to the current and future prosperity of our region. To meet customer needs, the County largely depends on groundwater for its water supply, which is pumped by domestic water wells.

The County operates and maintains the following:

- ✓ 52 domestic water wells with appurtenances
- ✓ 66 miles of water distribution systems
- ✓ 30 independent water systems

GET INVOLVED
For further information regarding opportunities for public participation in decisions that affect drinking water quality please call (209) 468-3090 or visit <a href="https://www.sjgov.org">https://www.sjgov.org</a>

## What are Drinking Water Standards?

The United States Environmental Protection Agency (USEPA) and the State Water Resources Control Board (SWRCB) are charged with the responsibility of setting and implementing safe drinking water standards. Well over one hundred compounds are now regulated. In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## What about Lead in drinking water?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. San Joaquin County Utility Maintenance is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: You may wish to collect the flushed water and reuse it for another beneficial purpose such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Below are the current watering guidelines for County districts.  
These have not changed since July 3, 2017

If your house number ends in:	Then you may water on:
an <b>EVEN</b> number (0, 2, 4, 6, 8)	<b>Wednesday</b> and/or <b>Friday</b> and/or <b>Sunday</b>
an <b>ODD</b> number (1, 3, 5, 7, 9)	<b>Tuesday</b> and/or <b>Thursday</b> and/or <b>Saturday</b>
Watering is prohibited between the hours of 11:00 AM and 6:00 PM Watering is not permitted on Mondays	

**COUNTY MAINTENANCE WORKERS ALWAYS WEAR TAN SHIRTS WITH THE COUNTY LOGO, DRIVE COUNTY VEHICLES, AND CARRY COUNTY I.D.**

If you have questions about anything contained in this document, want a hard copy of this document mailed to you, or want to report a water leak or sewer stoppage, please call (209) 468-3090

#### TERMS AND DEFINITIONS FOR THE FOLLOWING REPORT

<b>Regulatory Action Level (AL):</b> Concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
<b>Maximum Contaminant Level (MCL):</b> Highest level of a contaminant allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
<b>Maximum Contaminant Level Goal (MCLG):</b> Level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
<b>MFL:</b> Million fibers per liter
<b>Maximum Residual Disinfectant Level (MRDL):</b> Highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<b>Maximum Residual Disinfectant Level Goal (MRDLG):</b> The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<b>Mrem/year:</b> Millirems per year (a measure of radiation absorbed by the body)
<b>N/A:</b> Not applicable
<b>NTU:</b> Nephelometric Turbidity Units
<b>pCi/L:</b> Picocuries per liter (a measure of radioactivity)
<b>Primary Drinking Water Standard (PDWS):</b> MCLs, MRDLs and treatment techniques (TTs) for contaminants that affect health, along with their monitoring and reporting requirements.
<b>Public Health Goal (PHG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
<b>Ppb:</b> Parts per billion, or micrograms per liter (µg/L)
<b>Ppm:</b> Parts per million, or milligrams per liter (mg/L)
<b>Ppt:</b> Parts per trillion, or nanograms per liter (ng/L)
<b>Ppq:</b> Parts per quadrillion, or pictograms per liter (pg/L)
<b>Treatment Technique (TT):</b> A required process intended to reduce the level of a contaminant in drinking water.

**Water System Name: Mokelumne Acres Water System**

**Report Date:**

**Type of Water Source(s) in Use: Groundwater wells**

**6/2021**

**Name of Source(s) in Use: Wells #3, #6, #7 and #9**

**Table #1: Sampling Results Showing Detection of Coliform Bacteria**

MICROBIOLOGICAL CONTAMINANTS	HIGHEST NO. OF DETECTIONS	NO. of MOS. In VIOLATION	MCL	MCLG	TYPICAL SOURCE OF BACTERIA
Tot. Coliform Bacteria	0	0	>1	0	Naturally present in environment.
Fecal Coliform and <i>E. coli</i>	0	0	>1	0	Human and animal fecal waste.

**Table #2: Sampling Results Showing Detection of Lead and Copper**

LEAD and COPPER	SAMPLE DATE	NO. of SAMPLES	90TH Percentile LEVEL	NO. SITES >AL	AL	MCLG	TYPICAL SOURCE OF CONTAMINANT
Lead (ppb)	2018	20	0	0	15	2	Internal corrosion of household water plumbing systems; discharge from industrial manufacturers; erosion of natural deposits
Copper (ppb)	2018	20	469	0	1300	170	Internal corrosion of household water plumbing systems; discharge from industrial manufacturers; erosion of natural deposits; leaching from wood preservatives

**Table #3: Sampling Results Showing Detection of Sodium and Hardness**

CHEMICAL OR CONSTITUENT	SAMPLE DATE	LEVEL DETECTED	RANGE OF DETECTIONS	MCL	PHG (MCLG)	TYPICAL SOURCE OF CONTAMINANT
Sodium (ppm)	2020	35	35	NONE	NONE	Generally found in ground and surface water
Hardness (ppm)	2020	338	338	NONE	NONE	Generally found in ground and surface water
Calcium (ppm)	2020	76	76	NONE	NONE	Generally found in ground and surface water
Magnesium (ppm)	2020	36	26	NONE	NONE	Generally found in ground and surface water
Potassium (ppm)	2020	3	3	NONE	NONE	Generally found in ground and surface water
Total Alkalinity (ppm)	2020	290	290	NONE	NONE	Generally found in ground and surface water

**Table #4: Detection of Contaminants with a PRIMARY Drinking Water Standard**

CHEMICAL OR CONSTITUENT	SAMPLE DATE	LEVEL DETECTED	RANGE OF DETECTIONS	MCL	PHG (MCLG)	TYPICAL SOURCE OF CONTAMINANT
Gross Alpha Activity (pCi/L)	2020	12.4	12.4	15	N/A	Erosion of natural deposits.
Uranium (pCi/L)	2020	9.31	9.31	20	1	Erosion of natural deposits.
Arsenic	2020	3	3	10	0.004	Erosion of natural deposits;run-off from orchards; glass and electronics production wastes.
Barium (ppb)	2020	261	261	1000	2	Oil drilling and metal refinery waste discharge; erosion of natural deposits.
Nitrate as N (ppm)	2020	1.65	1.5 - 1.8	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
TTH(ppb) Total Trihalomethanes	2020	4	3 - 5	80	N/A	By-product of drinking water chlorination.
HAA5 (ppb)	2020	0.5	ND - 1	60		By-product of drinking water chlorination.
Chlorine as Cl2 (ppm)	2020	0.62	0.48 - 0.73	4.0	4.0	Drinking water disinfectant added for treatment.

**Table #5: Detection of Contaminants with a SECONDARY Drinking Water Standard**

CHEMICAL OR CONSTITUENT	SAMPLE DATE	LEVEL DETECTED	RANGE OF DETECTIONS	MCL	PHG (MCLG)	TYPICAL SOURCE OF CONTAMINANT
Corrosivity	2020	0.2		Non-corrosive	N/A	Natural or industrially influenced balance of hydrogen, carbon and oxygen in the water; affected by temperature and other factors.
Total Dissolved Solids (TDS)	2020	510		1000	N/A	Run-off /leaching from natural deposits.
Specific Conductance	2020	790	790	1600	N/A	Substances that form ions when in water, seawater influence.
Chloride (ppm)	2020	26	26	500	N/A	Substances that form ions when in water, seawater influence.
Sulfate (ppm)	2020	48.4	48.4	500	N/A	Leaching from natural deposits; industrial wastes.
Turbidity (units)	2020	2.15	ND - 5	5	N/A	Soil run-off.
Zinc	2019	70	70	N/A	N/A	Runoff/leaching from natural deposits; industrial wastes
Manganese (ppb)	2019	20	ND - 20	50	N/A	Leaching from natural deposits.
Iron	2020	95	ND - 150	300	N/A	Runoff/leaching from natural deposits; industrial wastes

**Table #6: Detection of UNREGULATED Contaminants**

CHEMICAL OR CONSTITUENT	SAMPLE DATE	RANGE OF DETECTIONS	NOTIFICATION LEVEL	HEALTH EFFECTS LANGUAGE
Vanadium (ppb)	2020	21	50	The babies of some pregnant women who drink water containing vanadium in excess of the notification level may have an increased risk of developmental defects (based on studies in laboratory animals).

Drinking water is tested for quality for many constituents as required by State and Federal regulations. This report shows the results of our monitoring for the period of Jan. 1 thru Dec. 31, 2020, or for the period as noted.

**Drinking Water Source Assessment Information:** An assessment of the drinking water sources for San Joaquin County – Mokelumne Acres water system was completed in March 2001. The sources are considered most vulnerable to the following activities: wastewater treatment plants, sewer collection systems, gas stations, agricultural wells, lagoons (liquid wastes), and metal plating, finishing and fabricating.

*A copy of the complete assessment is available at:*

Department of Health Services, Drinking Water Field Operations Branch  
 Stockton District Office, 31 E. Channel Street, Room 270, Stockton, CA 95202

*You may request a summary of the assessment be sent to you by contacting:*

Robert Lapp, at (209) 948-3816