

2020 Consumer Confidence Report

Water System Name: LITTLE POTATO SLOUGH MUTUAL Report Date: March 2021

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Surface Water. This Assessment was done using the Other Methods.

Your water comes from 1 source(s): Little Potato Slough - RAW
and from 1 treated location(s): Little Potato Slough - TREATED

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held at the Village Club House every third Monday of every month, at 10:30 a.m.

For more information about this report, or any questions relating to your drinking water, please call (209)339-1602 or visit our website at www.lpswaterco.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2020)	20	1.6	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2020)	20	0.01	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - TREATED SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2020)	19	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2020)	54.6	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Gross Alpha (pCi/L)	(2019)	1.17	n/a	15	(0)	Erosion of natural deposits.

Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2020)	12	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
MBAS (ug/L)	(2020)	100	n/a	500	n/a	Municipal and industrial waste discharges.
Odor Threshold at 60 °C (TON)	(2020)	2	ND - 4	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2020)	216	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2020)	20.3	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2020)	110	n/a	1000	n/a	Runoff/leaching from natural deposits

Table 5 - TREATED ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2020)	12	n/a	n/a	n/a
Magnesium (mg/L)	(2020)	6	n/a	n/a	n/a
pH (units)	(2020)	7.5	n/a	n/a	n/a
Alkalinity (mg/L)	(2020)	50	n/a	n/a	n/a
Aggressiveness Index	(2020)	10.7	n/a	n/a	n/a
Langelier Index	(2020)	-1.1	n/a	n/a	n/a

Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2020)	74	35 - 112	80	n/a	No	By-product of drinking water disinfection
Haloacetic Acids (five) (ug/L)	(2020)	27.785714285714	13 - 47	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and

components associated with the service lines and home plumbing. *Little Potato Slough* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Odor Threshold at 60 °C				Odor was found at levels that exceed the secondary MCL. The Odor MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Total Trihalomethanes (TTHMs)				Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.

2020 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the LITTLE POTATO SLOUGH - RAW of the LITTLE POTATO SLOUGH MUTUAL water system in January, 2003.

Little Potato Slough - RAW - is considered most vulnerable to the following activities:
Gas Stations, and Animal Feeding Operations in the watershed.

Acquiring Information

A copy of the complete assessment may be viewed at:

Drinking Water Field Operations Branch
31 E. Channel Street
Room 270
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

District 10 - Stockton
Vacant
31 E. Channel Street
Room 270
Stockton CA 95202
(209) 948-7696

Analytical Results By FGL - 2020

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			1.6	20
02 Silverwood Ct.	STK2032299-9	ug/L				2020-02-11	ND		
04 Silverwood Ct.	STK2052277-10	ug/L				2020-08-25	ND		
04 Silverwood Ct.	STK2032299-10	ug/L				2020-02-11	ND		
08 Whispering Wy.	STK2032299-1	ug/L				2020-02-11	ND		
09 Riverbend Dr.	STK2032299-7	ug/L				2020-02-12	ND		
09 Summersky Wy.	STK2032299-3	ug/L				2020-02-10	ND		
14 Whispering Wy.	STK2052277-5	ug/L				2020-08-25	14.2		
14 Whispering Wy.	STK2032299-5	ug/L				2020-02-13	ND		
15 Summersky Wy.	STK2052277-2	ug/L				2020-08-25	ND		
15 Summersky Wy.	STK2032299-2	ug/L				2020-02-14	ND		
19 Sleepy Hollow	STK2052277-6	ug/L				2020-08-25	ND		
19 Sleepy Hollow	STK2032299-6	ug/L				2020-02-13	ND		
2 Silverwood	STK2052277-9	ug/L				2020-08-25	ND		
20 Summersky Wy.	STK2052277-8	ug/L				2020-08-25	ND		
20 Summersky Wy.	STK2032299-8	ug/L				2020-02-10	ND		
26 Whispering Wy.	STK2052277-4	ug/L				2020-08-23	ND		
26 Whispering Wy.	STK2032299-4	ug/L				2020-02-13	ND		
8 Whispering Wy.	STK2052277-1	ug/L				2020-08-25	ND		
9 Riverbend Dr.	STK2052277-7	ug/L				2020-08-25	ND		
9 Summersky Wy.	STK2052277-3	ug/L				2020-08-25	ND		
Copper		mg/L		1.3	.3			0.01	20
02 Silverwood Ct.	STK2032299-9	mg/L				2020-02-11	ND		
04 Silverwood Ct.	STK2052277-10	mg/L				2020-08-25	ND		
04 Silverwood Ct.	STK2032299-10	mg/L				2020-02-11	ND		
08 Whispering Wy.	STK2032299-1	mg/L				2020-02-11	ND		
09 Riverbend Dr.	STK2032299-7	mg/L				2020-02-12	ND		
09 Summersky Wy.	STK2032299-3	mg/L				2020-02-10	ND		
14 Whispering Wy.	STK2052277-5	mg/L				2020-08-25	1.03		
14 Whispering Wy.	STK2032299-5	mg/L				2020-02-13	ND		
15 Summersky Wy.	STK2052277-2	mg/L				2020-08-25	ND		
15 Summersky Wy.	STK2032299-2	mg/L				2020-02-14	ND		
19 Sleepy Hollow	STK2052277-6	mg/L				2020-08-25	ND		
19 Sleepy Hollow	STK2032299-6	mg/L				2020-02-13	ND		
2 Silverwood	STK2052277-9	mg/L				2020-08-25	ND		
20 Summersky Wy.	STK2052277-8	mg/L				2020-08-25	ND		
20 Summersky Wy.	STK2032299-8	mg/L				2020-02-10	ND		
26 Whispering Wy.	STK2052277-4	mg/L				2020-08-23	ND		
26 Whispering Wy.	STK2032299-4	mg/L				2020-02-13	ND		
8 Whispering Wy.	STK2052277-1	mg/L				2020-08-25	ND		
9 Riverbend Dr.	STK2052277-7	mg/L				2020-08-25	ND		
9 Summersky Wy.	STK2052277-3	mg/L				2020-08-25	ND		

TREATED SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			19	19 - 19
Little Potato Slough - TREATED	STK2055344-1	mg/L				2020-11-02	19		
Hardness		mg/L		none	none			54.6	54.6 - 54.6
Little Potato Slough - TREATED	STK2055344-1	mg/L				2020-11-02	54.6		

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Gross Alpha		pCi/L		15	(0)			1.17	1.17 - 1.17
Little Potato Slough - TREATED	STK1951229-1	pCi/L				2019-08-05	1.17		

TREATED SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			12	12 - 12
Little Potato Slough - TREATED	STK2055344-1	mg/L				2020-11-02	12		
MBAS		ug/L		500	n/a			100	100 - 100
Little Potato Slough - TREATED	STK2055344-1	ug/L				2020-11-02	100		
Odor Threshold at 60 °C		TON		3	n/a			2	ND - 4
Little Potato Slough - TREATED	STK2056545-1	TON				2020-11-30	ND		
Little Potato Slough - TREATED	STK2055344-1	TON				2020-11-02	4		
Specific Conductance		umhos/cm		1600	n/a			216	216 - 216
Little Potato Slough - TREATED	STK2055344-1	umhos/cm				2020-11-02	216		
Sulfate		mg/L		500	n/a			20.3	20.3 - 20.3
Little Potato Slough - TREATED	STK2055344-1	mg/L				2020-11-02	20.3		
Total Dissolved Solids		mg/L		1000	n/a			110	110 - 110
Little Potato Slough - TREATED	STK2055344-1	mg/L				2020-11-02	110		

TREATED ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			12	12 - 12
Little Potato Slough - TREATED	STK2055344-1	mg/L				2020-11-02	12		
Magnesium		mg/L			n/a			6	6 - 6
Little Potato Slough - TREATED	STK2055344-1	mg/L				2020-11-02	6		
pH		units			n/a			7.5	7.5 - 7.5
Little Potato Slough - TREATED	STK2055344-1	units				2020-11-02	7.5		
Alkalinity		mg/L			n/a			50	50 - 50
Little Potato Slough - TREATED	STK2055344-1	mg/L				2020-11-02	50		
Aggressiveness Index					n/a			10.7	10.7 - 10.7
Little Potato Slough - TREATED	STK2055344-1					2020-11-02	10.7		
Langelier Index					n/a			-1.1	-1.1 - -1.1
Little Potato Slough - TREATED	STK2055344-1					2020-11-02	-1.1		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ug/L		80	n/a			74	35 - 112
ST2DBP - 17 Summersky	STK2056890-2	ug/L				2020-12-07	57		
ST2DBP - 17 Summersky	STK2055349-2	ug/L				2020-11-02	35		
ST2DBP - 17 Summersky	STK2054015-2	ug/L				2020-10-05	44		
ST2DBP - 17 Summersky	STK2052717-2	ug/L				2020-09-08	77		
ST2DBP - 17 Summersky	STK2050850-2	ug/L				2020-08-03	57		
ST2DBP - 17 Summersky	STK2039764-2	ug/L				2020-07-13	50		
ST2DBP - 17 Summersky	STK2037501-2	ug/L				2020-06-01	53		
ST2DBP - 17 Summersky	STK2035877-2	ug/L				2020-05-04	47		
ST2DBP - 17 Summersky	STK2034354-2	ug/L				2020-04-06	97		
ST2DBP - 17 Summersky	STK2032799-2	ug/L				2020-03-02	103		
ST2DBP - 17 Summersky	STK2032267-2	ug/L				2020-02-17	89		
ST2DBP - 17 Summersky	STK2031588-2	ug/L				2020-02-03	103		
ST2DBP - 17 Summersky	STK2031326-2	ug/L				2020-01-27	112		
ST2DBP - 17 Summersky	STK2030150-2	ug/L				2020-01-06	107		
Average ST2DBP - 17 Summersky								73.64	
Haloacetic Acids (five)		ug/L		60	n/a			27.785714285714	13 - 47
ST2DBP - 5 River Bend	STK2056890-1	ug/L				2020-12-07	14		

[illegible]

Little Potato Slough

CCR Login Linkage - 2020

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
LP-CuPb-ss09	STK2032299-9	2020-02-11	Metals, Total	02 Silverwood Ct.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss10	STK2032299-10	2020-02-11	Metals, Total	04 Silverwood Ct.	Little Potato Slough Copper & Lead Monitoring
	STK2052277-10	2020-08-25	Metals, Total	04 Silverwood Ct.	Little Potato Slough Copper & Lead Monitoring
TP-Bacti-Rout-2	STK2030610-1	2020-01-13	Coliform	05 Riverbend	Water Monitoring
	STK2032269-1	2020-02-17	Coliform	05 Riverbend	Routine #2 Bacteriological Monitoring
	STK2033830-1	2020-03-23	Coliform	05 Riverbend	Water Monitoring
	STK2035536-1	2020-04-27	Coliform	05 Riverbend	Routine #2 Bacteriological Monitoring
	STK2037502-1	2020-06-01	Coliform	05 Riverbend	Water Monitoring
	STK2039158-1	2020-07-06	Coliform	05 Riverbend	Routine #2 Bacteriological Monitoring
	STK2051752-1	2020-08-17	Coliform	05 Riverbend	Routine #2 Bacteriological Monitoring
	STK2053417-1	2020-09-21	Coliform	05 Riverbend	Routine #2 Bacteriological Monitoring
	STK2055213-1	2020-10-26	Coliform	05 Riverbend	Routine #2 Bacteriological Monitoring
	STK2056544-1	2020-11-30	Coliform	05 Riverbend	Routine #2 Bacteriological Monitoring
LP-CuPb-ss01	STK2032299-1	2020-02-11	Metals, Total	08 Whispering Wy.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss07	STK2032299-7	2020-02-12	Metals, Total	09 Riverbend Dr.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss03	STK2032299-3	2020-02-10	Metals, Total	09 Summersky Wy.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss05	STK2032299-5	2020-02-13	Metals, Total	14 Whispering Wy.	Little Potato Slough Copper & Lead Monitoring
	STK2052277-5	2020-08-25	Metals, Total	14 Whispering Wy.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss02	STK2032299-2	2020-02-14	Metals, Total	15 Summersky Wy.	Little Potato Slough Copper & Lead Monitoring
	STK2052277-2	2020-08-25	Metals, Total	15 Summersky Wy.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss06	STK2032299-6	2020-02-13	Metals, Total	19 Sleepy Hollow	Little Potato Slough Copper & Lead Monitoring
	STK2052277-6	2020-08-25	Metals, Total	19 Sleepy Hollow	Little Potato Slough Copper & Lead Monitoring
TP-Bacti-Rout-1	STK2030151-1	2020-01-06	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2032008-1	2020-02-10	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2033594-1	2020-03-16	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2035110-1	2020-04-20	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2037192-1	2020-05-26	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2038971-1	2020-06-29	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2039765-1	2020-07-13	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2051345-1	2020-08-10	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2053155-1	2020-09-14	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2054764-1	2020-10-19	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2056425-1	2020-11-23	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
	STK2057604-1	2020-12-28	Coliform	19 Summersky	Routine #1 Bacteriological Monitoring
LP-CuPb-ss09	STK2052277-9	2020-08-25	Metals, Total	2 Silverwood	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss08	STK2032299-8	2020-02-10	Metals, Total	20 Summersky Wy.	Little Potato Slough Copper & Lead Monitoring
	STK2052277-8	2020-08-25	Metals, Total	20 Summersky Wy.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss04	STK2032299-4	2020-02-13	Metals, Total	26 Whispering Wy.	Little Potato Slough Copper & Lead Monitoring
	STK2052277-4	2020-08-23	Metals, Total	26 Whispering Wy.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss01	STK2052277-1	2020-08-25	Metals, Total	8 Whispering Wy.	Little Potato Slough Copper & Lead Monitoring

LP-CuPb-ss07	STK2052277-7	2020-08-25	Metals, Total	9 Riverbend Dr.	Little Potato Slough Copper & Lead Monitoring
LP-CuPb-ss03	STK2052277-3	2020-08-25	Metals, Total	9 Summersky Wy.	Little Potato Slough Copper & Lead Monitoring
LP-WELL-RAW	STK1630034-1	2016-01-04	TOC	Little Potato Slough - RAW	Little Potato Slough TOC Monitoring
LP-WELL-TRTD	STK1951229-1	2019-08-05	Radio Chemistry	Little Potato Slough - TREATED	Little Potato Slough Radio Monitoring
	STK2055344-1	2020-11-02	General Mineral	Little Potato Slough - TREATED	Little Potato Slough Water Quality Monitoring
	STK2055344-1	2020-11-02	Wet Chemistry	Little Potato Slough - TREATED	Little Potato Slough Water Quality Monitoring
	STK2056545-1	2020-11-30	Wet Chemistry	Little Potato Slough - TREATED	LP- Water Quality Monitoring
TP-Bacti-Rout-4	STK2031360-1	2020-01-27	Coliform	RV Space #228	Water Monitoring
LP-RV SPACE 228	STK2032795-1	2020-03-02	Coliform	RV Space #228	Bacteriological Monitoring
	STK2034350-1	2020-04-06	Coliform	RV Space #228	Bacteriological Monitoring
	STK2036387-1	2020-05-11	Coliform	RV Space #228	Bacteriological Monitoring
	STK2038339-1	2020-06-15	Coliform	RV Space #228	Bacteriological Monitoring
	STK2050373-1	2020-07-27	Coliform	RV Space #228	Bacteriological Monitoring
	STK2052403-1	2020-08-31	Coliform	RV Space #228	Bacteriological Monitoring
TP-Bacti-Rout-4	STK2054011-1	2020-10-05	Coliform	RV Space #228	Routine #4 Bacteriological Monitoring
LP-RV SPACE 228	STK2055815-1	2020-11-09	Coliform	RV Space #228	Bacteriological Monitoring
TP-Bacti-Rout-4	STK2057299-1	2020-12-14	Coliform	RV Space #228	Routine #4 Bacteriological Monitoring
RV Space #286	STK2030808-1	2020-01-20	Coliform	RV Space #286	Water Monitoring
TP-Bacti-Rout-3	STK2032480-1	2020-02-24	Coliform	RV Space #286	Water Monitoring
	STK2034111-1	2020-03-30	Coliform	RV Space #286	Water Monitoring
	STK2035810-1	2020-05-04	Coliform	RV Space #286	Water Monitoring
	STK2038048-1	2020-06-08	Coliform	RV Space #286	Routine #3 Bacteriological Monitoring
	STK2050124-1	2020-07-20	Coliform	RV Space #286	Routine #3 Bacteriological Monitoring
	STK2052156-1	2020-08-24	Coliform	RV Space #286	Routine #3 Bacteriological Monitoring
	STK2053767-1	2020-09-28	Coliform	RV Space #286	Routine #3 Bacteriological Monitoring
	STK2055345-1	2020-11-02	Coliform	RV Space #286	Routine #3 Bacteriological Monitoring
	STK2056886-1	2020-12-07	Coliform	RV Space #286	Routine #3 Bacteriological Monitoring
LP-SLIP #159	STK2031498-1	2020-02-03	Coliform	Slip 159 (Tomato Shed)	Bacteriological Monitoring
TP-Bacti-Rout-6	STK2033282-1	2020-03-09	Coliform	Slip 159 (Tomato Shed)	Routine #6 Bacteriological Monitoring
LP-SLIP #159	STK2034926-1	2020-04-13	Coliform	Slip 159 (Tomato Shed)	Bacteriological Monitoring
	STK2036779-1	2020-05-18	Coliform	Slip 159 (Tomato Shed)	Water Monitoring
	STK2038769-1	2020-06-22	Coliform	Slip 159 (Tomato Shed)	Bacteriological Monitoring
TP-Bacti-Rout-6	STK2050606-1	2020-08-03	Coliform	Slip 159 (Tomato Shed)	Routine #6 Bacteriological Monitoring
LP-SLIP #159	STK2052713-1	2020-09-08	Coliform	Slip 159 (Tomato Shed)	Bacteriological Monitoring
	STK2054565-1	2020-10-12	Coliform	Slip 159 (Tomato Shed)	Bacteriological Monitoring
	STK2056055-1	2020-11-16	Coliform	Slip 159 (Tomato Shed)	Bacteriological Monitoring
	STK2057481-1	2020-12-21	Coliform	Slip 159 (Tomato Shed)	Bacteriological Monitoring
LP-DBP-Stg2-901	STK2030150-2	2020-01-06	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2031326-2	2020-01-27	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2031588-2	2020-02-03	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2032267-2	2020-02-17	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2032799-2	2020-03-02	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2034354-2	2020-04-06	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2035877-2	2020-05-04	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2037501-2	2020-06-01	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2039764-2	2020-07-13	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2050850-2	2020-08-03	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring

	STK2052717-2	2020-09-08	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2054015-2	2020-10-05	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2055349-2	2020-11-02	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
	STK2056890-2	2020-12-07	EPA 551.1	ST2DBP - 17 Summersky	Little Potato Slough Stage 2 IDSE Monitoring
LP-DBP-Stg2-900	STK1935996-2	2019-05-06		ST2DBP - 5 River Bend	DBP Monitoring
	STK1939266-1	2019-07-01		ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2030150-1	2020-01-06	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2031326-1	2020-01-27	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2031588-1	2020-02-03	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2032267-1	2020-02-17	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2032799-1	2020-03-02	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2034354-1	2020-04-06	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2035877-1	2020-05-04	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2037501-1	2020-06-01	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2039764-1	2020-07-13	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2050850-1	2020-08-03	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2052717-1	2020-09-08	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2054015-1	2020-10-05	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2055349-1	2020-11-02	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring
	STK2056890-1	2020-12-07	EPA 552.2	ST2DBP - 5 River Bend	Little Potato Slough Stage 2 IDSE Monitoring