

2020 Consumer Confidence Report

Water System Information

Water System Name: **Toyota of San Luis Obispo**

Report Date: **June 21, 2021**

Type of Water Source(s) in Use: **Groundwater Well**

Name and General Location of Source(s): **Well 01 is located onsite at 12350 Los Osos Valley Road, San Luis Obispo, CA, 93405**

Drinking Water Source Assessment Information: **A source water assessment was conducted for Well 01 of the Toyota San Luis Obispo water system in 2002. The source is considered most vulnerable to the following activities associated with containment detected in the water supply: automobile repair shops. The source is considered most vulnerable to the following activities not associated with any detected contaminants: automobile gas stations, underground storage tanks, and confirmed leaking tanks. A copy of the complete assessment may be viewed at Environmental Health Services, 2156 Sierra Say, San Luis Obispo, CA. You may request a summary of the assessment to be sent to you by contacting San Luis Obispo County Environmental Health Services at (805) 781-5544.**

Time and Place of Regularly Scheduled Board Meetings for Public Participation: **Water system is a business; staff meetings are held regularly and concerns or questions can be brought to management or ownership at any time.**

For More Information, Contact: **Jessica Ruffoni, (805) 922-4600**

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2020 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Toyota San Luis Obispo a 12350 Los Osos Valley Road, San Luis Obispo, CA, 93405, (805) 922-4600 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Toyota San Luis Obispo 以获得中文的帮助: 12350 Los Osos Valley Road, San Luis Obispo, CA, 93405, (805) 922-4600.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Toyota San Luis Obispo, 12350 Los Osos Valley Road, San Luis Obispo, CA, 93405 o tumawag sa (805) 922-4600 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Toyota San Luis Obispo tại 12350 Los Osos Valley Road, San Luis Obispo, CA, 93405, (805) 922-4600 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Toyota San Luis Obispo ntawm 12350 Los Osos Valley Road, San Luis Obispo, CA, 93405, (805) 922-4600 rau kev pab hauv lus Askiv.

Terms Used in This Report

| Term | Definition |
|--|---|
| Level 1 Assessment | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. |
| Level 2 Assessment | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level (MCL) | The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water. |
| Maximum Contaminant Level Goal (MCLG) | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA). |
| Maximum Residual Disinfectant Level (MRDL) | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| Maximum Residual Disinfectant Level Goal (MRDLG) | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| Primary Drinking Water Standards (PDWS) | MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements. |
| Public Health Goal (PHG) | The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency. |
| Regulatory Action Level (AL) | The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow. |
| Secondary Drinking Water Standards (SDWS) | MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels. |
| Treatment Technique (TT) | A required process intended to reduce the level of a contaminant in drinking water. |
| Variances and Exemptions | Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions. |
| ND | Not detectable at testing limit. |
| ppm | parts per million or milligrams per liter (mg/L) |
| ppb | parts per billion or micrograms per liter (µg/L) |
| ppt | parts per trillion or nanograms per liter (ng/L) |
| ppq | parts per quadrillion or picogram per liter (pg/L) |
| pCi/L | picocuries per liter (a measure of radiation) |

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and,

in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

| Microbiological Contaminants | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria |
|---|---------------------------|----------------------------|--|------|--------------------------------------|
| Total Coliform Bacteria (State Total Coliform Rule) | (In a month) 0 | 0 | 1 positive monthly sample (a) | 0 | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i> (State Total Coliform Rule) | (In the year) 0 | 0 | A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive | None | Human and animal fecal waste |
| <i>E. coli</i> (Federal Revised Total Coliform Rule) | (In the year) 0 | 0 | (b) | 0 | Human and animal fecal waste |

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

| Lead and Copper | Sample Date | No. of Samples Collected | 90 th Percentile Level Detected | No. Sites Exceeding AL | AL | PHG | No. of Schools Requesting Lead Sampling | Typical Source of Contaminant |
|-----------------|-------------|--------------------------|--|------------------------|-----|-----|---|---|
| Lead (ppb) | N/A | N/A | N/A | N/A | 15 | 0.2 | N/A | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm) | 9/29/20 | 5 | 0.245 | 0 | 1.3 | 0.3 | N/A | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

Table 3. Sampling Results for Sodium and Hardness

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|---|-------------|----------------|---------------------|------|------------|--|
| Sodium (ppm) | 12/27/16 | 52 | N/A | None | None | Salt present in the water and is generally naturally occurring |
| Hardness (ppm) | 12/27/16 | 470 | N/A | None | None | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|---|--------------------|----------------|---------------------|------------|--------------------|---|
| Barium (ppm) | 12/9/19 | 0.14 | N/A | 1 | 2 | Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits |
| Copper (ppm) | 12/27/16 | 0.014 | N/A | | | |
| Fluoride (ppm) | 12/9/19 | 0.28 | N/A | 2 | 1 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Gross Alpha Particle Activity | 12/9/19 | 2.01 | N/A | 50 | 0 | Erosion of natural deposits |
| Nitrate as N – Distribution (ppm) | 4/2/20 | 1.3 | N/A | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Nitrate as N – Well (ppm) | 4/2/20 | 2.6 | N/A | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Selenium (ppb) | 12/9/19 | 3.6 | N/A | 50 | 30 | Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive) |
| Tetrachloroethene – PCE – Well* (ppb) | 4/2/20 11/16/20 | 8.0 | 7.3 – 8.7 | 5 | 0.06 | Discharge from factories, dry cleaners, and auto shops (metal degreaser) |

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL | PHG (MCLG) | Typical Source of Contaminant |
|---|-------------|----------------|---------------------|-------|------------|---|
| Chloride (ppm) | 12/27/16 | 43 | N/A | 500 | N/A | Runoff/leaching from natural deposits; seawater influence |
| Specific Conductance (µS/cm) | 12/9/19 | 1,000 | N/A | 1,600 | N/A | Substances that form ions when in water; seawater influence |
| Sulfate (ppm) | 12/27/16 | 75 | N/A | 500 | N/A | Runoff/leaching from natural deposits; industrial wastes |
| Total Dissolved Solids – TDS (ppm) | 12/27/16 | 600 | N/A | 1,000 | N/A | Runoff/leaching from natural deposits |
| Turbidity (NTU) | 12/24/16 | 0.33 | N/A | 5 | N/A | Soil runoff |

Table 6. Detection of Unregulated Contaminants

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | Notification Level | Health Effects Language |
|---|-------------|----------------|---------------------|--------------------|--|
| Perfluorooctanoic Acid – PFOA (ng/L) | 11/16/20 | 2.6 | N/A | 5.1** | Perfluorooctanoic acid exposures resulted in increased liver weight in laboratory animals. |
| Perfluorooctanesulfonic Acid – PFOS (ng/L)** | 11/16/20 | 10 | N/A | 6.5** | Perfluorooctanesulfonic acid exposures resulted in immune suppression, specifically, a decrease in antibody response to an exogenous antigen challenge. |

*Any violation of an MCL, MRDL, Notification Level, or TT is asterisked. Additional information regarding the violation is provided later in this report.

** The July 2018 notification levels for PFOA of 14 ng/L and PFOS of 13 ng/L were superseded on August 22, 2019 by new notification levels of 5.1 ng/L for PFOA and 6.5 ng/L for PFOS.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

The unregulated contaminant PFOS was found at levels that exceeded the notification level for those parameters set by the State of California. The health effects are described in Table 6 above. For more information regarding PFOS, please visit <https://www.waterboards.ca.gov/pfas/>. We will keep you updated as new results and/or monitoring requirements are available.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

| Violation | Explanation | Duration | Actions Taken to Correct Violation | Health Effects Language |
|--|--|----------|--|---|
| Raw Well MCL Exceedance: Tetrachloroethene (PCE) | Due to aquifer conditions beyond our control, samples collected at the well have routinely exceeded the MCL for Tetrachloroethene (PCE). | Ongoing | Toyota San Luis Obispo uses two reverse osmosis (RO) systems to treat its well water for Tetrachloroethene (PCE) and Trichloroethene (TCE). Water is tested monthly after treatment for both parameters; the results of all treated samples collected during 2020 were non-detect. | Some people who use water containing tetrachloroethene in excess of the MCL over many years may experience liver problems and may have an increased risk of getting cancer. |