

2022 Consumer Confidence Report

Water System Information

Water System Name: **Country Hills Estates Mutual Water Company**

Report Date: **June 21, 2023**

Type of Water Source(s) in Use: **Groundwater Wells**

Name and General Location of Source(s): **Wells 1 and 2 are located within the development.**

Drinking Water Source Assessment Information: **The most recent inspection report is available upon request from Country Hills Estates Mutual Water Company or the San Luis Obispo County Public Health Department.**

Time and Place of Regularly Scheduled Board Meetings for Public Participation: **Meetings are held annually, and more frequently as needed. Location and time are announced in advance.**

For More Information, Contact: **Paul Edwards, (805) 888-7943**

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Country Hills Estates Mutual Water Company a PO Box 1273, Arroyo Grande, CA 93421, (805) 888-7943 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Country Hills Estates Mutual Water Company 以获得中文的帮助: PO Box 1273, Arroyo Grande, CA 93421, (805) 888-7943.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Country Hills Estates Mutual Water Company, PO Box 1273, Arroyo Grande, CA 93421 o tumawag sa (805) 888-7943 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Country Hills Estates Mutual Water Company tại PO Box 1273, Arroyo Grande, CA 93421, (805) 888-7943 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Country Hills Estates Mutual Water Company ntawm PO Box 1273, Arroyo Grande, CA 93421, (805) 888-7943 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	June 2022	5	ND	0	15	0.2	N/A	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	June 2022	5	0.595	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	5/24/2022	41.5	36 – 47	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	5/24/2022	50	43 – 57	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic – Treated (ppb)	2022 (various)	0.38	ND – 7.3	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Arsenic – Wells (ppb)	2022 (various)	31.7	22 – 44			

Table 4. Detection of Contaminants with a Primary Drinking Water Standard, Continued

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Chlorine Residual	2022 (various)	1.55	0.75 – 4.40	[4.0 (as Cl ₂)]	[4 (as Cl ₂)]	Drinking water disinfectant added for treatment
Fluoride (ppm)	5/24/2022	0.92	0.54 – 1.30	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha (pCi/L)	7/25/2016 5/24/2022	0.393	ND – 0.786	15	(0)	Erosion of natural deposits
Total Trihalomethanes – TTHMs (ppb)	9/30/20	2	N/A	80	N/A	Byproduct of drinking water disinfection

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	5/24/2022	46	42 – 50	500	N/A	Runoff/leaching from natural deposits; seawater influence
Color (units)	5/24/2022	5	N/A	15	N/A	Naturally-occurring organic materials
Iron (ppb)*	5/24/2022	465	400 – 530	300	N/A	Leaching from natural deposits; industrial wastes
Manganese (ppb)*	5/24/2022	65	52 – 78	50	N/A	Leaching from natural deposits
Specific Conductance – Distribution (units)	5/24/2022	340	N/A	1,600	N/A	Substances that form ions when in water; seawater influence
Specific Conductance – Wells (units)	5/24/2022	305	300 – 310			
Sulfate (ppm)	5/24/2022	22	N/A	500	N/A	Runoff/leaching from natural deposits; industrial wastes

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard, Continued

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids – TDS (ppm)	5/24/2022	245	230 – 260	1,000	N/A	Runoff/leaching from natural deposits
Turbidity (NTU)	5/24/2022	1.80	0.99 – 2.60	5	N/A	Soil runoff

**Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.*

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Country Hills Estates Mutual Water Company is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Iron and manganese were found at levels that exceeded the secondary MCL (Maximum Contaminant Level) standards. The secondary MCLs were set to protect you against unpleasant aesthetic effects (e.g., color, taste, and odor) and the staining of plumbing fixtures (e.g., tubs and sinks) and clothing while washing. The high levels are most likely due to the leaching of natural deposits and industrial wastes. The notification level for manganese is used to protect consumers from neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system. (The notification level for manganese is 500 ppb.)

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
Arsenic – Raw Well MCL Exceedance	Due to groundwater conditions beyond our control, raw well arsenic results continue to be above the MCL.	Ongoing	Country Hills Estates utilizes Point of Use (POU) treatment systems in each home to reduce arsenic levels to levels that are compliance with the MCL. All residents are encouraged to participate, and those who have opted out are encouraged to investigate treatment options for their homes and if a treatment option is installed, to conduct routine maintenance and repairs to ensure that the system is working properly. The results of all samples collected from the treatment systems within residents' homes were in compliance with the MCL. One home could not be sampled because it is unoccupied.	Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems and may have an increased risk of getting cancer.
Chlorine Residual – Over the MRDL	While conducting routine rounds, staff noted that the chlorine residual was elevated due to changes in well operation requiring a lower dose of chlorine.	Resolved upon discovery	The chlorine pumps were turned down and staff continued to monitor the chlorine levels within the system. Chlorine levels returned to the allowed range after being turned down.	Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.