

## 2025 Consumer Confidence Report

### Water System Information

Water System Name: **Varian Ranch Mutual Water Company**

Report Date: **April 21, 2026**

Type of Water Source(s) in Use: **Groundwater Wells**

Name and General Location of Source(s): **Wells 1 and 3 are located near Orcutt Road and Varian Circle.**

Drinking Water Source Assessment Information: **A source water assessment was conducted for Well 03 in November 2001. Authorization to use the restored Well 01 was received in October 2008. The wells were found to be most at risk of contamination from grazing activities. To date, these activities have not adversely impacted the treated water quality. The most recent system inspection was performed in December 2023 by SLO County Environmental Health Services. All source assessment and SLO County inspection reports are available to customers at [www.varianranch.org](http://www.varianranch.org).**

Time and Place of Regularly Scheduled Board Meetings for Public Participation: **The board meets at 6:30 PM on the second Monday of odd numbered months, at the Varian Ranch Community Center.**

For More Information, Contact: **Rod Curb at (805) 440-3831**

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025, and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Varian Ranch Mutual Water Company a 2060 Varian Circle, Arroyo Grande, CA 93420 o (805) 440-3831 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Varian Ranch Mutual Water Company 以获得中文的帮助: Varian Circle, Arroyo Grande, CA 93420, (805) 440-3831.

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Varian Ranch Mutual Water Company, Varian Circle, Arroyo Grande, CA 93420 o tumawag sa (805) 440-3831 para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Varian Ranch Mutual Water Company tại Varian Circle, Arroyo Grande, CA 93420, (805) 440-3831 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Varian Ranch Mutual Water Company ntawm Varian Circle, Arroyo Grande, CA 93420, (805) 440-3 rau kev pab hauv lus Askiv.

**Terms Used in This Report**

<b>Term</b>	<b>Definition</b>
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter ( $\mu\text{g/L}$ )
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1 – 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	Range of Results	AL	PHG	Typical Source of Contaminant
Lead (ppb)	8/12/2024	10	ND	0	ND	15	0.2	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	8/12/2024	10	0.270	0	0.098 – 0.280	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	7/20/2023 7/8/2025	38.5	38 – 39	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	7/20/2023 7/8/2025	340	320 – 360	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic (ppb)	7/8/2025	4.5	4.1 – 4.9	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	7/20/2023 7/8/2025	0.15	0.12 – 0.15	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	7/20/2023 7/8/2025	0.42	0.36 – 0.48	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha Particle Activity (pCi/L)	4/18/2023 4/2/2024	9.85	5.59 – 14.1	15	(0)	Erosion of natural deposits
Haloacetic Acids – HAAs (ppb)	9/14/2023	1.2	N/A	60	N/A	Byproduct of drinking water disinfection
Hexavalent Chromium (ppb) – Distribution	12/12/2024	ND	N/A	10	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities.
Hexavalent Chromium (ppb) – Raw Wells	12/12/2024	0.40	0.11 – 0.69			
Lead (ppb)	7/20/2023 7/8/2025	1.1	1.0 – 1.2	AL = 15	0.2	Corrosion of household plumbing systems; Erosion of natural deposits
Nickel (ppb)	7/20/2023 7/8/2025	2.75	2.5 – 3.0	100	12	Erosion of natural deposits; discharge from metal factories
Nitrate as N (ppm) – Distribution	7/8/2025	ND	N/A	10 (as N)	10 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate as N (ppm) – Raw Wells	7/8/2025	1.3	ND – 2.6			
Selenium (ppb)	7/20/2023 7/8/2025	4.75	2.4 – 7.1	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard, Continued**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Total Chromium (ppb)	7/20/2023 7/8/2025	1.5	ND – 3.0	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Total Trihalomethanes – TTHMs (ppb)	9/14/2023	4.5	N/A	80	N/A	Byproduct of drinking water disinfection
Combined Radium (pCi/L)	12/17/2025	2.43	1.79 – 3.08	5	0	Erosion of natural deposits
Uranium (pCi/L)	4/14/2020 4/2/2024	8.65	7.40 – 9.9	20	0.43	Erosion of natural deposits

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	7/20/2023 7/8/2025	92	84 – 100	500	N/A	Runoff/leaching from natural deposits; seawater influence
Copper (ppm)	7/20/2023 7/8/2025	0.0061	0.0053 – 0.0068	1.0	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Manganese (ppb)	7/20/2023 7/8/2025	10.5	10 – 11	50	N/A	Leaching from natural deposits
<b>Odor (TON) – Distribution*</b>	<b>7/30/2025 10/8/2025</b>	<b>2.0</b>	<b>ND – 4.0</b>	<b>3</b>	<b>N/A</b>	<b>Naturally-occurring organic materials</b>
<b>Odor (TON) – Raw Wells*</b>	<b>2025 (various)</b>	<b>9.8</b>	<b>ND – 17</b>			
Specific Conductance (µS/cm)	7/20/2023 7/8/2025	875	860 – 890	1,600	N/A	Substances that form ions when in water; seawater influence
Sulfate (ppm)	7/20/2023 7/8/2025	44.5	43 – 46	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids – TDS (ppm)	7/20/2023 7/8/2025	530	530	1,000	N/A	Runoff/leaching from natural deposits
Turbidity (NTU)	7/20/2023 7/8/2025	1.03	0.35 – 1.70	5	N/A	Soil runoff
Zinc (ppm)	7/20/2023 7/8/2025	0.0031	ND – 0.0061	5	N/A	Runoff/leaching from natural deposits; industrial wastes

\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation, if any, is provided later in this report.

### **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Varian Ranch Mutual Water Company is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the Varian Ranch Water System Specialist at (805) 440-3831. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Odor was found at levels that exceeded the secondary MCL (Maximum Contaminant Level) standards. The secondary MCLs were set to protect you against unpleasant aesthetic effects (e.g., color, taste, and odor) and the staining of plumbing fixtures (e.g., tubs and sinks) and clothing while washing. The high levels are most likely due to the leaching of natural deposits, industrial waste, naturally occurring organic materials, and soil runoff. Following the initial odor detections, Varian Ranch began submitting odor samples to additional laboratories for verification and believes the elevated results may be anomalous, as odor evaluations are inherently subjective.

Fluoride is not added to the water at Varian Ranch.

While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.