

## 2025 Consumer Confidence Report

### Water System Information

Water System Name: Daou Vineyards, LLC

Report Date: May 28, 2025

Type of Water Source(s) in Use: Groundwater

Name and General Location of Source(s): Well 01, Well 02, Well 03, and Well 04 are located throughout the Daou Vineyard property at 2777 Hidden Mountain Road, Paso Robles, CA 93446.

Drinking Water Source Assessment Information: Source water assessment information available at County of San Luis Obispo Environmental Health Services. The sources are considered most vulnerable to the following activities not associated with detected contaminants: fertilizer and irrigated crops.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: N/A

For More Information, Contact: Hanna Morford, [hanna.morford@tweglobal.com](mailto:hanna.morford@tweglobal.com).

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2024, and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Daou Vineyards a [hanna.morford@tweglobal.com](mailto:hanna.morford@tweglobal.com) para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Daou Vineyards 以获得中文的帮助: [hanna.morford@tweglobal.com](mailto:hanna.morford@tweglobal.com).

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Daou Vineyards o tumawag sa [hanna.morford@tweglobal.com](mailto:hanna.morford@tweglobal.com) para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Daou Vineyards tại [hanna.morford@tweglobal.com](mailto:hanna.morford@tweglobal.com) để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Daou Vineyards ntawm [hanna.morford@tweglobal.com](mailto:hanna.morford@tweglobal.com) rau kev pab hauv lus Askiv.

## Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variations and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	Range of Results	AL	PHG	Typical Source of Contaminant
Lead (ppb)	2025	5	3.3	0	0 – 6.6	15	0.2	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	2025	5	0.395	0	0.130 – 0.420	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	5/23/2022	30	26-34	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	5/23/2022	507	450-560	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

<b>Chemical or Constituent (and reporting units)</b>	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Source of Contaminant</b>
Arsenic (ug/L)	2025	3.4	0 – 14	10	0.004	Erosion of natural deposits; residue from some surface water treatment processes
Barium (mg/L)	2025	0.034	0 – 0.078	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (hexavalent) (µg/L)	2025	0.033	0.00 – 0.07	10	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production,
Combined Radium (pCi/L)	2020	0.326	0.112 - 0.904	5	(0)	Erosion of natural deposits
Fluoride (mg/L)	2025	0.67	0.55 – 0.76	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
<b>*Gross Alpha Particle Activity (pCi/L)</b>	<b>2020 (Well 1) 2025 (Wells 2, 3, 4)</b>	<b>13.85</b>	<b>8.84 – 18.3</b>	<b>15</b>	<b>(0)</b>	<b>Erosion of natural deposits</b>
Nickel (µg/L)	2025	0.78	0 – 3.1	100	12	Erosion of natural deposits; discharge from metal factories
Nitrate (mg/L)	2025	1.03	0 – 4.1	10	10	Runoff and leaching from fertilizer use;

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
						leaching from septic tanks and sewage; erosion of natural deposits
Selenium	2025	3.5	0 – 14	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Uranium (pCi/L)	2020 (Wells 1 & 2) 2025 (Well 3)	5.65	3.45 – 7.8	20	0.43	Erosion of natural deposits

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (mg/L)	2019, 2022, 2025	63.5	20 – 180	500	–	Runoff/leaching from natural deposits; seawater influence
<b>*Color (units)</b>	<b>2022, 2024, 2025</b>	<b>63.8</b>	<b>0 - 250</b>	<b>15</b>	<b>–</b>	<b>Naturally-occurring organic materials</b>
Copper (mg/L)	2022, 2024, 2025	0.002	0 – 0.006	1	-	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
<b>*Iron (µg/L)</b>	<b>2022, 2024, 2025</b>	<b>2874</b>	<b>0 - 11,000</b>	<b>300</b>	<b>–</b>	<b>Leaching from natural deposits; industrial wastes</b>

<b>Chemical or Constituent (and reporting units)</b>	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>SMCL</b>	<b>PHG (MCLG)</b>	<b>Typical Source of Contaminant</b>
Manganese (µg/L)	2022, 2024, 2025	25	0 - 89	50	–	Leaching from natural deposits
Odor - Threshold (Units)	2022, 2024, 2025	6.5	0 – 24	3	–	Naturally-occurring organic materials
Specific Conductance (µS/cm)	2025	1130	930 – 1600	1,600	–	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	2022, 2024, 2025	175	150 – 230	500	–	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids [TDS] (mg/L)	2022, 2024, 2025	790	600 – 1200	1,000	–	Runoff/leaching from natural deposits
<b>*Turbidity (Units)</b>	<b>2022, 2024, 2025</b>	<b>44.28</b>	<b>0.52 – 170</b>	<b>5</b>	<b>–</b>	<b>Soil runoff</b>
Zinc (mg/L)	2022, 2024, 2025	0.69	0 – 2.70	5	–	Runoff/leaching from natural deposits; industrial wastes

**Table 6. Detection of Unregulated Contaminants**

<b>Chemical or Constituent (and reporting units)</b>	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Health Effects</b>
Boron (mg/L)	2019	0.067	0 - 0.200	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Daou Vineyards is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Daou Vineyards and [hanna.morford@tweglobal.com](mailto:hanna.morford@tweglobal.com). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

**Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

**Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement**

<b>Violation</b>	<b>Explanation</b>	<b>Duration</b>	<b>Actions Taken to Correct Violation</b>	<b>Health Effects Language</b>
Gross Alpha Particle Activity (pCi/L)	Wells 2, 3, and 4 are over the MCL for Gross Alpha Particle Activity.	Ongoing	Quarterly monitoring of wells continue to show Gross Alpha Particle Activity exceeds the MCL in these wells. In addition, the distribution samples in the Production Zone of the water system show levels above the MCL. The water system is currently pursuing point of use treatment devices to provide drinking water that meets the MCL standard. Regulatory approval and installation of the devices is expected to be completed by the end of 2026.	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
Color (units)	Well 1 is over the SMCL for color	Single Event	There is no action required as color is a secondary standard (not a risk to human health). Wells 2, 4, and 4 tested at or below the SMCL for color.	There is no mandatory standard health effects language for this constituent. Secondary MCLs are set on the basis of aesthetics.
Iron (µg/L)	Wells 1 and 4 are over the SMCL for iron	Single Event	There is no action required as iron is a secondary standard (not a risk to human health). Wells 2 and 3 tested below the SMCL for iron.	There is no mandatory standard health effects language for this constituent. Secondary MCLs are set on the basis of aesthetics.
Turbidity (Units)	Wells 1 and 4 are over the SMCL for Turbidity	Single Event	There is no action required as turbidity is a secondary standard (not a risk to human health). Wells 2 and 3 tested below the SMCL for turbidity.	There is no mandatory standard health effects language for this constituent. Secondary MCLs are set on the basis of aesthetics.

**Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements**

**Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation**

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year, the water system was required to conduct one Level 1 assessment. The Level 1 assessment was completed and identified three corrective actions. All corrective actions were completed.

During the past year zero Level 2 assessments were required to be completed for this water system.