

## Appendix 2 – Certification of Completion of Public Notification

Citation Number: 04\_06\_24C\_035

Name of Water System: Oceano Community Services District

System Number: CA4010005

**Attach a copy of the public notice distributed to the water system's customers.**

This form, when completed and sent to [dwpdist06@waterboards.ca.gov](mailto:dwpdist06@waterboards.ca.gov) for the Division of Drinking Water, District 06, certifies that public notification to water users was completed as required by California Code of Regulations, title 22, sections 64463-64465.

Public notification for failure to comply with California Code of Regulations, title 22, section 64421 was conducted on:

Notification was made on 28<sup>th</sup>.

For the month, year of June, 2024.

To summarize report delivery used and good-faith efforts taken, please check all items below that apply and fill-in where appropriate:

### For Community and non-transient non-community public water systems

☐ The notice was distributed by mail or direct delivery to each customer on: \_\_\_\_\_

One or more of the following methods were used to reach persons not likely to be reached by a mailing or direct delivery or persons served by a transient public water system (renters, nursing home patients, prison inmates, etc.):

☒ Posted the notice at the following conspicuous locations served by the water system. (If needed, please attach a list of locations) Oceano Community Services District Office.

☐ Publication of the notice in a local newspaper or newsletter of general circulation (attach a copy of the published notice, including name of newspaper and date published).

☐ Posted the notice on the Internet at [www.](http://www.)\_\_\_\_\_

☒ Other method used to notify customers. 2024 CCR\_

I hereby certify that the above information is factual.

Certified by: Printed Name Tony Marraccino Title Utility Systems Manager

Signature \_\_\_\_\_

Date 7/1/2024

**Disclosure:** Be advised that the California Health and Safety Code sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation or, for continuing violations, for each day that violation continues, or be punished by a fine of not more than \$25,000 for each day of violation, or by imprisonment in the county jail not to exceed one year, or by both the fine and imprisonment

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

Este informe contiene información muy importante sobre su agua potable.  
Tradúzcalo o hable con alguien que lo entienda bien.

**MONITORING REQUIREMENTS NOT MET FOR THE OCEANO COMMUNITY SERVICES DISTRICT**

Our water system failed to monitor as required for drinking water standards during the past year and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. From July 1, 2021, to March 31, 2024, we did not complete all source monitoring for coliform bacteria.

**What should I do?**

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the last year, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

| Location          | Contaminant    | Required Sampling Frequency | Number of Samples Taken | When All Samples Should Have Been Taken        | When Samples Were or Will Be Taken                    |
|-------------------|----------------|-----------------------------|-------------------------|------------------------------------------------|-------------------------------------------------------|
| Well 6 and Well 8 | Total Coliform | Quarterly                   | 0                       | Quarterly from July 1, 2021, to March 31, 2024 | Quarterly Sampling has started and will continue 2024 |

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

**What happened? What is being done?**

The period from July 1, 2021, to March 31, 2024 Oceano Community Service District failed to test our primary and back-up wells for Total Coliform. Oceano Community Services District tested the distribution system weekly for Total Coliform during that same time period and all results were negative for Total Coliform and E.coli. The system was tested 284 times, all samples came back absent for Total Coliform and E. coli.

While this failure to sample at the wells prior to chlorination, is a violation of the new monitoring and reporting requirements for Oceano Community Services District, the water delivered during this time period did not test positive for Total Coliform in the distribution system.

Oceano Community Services District, will conduct required quarterly Total Coliform sampling at the well head for both wells going forward.

For more information, please contact Tony Marraccino at (805) 574-4860 or 1655 Front St., Oceano, CA 93445

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

### **Secondary Notification Requirements**

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by the Oceano Community Services District

State Water System ID#: CA4010005

Date distributed: June 28, 2024

Si bien esta falta de muestras en los pozos antes de la cloración es una violación de los nuevos requisitos de monitoreo e informes para el Distrito de Servicios Comunitarios de Oceano, el agua entregada durante este período no dio positivo para coliformes totales en el sistema de distribución.

El Distrito de Servicios Comunitarios de Oceano llevará a cabo las muestras trimestral de coliformes totales requerido en la boca del pozo para ambos pozos en el futuro.

Para obtener más información, comuníquese con Tony Marraccino al (805) 574-4860 o 1655 Front St., Oceano, CA 93445.

Comparta esta información con todas las demás personas que beben esta agua, especialmente aquellas que quizás no hayan recibido este aviso directamente (por ejemplo, personas en apartamentos, hogares de ancianos, escuelas y negocios). Puede hacerlo publicando este aviso público en un lugar público o distribuyendo copias a mano o por correo.

#### Requisitos de notificación secundaria

Al recibir la notificación de una persona que opera un sistema público de agua, se debe dar la siguiente notificación dentro de los 10 días [Código de Salud y Seguridad, Sección 116450(g)]:

- **ESCUELAS:** Deben notificar a los empleados de la escuela, estudiantes y padres (si los estudiantes son menores de edad).
- **PROPIETARIOS O ADMINISTRADORES DE PROPIEDADES DE ALQUILER RESIDENCIALES** (incluidos hogares de ancianos y centros de atención): deben notificar a los inquilinos.
- **DUEÑOS, ADMINISTRADORES U OPERADORES DE PROPIEDADES DE NEGOCIOS:** Deben notificar a los empleados de los negocios ubicados en la propiedad.

Este aviso le está siendo enviado por el Distrito de Servicios Comunitarios de Oceano.

Número de identificación del sistema de agua estatal: CA4010005

Fecha de distribución: 28 de junio de 2024

INFORMACIÓN IMPORTANTE SOBRE SU AGUA POTABLE

Este informe contiene información muy importante sobre su agua potable.

REQUISITOS DE MONITOREO NO FUERON CUMPLIDOS POR EL DISTRITO DE SERVICIOS COMUNITARIOS DE OCEANO

Nuestro sistema de agua no realizó el monitoreo requerido por los estándares de agua potable durante el año pasado y, por lo tanto, violó las regulaciones. Aunque esta falla no fue una emergencia, como clientes nuestros, tienen derecho a saber qué deben hacer, qué sucedió y qué hicimos para corregir esta situación.

Estamos obligados a controlar periódicamente el agua potable para detectar contaminantes específicos. Los resultados del monitoreo regular son un indicador de si nuestra agua potable cumple o no con los estándares de salud. Desde el 1 de julio de 2021 hasta el 31 de marzo de 2024, no completamos todos los monitoreos de fuentes para bacterias coliformes.

¿Qué tengo que hacer?

- No hay nada que deba hacer en este momento.
- La siguiente tabla enumera los contaminantes que no analizamos adecuadamente durante el último año, cuántas muestras debemos tomar y con qué frecuencia, cuántas muestras tomamos, cuándo deberían haberse tomado las muestras y la fecha en qué muestras de seguimiento se tomaron (o se tomarán).

| Ubicación       | Contaminante    | Frecuencia Requerida de Muestras | Número de Muestras Tomado | Cuando todo Muestras Debería tener Ha sido tomada               | Cuando las muestras Fueron o serán Tomado                 |
|-----------------|-----------------|----------------------------------|---------------------------|-----------------------------------------------------------------|-----------------------------------------------------------|
| Pozo 6 y Pozo 8 | Total coliforme | Trimestral                       | 0                         | Trimestralmente desde 1 de julio de 2021 al 31 de marzo de 2024 | Trimestral El muestreo ha comenzado y continuará en 2024. |

- Si tiene problemas de salud relacionados con el consumo de esta agua, puede desea consultar a su médico.

¿Qué pasó? ¿Lo que se está haciendo?

Durante el período comprendido entre el 1 de julio de 2021 y el 31 de marzo de 2024, el Distrito de Servicios Comunitarios de Oceano no realizó pruebas de coliforme total en nuestros pozos primarios y de respaldo. El Distrito de Servicios Comunitarios de Oceano tomó muestras del sistema de distribución semanalmente para coliforme total durante ese mismo período y todos los resultados fueron negativos para coliforme total y E.coli. El sistema fue examinado 284 veces y todas las muestras resultaron ausentes de coliformes totales y E. coli.