

## 2024 Consumer Confidence Report

### Water System Information

Water System Name: **Woodlands Mutual Water Company**

Report Date: **June 6, 2025**

Type of Water Source(s) in Use: **Groundwater Wells**

Name and General Location of Source(s): **Well 2 is located on Homestead Road; Well 3 is located on Mesa Road; Well 4 is located on Dawn Road.**

Drinking Water Source Assessment Information: **A Drinking Water Source Assessment and Protection study was previously completed; there have been no changes to the source water vulnerability since that study was completed. More information is available from the State Water Resources Control Board Division of Drinking Water, Santa Barbara District at 1180 Eugenia Place, Suite 200, Carpinteria, CA 93013 or by calling (805) 566-5208.**

Time and Place of Regularly Scheduled Board Meetings for Public Participation: **Meetings are held annually in July and quarterly as needed; time and location are announced in advance.**

For More Information, Contact: **Woodlands Mutual Water Company at (805) 540-5208**

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2024, and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Woodlands Mutual Water Company a PO Box 19, Arroyo Grande, CA 93421 o (805) 540-5208 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Woodlands Mutual Water Company 以获得中文的帮助: PO Box 19, Arroyo Grande, CA 93421, (805) 540-5208.

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Woodlands Mutual Water Company, PO Box 19, Arroyo Grande, CA 93421 o tumawag sa (805) 540-5208 para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Woodlands Mutual Water Company tại PO Box 19, Arroyo Grande, CA 93421, (805) 540-5208 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Woodlands Mutual Water Company ntawm PO Box 19, Arroyo Grande, CA 93421, (805) 540-5208 rau kev pab hauv lus Askiv.

## Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, 7, 8, and 9 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	2024 (various)	10	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2024 (various)	10	0.095	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	7/30/2024	51.6	35 – 80	None	None	Salt present in the water and is generally naturally occurring
Hardness – Distribution (ppm)	7/30/2024	380	N/A	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
Hardness – Wells (ppm)	7/30/2024	249	58 – 630			

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

<b>Chemical or Constituent (and reporting units)</b>	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Source of Contaminant</b>
Barium (ppm)	7/19/2023 9/11/2023	0.024	0.021 – 0.026	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
<b>Chlorine (ppm)*</b>	<b>2024 (various)</b>	<b>1.54</b>	<b>0.05 – 3.29</b>	<b>[MRDL = 4.0 (as Cl<sub>2</sub>)]</b>	<b>[MRDLG = 4 (as Cl<sub>2</sub>)]</b>	<b>Drinking water disinfectant added for treatment</b>
Chromium (ppb)	7/19/2023 9/11/2023	3.27	3.1 – 3.4	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	7/19/2023 9/11/2023	0.16	ND – 0.28	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha Particle Activity (pCi/L)	6/16/2021 4/9/2024	2.33	0.235 – 5.31	15	(0)	Erosion of natural deposits
Hexavalent Chromium (ppb)	7/19/2023 9/11/2023	1.37	ND – 2.7	10	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities.
Nickel (ppb)	7/19/2023 9/11/2023	2.07	ND – 3.9	100	12	Erosion of natural deposits; discharge from metal factories

**Table 5. Detection of Contaminants with a Primary Drinking Water Standard, Continued**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate as N – Distribution (ppm)	2024 (various)	3.88	3.6 – 4.2	10 (as N)	10 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate as N – Wells (ppm)	2024 (various)	3.82	0.95 – 6.1			
Selenium (ppb)	7/19/2023 9/11/2023	2.53	1.8 – 3.2	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Total Trihalomethanes – TTHM (ppb)	10/3/2024	1.1	N/A	80	N/A	Byproduct of drinking water disinfection

**Table 6. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	7/30/2024	45.7	41 – 49	500	N/A	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	7/30/2024	63.3	ND – 190	300	N/A	Leaching from natural deposits; industrial wastes
Specific Conductance (µS/cm)	7/30/2024	643.3	310 – 1,300	1,600	N/A	Substances that form ions when in water; seawater influence
Sulfate (ppm)	7/30/2024	172.7	16 – 470	500	N/A	Runoff/leaching from natural deposits; industrial wastes

**Table 7. Detection of Contaminants with a Secondary Drinking Water Standard, Continued**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids – TDS – Distribution (ppm)	2024 (various)	617.5	510 – 740	1,000	N/A	Runoff/leaching from natural deposits
<b>Total Dissolved Solids – TDS – Wells (ppm)*</b>	<b>2024 (various)</b>	<b>594</b>	<b>200 – 1,100</b>	<b>1,000</b>	<b>N/A</b>	<b>Runoff/leaching from natural deposits</b>
Turbidity (NTU)	2023 (various)	1.97	0.15 – 7.8	5	N/A	Soil runoff

**Table 8. Detection of Unregulated Contaminants**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Boron (ppm)	7/30/2024	0.07	ND – 0.2	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Silica (ppm)	12/19/2017	43	N/A	N/A	N/A

\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Woodlands Mutual Water Company is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If

you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Total Dissolved Solids (TDS) was found at a level that exceeded the secondary MCL (Maximum Contaminant Level) standard in a single sample collected from one well. The secondary MCLs were set to protect you against unpleasant aesthetic effects (e.g., color, taste, and odor) and the staining of plumbing fixtures (e.g., tubs and sinks) and clothing while washing. The high levels are most likely due to runoff or leaching from natural deposits.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 9. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
Distribution Chlorine Residual Less than 0.20 ppm	During a routine bacteriological sampling event, the field chlorine residual recorded by the sampler for one sample location was less than 0.20 ppm, which is the minimum chlorine residual allowed by law.	All other chlorine residuals recorded were within normal levels.	Staff continued to monitor chlorine residuals daily. All other chlorine residual samples collected in 2024 were in compliance.	Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.