


**Consumer Confidence Report
Certification Form**
(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: Mid-Peninsula Water District

Water System Number: 4110001

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6-28-2019 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Rick Bisio
Signature: 
Title: Lead Operator- Water Quality
Phone Number: (650) 591-8941 Date: June 28, 2019

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: _____

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- Posting the CCR on the Internet at www.midpeninsulawater.org _____
- Mailing the CCR to postal patrons within the service area (attach zip codes used)
- Advertising the availability of the CCR in news media (attach copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www._____

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).

MPWD 2018 CONSUMER CONFIDENCE REPORT

1929




2019



DEDICATED TO DELIVERING QUALITY WATER FOR 90 YEARS

MidPeninsulaWater.org



ABOUT MPWD

MID-PENINSULA
WATER DISTRICT

3 Dairy Lane
Belmont, CA 94002
650-591-8941
www.MidPeninsulaWater.org

BOARD OF DIRECTORS

The Board of Directors meets every fourth Thursday of the month at 6:30 p.m. at 3 Dairy Lane, Belmont.

Louis J. Vella
President

Matthew P. Zucca
Vice President

Dave Warden
Director

Brian Schmidt
Director

Kirk R. Wheeler
Director

OFFICERS

Tammy Rudock
General Manager

Candy Piña
*Board Secretary /
Administrative Service Manager*

Rene Ramirez
Operations Manager

Julie Sherman
District Counsel

Joubin Pakpour
District Engineer

Jeff Ira
District Treasurer



California Special
Districts Association
Districts Serving Together

MPWD's Mission: Then & Now

A lot has changed in 90 years. In 1929, bread cost 10¢, milk was 15¢, and a postage stamp would set you back 2¢. Cars and radios were just transitioning into everyday American life. The first Oscar Award was presented that year... *to a silent film!* And the seemingly eternal Golden Gate Bridge was still years away from being built.

On July 2 of that same year, a small water district was incorporated under the County Water District Act of California. The Belmont County Water District, which later became the Mid-Peninsula Water District (MPWD), began supplying water from the Hetch Hetchy Regional Water System to the local community. For MPWD, a lot has changed in 90 years, as well. But one thing has not changed for MPWD over the generations – ***its commitment to provide its customers with a safe, high-quality, reliable supply of water.***

Today, MPWD serves approximately 28,000 people over five square miles via a gravity fed system that includes nine pumping stations, ten storage tanks, and delivery of 2.5 to 4.8 million gallons of water per day. It's a great responsibility requiring diligent maintenance, management, and commitment.

The employees and Board of Directors of MPWD remain dedicated to our Mission as we celebrate 90 years of service within our community. This year's water quality report – as well as our recent accomplishments and achievements – affirms our commitment:

- The MPWD 5-year Capital Improvement Program is well underway modernizing our water delivery infrastructure.
- Recipient of the American Public Works Association, Silicon Valley Chapter's Honor Award for the joint capital project with the City of Belmont.
- Recipient of the Special District Leadership Foundation District Transparency Certificate of Excellence.
- 98% completion of the installation of Automated Metering Infrastructure meters.

MPWD not only looks forward to delivering quality water to our community for the next 90 years, but we are actually making it happen today. Follow along with us in our 90th anniversary at MidPeninsulaWater.org and join us at the City of Belmont National Night Out event on August 6 and our Fall Hands-On Workshop in October. ■



This report contains important information about our drinking water. Translate it, or speak with someone who understands it.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse MPWD para asistirlo en español con alguien que lo entienda bien.

此份水質報告，內有重要資訊。請找他人為你翻譯和解說清楚。

Protecting Our Watersheds

The SFPUC conducts watershed sanitary surveys for the Hetch Hetchy source annually and the local water sources as well as UNHHS every five years. The latest local sanitary survey was completed in 2016 for the period of 2011-2015. The last watershed sanitary survey for UNHHS was conducted in 2015 as part of the SFPUC's drought response plan efforts. These surveys evaluate the sanitary conditions, water quality, potential contamination sources and the results of watershed management activities. With support from partner agencies including National Park Service and US Forest Service, these surveys identified wildlife, stock, and human activities as potential contamination sources. You may contact the San Francisco District office of SWRCB-DDW at 510-620-3474 for review of these reports. ■



Special Health Needs

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly people and infants, can be particularly at risk from infections.

These people should seek advice about drinking water from their healthcare providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline 800-426-4791 or at www.epa.gov/safewater ■

Drinking Water and Lead

The SFPUC's annual monitoring of the water sources in 2018 continues to demonstrate that there is no lead detected. There are no known lead service lines in our distribution system. If lead was detected in tap water, it is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. It is possible that lead levels at your home in the community may be higher than at others because of plumbing materials used in your property.

Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the USEPA's Safe Drinking Water Hotline 800-426-4791, or at www.epa.gov/lead ■

Taste and Odor Treatment at SVWTP

In response to an increase in the magnitude and frequency of algal blooms in Calaveras Reservoir and San Antonio Reservoir, the SFPUC initiated a taste and odor (T&O) control program for the SVWTP in 2018. The program will address seasonal taste and odor resulting from algal blooms in the reservoirs. The first component of this program is to a Powdered Activated Carbon facility to mitigate the occurrence of taste and odor compounds. A secondary benefit of using carbon for treatment will reduce the color of the water and formation of disinfection byproducts. The long-term component of the program is an ozonation treatment facility that is currently in design phase. ■



WATER QUALITY

The SFPUC's Water Quality Division (WQD) regularly collects and tests water samples from reservoirs and designated sampling points throughout the system to ensure the water delivered to you meets or exceeds federal and state drinking water standards. In 2018, WQD staff conducted more than 57,690 drinking water tests in the source, transmission, and distribution system. This is in addition to the extensive treatment process control monitoring performed by the SFPUC's certified operators and online instruments.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. In order to ensure that tap water is safe to drink, the USEPA and SWRCB-DDW prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Fluoridation and Dental Fluorosis

Mandated by State law, water fluoridation is a widely accepted practice proven to be safe and effective for preventing and controlling tooth decay. Our fluoride target level in the water is 0.7 milligram per liter (mg/L, or part per million, ppm), consistent with the May 2015 State regulatory guidance on optimal fluoride level. Infants fed formula mixed with water containing fluoride at this level may still have a chance of developing tiny white lines or streaks in their teeth. These marks are referred to as mild to very mild fluorosis, and are often only visible under a microscope. Even in cases where the marks are visible, they do not pose any health risk. The Centers of Disease Control (CDC) considers it safe to use optimally fluoridated water for preparing infant formula. To lessen this chance of dental fluorosis, you may choose to use low-fluoride bottled water to prepare infant formula. Nevertheless, children may still develop dental fluorosis due to fluoride intake from other sources such as food, toothpaste and dental products.

Contact your healthcare provider or SWRCB-DDW if you have concerns about dental fluorosis. For additional information about fluoridation or oral health, visit the SWRCB-DDW website www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Fluoridation.shtml or the CDC website www.cdc.gov/fluoridation ■



Taste, Odor, or Discolored Water Issue?

Opening a faucet or two in your home or business, or an outside spigot, to let the water run for a couple of minutes should resolve it. Remember to capture the water in a bucket to use for watering indoor plants or outdoor landscaping!

Depending upon the water turnover in the mainline serving your connection, or seasonal fluctuations in water treatment by San Francisco Water, a temporary water quality issue could be quickly resolved with a mini-flushing of your service line. If the problem persists, please contact us at **650-591-8941**. ■

KEY WATER QUALITY TERMS

The following are definitions of key terms referring to standards and goals of water quality noted on the data table.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs or MCLGs as is economically and technologically feasible. Secondary MCLs (SMCLs) are set to protect the odor, taste, and appearance of drinking water.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Regulatory Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Turbidity: A water clarity indicator that measures cloudiness of the water, and is also used to indicate the effectiveness of the filtration system. High turbidity can hinder the effectiveness of disinfectants.

Cryptosporidium is a parasitic microbe found in most surface water. We regularly test for this waterborne pathogen and found it at very low levels in source water and treated water in 2018. However, current test methods approved by the USEPA do not distinguish between dead organisms and those capable of causing disease. Ingestion of *Cryptosporidium* may produce symptoms of nausea, abdominal cramps, diarrhea, and associated headaches. *Cryptosporidium* must be ingested to cause disease, and it may be spread through means other than drinking water.

CONTAMINANTS AND REGULATIONS

Generally, the sources of drinking water (both tap water and bottled water) include rivers, lakes, oceans, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Such substances are called contaminants, and may be present in source water as:

Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides that may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline 800-426-4791, or at www.epa.gov/safewater

MPWD's Water Quality Data for Calendar Year 2018

The table below lists all 2018 detected drinking water contaminants and the information about their typical sources. Contaminants below detection limits for reporting are not shown, in accord with regulatory guidance. The SFPUC holds a SWRCB-DDW monitoring waiver for some contaminants and therefore their monitoring frequencies are less than annual.

DETECTED CONTAMINANTS ¹							
TURBIDITY	Unit	MCL	PHG or (MCLB)	Range or Level Found	Average or [Max]	Major Sources in Drinking Water	
Unfiltered Hetch Hetchy Water	NTU	5	N/A	0.3 - 0.8 ⁽²⁾	[1.8]	Soil runoff	
Filtered Water from Sunol Valley Water Treatment Plant (SVWTP)	NTU	1 ⁽³⁾	N/A	-	[1]	Soil runoff	
	-	Min 95% of samples ≤ 0.3 NTU ⁽³⁾	N/A	99.96 - 100%	-	Soil runoff	
Filtered Water from Harry Tracy Water Treatment Plant (HTWTP)	NTU	1 ⁽³⁾	N/A	-	[0.07]	Soil runoff	
	-	Min 95% of samples ≤ 0.3 NTU ⁽³⁾	N/A	100%	-	Soil runoff	
DISINFECTION BYPRODUCTS AND PRECURSOR							
Total Trihalomethanes	ppb	80	N/A	29.1 - 55.1	44.0 ⁽⁴⁾	Byproduct of drinking water disinfection	
Haloacetic Acids	ppb	60	N/A	19.0 - 42.0	32.4 ⁽⁴⁾	Byproduct of drinking water disinfection	
Total Organic Carbon ⁽⁵⁾	ppm	TT	N/A	1.2 - 2.9	2.2	Various natural and man-made sources	
MICROBIOLOGICAL							
Total Coliform ⁽⁶⁾	-	NoP ≤ 5.0% of monthly samples	(0)	-	0	Naturally present in the environment	
<i>Giardia lamblia</i>	cyst/L	TT	(0)	0 - 0.24	0.03	Naturally present in the environment	
INORGANICS							
Fluoride (source water) ⁽⁷⁾	ppm	2.0	1	ND - 0.7	0.3 ⁽⁸⁾	Erosion of natural deposits; water additive to promote strong teeth	
Chloramine (as chlorine)	ppm	MRDL = 4.0	MRDLG = 4	0.73 - 3.01	2.35 ⁽⁸⁾	Drinking water disinfectant added for treatment	
KEY							
< / ≤ =	less than / less than or equal to		N/A =	Not Available		ORL =	Other Regulatory Level
AL =	Action Level		ND =	Non-detect		ppb =	part per billion
Max =	Maximum		NL =	Notification Level		ppm =	part per million
Min =	Minimum		NoP =	Number of Coliform-Positive Sample		µS/cm =	microSiemens / centimeter
			NTU =	Nephelometric Turbidity Unit			

DETECTED CONTAMINANTS¹

CONSTITUENTS WITH SECONDARY STANDARDS

Constituent	Unit	SMCL	PHG	Range	Average	Major Sources of Contaminant
Chloride	ppm	500	N/A	<3 - 17	8.9	Runoff / leaching from natural deposits
Color	unit	15	N/A	<5 - 7	<5	Naturally-occurring organic materials
Specific Conductance	µS/cm	1600	N/A	29 - 221	154	Substances that form ions when in water
Sulfate	ppm	500	N/A	0.9 - 29	16	Runoff / leaching from natural deposits
Total Dissolved Solids	ppm	1000	N/A	<20 - 144	82	Runoff / leaching from natural deposits
Turbidity	NTU	5	N/A	ND - 0.3	0.1	Soil runoff

LEAD AND COPPER

Constituent	Unit	AL	PHG	Range	90th Percentile	Major Sources in Drinking Water
Copper	ppb	1300	300	8.8 - 394 ⁽¹⁰⁾	67.6	Internal corrosion of household water plumbing systems
Lead	ppb	15	0.2	<1 - 18 ⁽¹¹⁾	2.7	Internal corrosion of household water plumbing systems

OTHER WATER QUALITY PARAMETERS

Parameter	Unit	ORL	Range	Average
Alkalinity (as CaCO ₃)	ppm	N/A	<3 - 132	51
Boron	ppb	1000 (NL)	ND - 104	ND
Bromide	ppb	N/A	<5 - 27	7
Calcium (as Ca)	ppm	N/A	2.9 - 18	11
Chlorate ⁽¹²⁾	ppb	(800) NL	42 - 230	124
Chromium (VI) ⁽¹³⁾	ppb	N/A	0.031 - 0.1	0.068
Hardness (as CaCO ₃)	ppm	N/A	15 - 68	47
Magnesium	ppm	N/A	<0.2 - 6.2	4.0
pH	-	N/A	8.6 - 9.8	9.4
Potassium	ppm	N/A	0.2 - 1.0	0.6
Silica	ppm	N/A	2.8 - 7.1	5.0
Sodium	ppm	N/A	2.3 - 20	14
Strontium	ppb	N/A	12 - 199	99



FOOTNOTES

- (1) All results met State and Federal drinking water health standards and were confirmed by the MPWD.
- (2) These are monthly average turbidity values measured every 4 hours daily.
- (3) There is no turbidity MCL for filtered water. The limits are based on the TT requirements for filtration systems.
- (4) This is the highest locational running annual average value.
- (5) Total organic carbon is a precursor for disinfection byproduct formation. The TT requirement applies to the filtered water from the SVWTP only.
- (6) The Mid-Peninsula Water District had zero positives for Total Coliform In 2018.
- (7) In May 2015, the SWRCB recommended an optimal fluoride level of 0.7 ppm be maintained in the treated water. In 2018, the range and average of the fluoride levels were 0.6 ppm - 1.0 ppm and 0.7 ppm, respectively.
- (8) The natural fluoride level in the Hetch Hetchy supply was ND. Elevated fluoride levels in the SVWTP and HTWTP raw water are attributed to the transfer of fluoridated Hetch Hetchy water into the local reservoirs.

- (9) This is the highest running annual average value.
- (10) The most recent Lead and Copper Rule monitoring was in 2018. 0 of 32 site samples collected at consumer taps had copper concentrations above the AL.
- (11) The most recent Lead and Copper Rule monitoring was in 2018. 1 of 32 site samples collected at consumer taps had lead concentrations above the AL.
- (12) The detected chlorate in the treated water is a degradation product of sodium hypochlorite used by the SFPUC for water disinfection.
- (13) Chromium (VI) has a PHG of 0.02 ppb but no MCL. The previous MCL of 10 ppb was withdrawn by the SWRCB-DDW on September 11, 2017. Currently, the SWRCB-DDW regulates all chromium through a MCL of 50 ppb for Total Chromium, which was not detected in our water in 2018.

NOTE: Additional water quality data may be obtained by calling the Mid-Peninsula Water District phone number at 650-591-8941.



Produced with eco-friendly printing and paper.

MPWD 2018 CONSUMER CONFIDENCE REPORT

Our Drinking Water Sources and Treatment

Supplied by the San Francisco Regional Water System (SFRWS), which is owned and operated by the San Francisco Public Utilities Commission (SFPUC), our major water source originates from spring Yosemite National Park snowmelt flowing down the Tuolumne River to storage in Hetch Hetchy Reservoir. The well protected Sierra water source is exempt from filtration requirements by the United States Environmental Protection Agency (USEPA) and the State Water Resources Control Board's Division of Drinking Water (SWRCB-DDW). Water from Hetch Hetchy Reservoir receives the following treatment to meet the appropriate drinking water standards for consumption: ultraviolet light and chlorine disinfection, pH adjustment for optimum corrosion

control, fluoridation for dental health protection, and chloramination for maintaining disinfectant residual and minimizing the formation of regulated disinfection byproducts.

The Hetch Hetchy water is supplemented with surface water from local watersheds and upcountry non-Hetch Hetchy sources (UNHHS). Rainfall and runoff from the 35,000-acre Alameda Watershed in Alameda and Santa Clara counties are collected in Calaveras Reservoir and San Antonio Reservoir before delivery to the Sunol Valley Water Treatment Plant (SVWTP). In 2018, the UNHHS was not used. Water at the Sunol Valley Treatment Plant is subject to filtration, disinfection, fluoridation, optimum corrosion control, and taste and odor removal. ■

