

2022 Consumer Confidence Report

Water System Name: **BOBCAT SPRINGS**

Report Date: **February 2023**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: **Two primary wells drawing from the Paso Robles and Careaga formations Aquifers and two emergency wells.**

Name & general location of source(s): Our primary well is the "Partner's" well. It produces 230 gpm, 8" diameter PVC, and 430' deep. It was constructed in 1996. Our newest well "5" is 500' deep and produces 100 gpm. Our backup well "Bleak" produces 125 gallons per minute (gpm). It is 8" diameter of stainless steel and 550' deep. It was constructed in 1995. "Well E" is only used for emergency purposes, producing 50 gpm, 8" diameter PVC and 520' deep. Our water storage is two 125,000 gallon concrete tanks. The water is chlorinated at each well site before being pumped into approximately 5 miles of PVC distribution main lines, serving 44 parcels. A radio telemetry system controls the wells and booster pumps with the storage tanks. We have an alarm system for low and high water storage alarms.

Drinking Water Source Assessment information: **The source water assessment was completed by Environmental Health Services and is available upon request to the water company.**

Time and place of regularly scheduled board meetings for public participation: **held approximately every two months. Call for the date of the next scheduled meeting, Mike Adrianson (805) 453-1944**

For more information, contact: **David G. Mexico** Phone: **(805) 896-3723**

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a mo.) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	09/20	5	ND	0	15	0.2		Internal corrosion of

							household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	09/20	5	.51 ppm	0	1.3	0.3	Not applicable Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	02/22	58 avg.	32-83 mg/L	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	02/22	297 avg.	83-510 mg/L	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Alpha Activity, Gross	02/22	6.4pCi/L		15	N/A	Erosion of natural deposits
Uranium	02/22	4.8 pCi/L.		20		Erosion of natural deposits
Radium 228	12/19	1.38 pCi/L avg.	.93-1.82	5		Erosion of natural deposits
*Arsenic, Treated	2022 Avg.	8.9 ppb Upper blend	8.4-9.7 ppb	10	.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
*Arsenic, Wells	2022	9.2 ppb avg Well 5 and Partner Well	5.3-13 ppb	10	.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Fluoride	02/22	.52 ppm avg.	.50-.53 mg/L	2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Selenium	02/22	22.0 ppb avg.	7.9-36 ppb	50	50	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
TTHMs [Total Trihalomethanes]	08/22	43.4 ppb		80	n/a	Byproduct of drinking water chlorination
Haloacetic Acid	08/22	6.6 ppb		60	n/a	Drinking water disinfectant added for treatment
Chlorine	2022 Avg.	.93 ppm	.40-1.8 ppm	[MRDL= 4.0 (as Cl ₂)]	n/a	Drinking water disinfectant added for treatment
Nitrates	02/22	1.22 ppm avg.	.73-1.7	10	n/a	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Corrosivity/Langelier	04/04	11.08 Non- corrosive		Non- corrosive	N/A	Natural or industrially-influenced balance of hydrogen, carbon and oxygen in the water; affected by the temperature and other factors.
Odor-Threshold	02/22	4.5 unit avg	4-5	3	N/A	Leaching from natural deposits
Iron	02/22	50 ppb avg	0-100	300		Leaching from natural deposits; Industrial waste
Total dissolved solids	02/22	515 ppm avg	190-840	1000	N/A	Runoff/ leaching from natural deposits deposits
Specific conductance	02/22	750 avg. microhos	300-1200	1,600	N/A	Substances that form natural deposits; sea water influence
Chloride	02/22	55 ppm avg.	24-84 ppm	500	N/A	Runoff/leaching from natural deposits; sea water influence
Sulfate	02/22	172 ppm avg	23-320 ppm	500	N/A	Runoff/leaching from natural deposits; industrial waste
Magnesium	02/22	28.7 ppm avg.	5.4-52 ppm			Leaching from natural deposits
Potassium	02/22	3.2 ppm avg	2.1-4.2			
Zinc	02/22	28 ppb avg.	ND-56 ppb			Runoff/leaching from natural deposits, industrial waste

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Boron	02/22	265 ppb avg.	120-410 ppb		
Vanadium	02/22	5.7 ppb avg.	5.8-6.4 ppb		

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and

components associated with service lines and home plumbing. BOBCAT SPRINGS is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.

* While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

We at Bobcat Springs Mutual Water Company work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
06/22	Missed 6/22 month Arsenic sample	1 month		* see above

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Groundwater TT

SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLE				
NONE				
SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES				
NONE				
VIOLATION OF GROUNDWATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
NONE				

--	--	--	--	--