

**Consumer Confidence Report
Certification Form**
(To be submitted with a copy of the CCR)

Water System Name: Montecito Water District

Water System Number: 4210007

The water system named above hereby certifies that its Consumer Confidence Report was distributed on June 1, 2018 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by: Name: Chad Hurshman
Signature: _____
Title: Water Treatment & Production
Superintendent
Phone Number: (805) 969-2271 Date: 6/28/18

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☒ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- ☒ Posting the CCR at the following URL: www.montecitowater.com/CCR_2017.htm
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☒ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☐ Posted the CCR in public places (attach a list of locations)
 - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - ☒ Delivery to community organizations: **Montecito Association**
 - ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
 - ☒ Electronic announcement of CCR availability via social media outlets: **Facebook, Twitter**
 - ☒ Other : **List on reverse**
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☒ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www.montecitowater.com/CCR_2017.htm __ (Bill Insert & Bill message) _
- ☒ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: [www.montecitowater.com/](http://www.montecitowater.com/CCR_2017.htm)
- ☐ CCR_2017.htm_____
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

Montecito Water District used electronic delivery for the 2017 CCR, and distribution was supported with these procedures:

CCR Posted to Web Site June 1, 2018 at www.montecitowater.com/CCR_2017.htm

Bill Insert / Bill message sent to all District Customers with May Invoice: mailed by June 4, 2018

Direct Email to all District Customers who have an email address associated with their account: sent by June 13, 2018

Social Media Announcement: Twitter & Facebook Post: June 14, 2018

Advertisement placed in Montecito Journal announcing availability of CCR: June 21, 2018

Printed copies of the CCR are available at the District Office.

Printed copies of the CCR are / have been mailed upon request.

CCR availability announced in Press release distributed to local media outlets: June 27, 2018

*This form is provided as a convenience and may be used to meet the certification requirement of
section 64483(c), California Code of Regulations.*



583 San Ysidro Road
Montecito, CA 93108
phone: 805.969.2271
www.montecitowater.com

2017 ANNUAL DRINKING WATER CONSUMER CONFIDENCE REPORT

This report explains where your water comes from, provides information on water quality and how it is measured, and presents the District's 2017 test results which show that **drinking water met, or was better than, state and federal water quality standards.**

OUR WATER SOURCES

SUPPLEMENTAL SURFACE WATER

State Water Project Table A Allocation and Supplemental Water Purchases

San Luis Reservoir stores State Water and supplemental water supplies.

California Aqueduct and the Coastal Branch Pipeline convey water from San Luis Reservoir to Lake Cachuma.

LOCAL SURFACE WATER

Lake Cachuma (A Primary Water Source)

Tecolote Tunnel carries water from Lake Cachuma 6.4 miles through the Santa Ynez mountains to the South Coast.

South Coast Conduit pipeline conveys water from Tecolote Tunnel across the South Coast, from Goleta to Carpinteria.

Cater Treatment Plant
City of Santa Barbara provides treated water to Montecito Water District via the South Coast Conduit.

Jameson Lake (A Primary Water Source)

Doulton Tunnel carries water from Jameson Lake, and water seeps into it providing additional supply.

Bella Vista and Doulton Treatment Plants The District provides treated water from Jameson Lake and Doulton Tunnel to customers.

LOCAL GROUNDWATER

Groundwater wells
District groundwater resources are limited, but provide an important and reliable supply.



POTENTIAL NEW SOURCES

Two Potential New Water Sources

Desalinated water

The District is working toward participation in the regional use of the City of Santa Barbara's desalination facility.

Recycled water

The District facilitates the import of recycled water from South Coast recycled water facilities, and is evaluating recycled water feasibility in Montecito.

CONSERVATION

Efficient use of water by customers reduces overall water use. The District's current conservation target is 30% or more. Conservation is a California way of life!

OUR COMMITMENT TO WATER QUALITY

The District's state-certified water treatment professionals combine round-the-clock monitoring with extensive analysis to ensure compliance with all State and Federal water quality standards.

Steps the District takes to ensure that the water you drink meets requirements:

STEP 1: We begin with a high-quality water supply.

STEP 2: We treat the water with a variety of filtration processes.

STEP 3: We add trace amounts of chlorine to disinfect the water as it travels through the water system.

STEP 4: We test the water. Samples from various locations around the District are analyzed each day in our own laboratory or by independent state-certified labs. Additional testing is conducted each week for bacterial contamination. Results of these and other tests are reported regularly to state authorities. The tests use ultra sensitive measuring equipment and are highly accurate.

Regular water quality testing ensures that your drinking water complies with standards. For more information contact Chad Hurshman, Water Treatment and Production Superintendent, at 805.969.7924.

Para información en español llame 805.969.2271

Este aviso contiene las instrucciones mas recientes para obtener información importante sobre su agua potable. Traducir, o hablar con alguien que lo entienda.



2017 ANNUAL DRINKING WATER CONSUMER CONFIDENCE REPORT

The table below lists all the drinking water contaminants and other constituents that we detected during the 2017 calendar year. We tested for over 180 contaminants and constituents. Not included in the list below are substances for which we test but were not detected. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing conducted between January 1 and December 31, 2017.

The test results below indicate that your water met, or was better than, all primary state and federal water quality standards.

Primary Standards (PDWS)	Units	Maximum Contaminant Level (MCL)	Public Health Goal (MCLG)	Jameson Lake Average	Jameson Lake Range	Ground Water Average	Ground Water Range	Cachuma Lake Average	Cachuma Lake Range	Typical Sources of Contamination
Water Clarity										
Treated Turbidity ³	NTU	TT = 1 NTU TT = 95% of Samples ≤ 0.3	NA	0.05	0.04 - 0.29 99.9%	0.05	ND - 0.20 100%	NA	ND - 0.10 100%	Soil runoff.
Radioactive Contaminants										
Gross Alpha Particle Activity	pCi/L	15	(0)	1.74	1.74	2.63	1.72 - 3.86	ND	NA	Erosion of natural deposits.
Uranium	pCi/L	20	0.43	NA	NA	1.10	0.82 - 1.56	1.0	NA	Erosion of natural deposits.
Inorganic Contaminants										
Aluminum	µg/L	1000	600	10	ND - 20	ND	ND	200	ND - 800	Erosion of natural deposits; residual from some surface water treatment processes.
Arsenic	µg/L	10	0.004	ND	ND	ND	ND	2.3	ND - 4.5	NA Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer Runoff or leaching from fertilizer use; leaching from septic tanks and sewage; erosion from natural deposits Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Boron	µg/L	1000 (RAL)	NA	ND	ND	50	ND - 100	NA	0.54	
Hexavalent Chromium, Cr VI	µg/L	10	0.02	NA	NA	ND	ND	NA	0.027	
Fluoride (not added)	mg/L	2	1	0.2	0.2	0.6	0.5 - 0.7	0.34	ND - 0.53	
Nitrate as N (Nitrogen)	mg/L	10	10	0.1	0.0 - 0.4	2.36	0.9 - 7.2	0.19	ND - 0.71	
Selenium	µg/L	50	30	1	1	10.8	9.0 - 14.0	NA	NA	
Primary Standards for Distribution System	Units	Maximum Contaminant Level (MCL)	Public Health Goal (MCLG)	Distribution System Average		Distribution System Range				Major Sources of Contamination in Drinking Water
Disinfectant										
Free Chlorine Residual	mg/L	MRDLG, 4.0	MRDLG, 4.0	0.66		0.20 - 1.53				Drinking water disinfectant added for treatment.
Disinfection By Products										
Total Trihalomethanes	µg/L	80	NA	Highest LRAA, 76.6		35.8 - 103.0				By-product of drinking water disinfection
Haloacetic Acids	µg/L	60	NA	Highest LRAA, 27.5		7.0 - 44.0				By-product of drinking water disinfection
Bromate (Cachuma Lake)	µg/L	10	0.1	3.0		1.4 - 5.4				By-product of drinking water disinfection
Microbiological Contaminant Samples										
Total Coliform Bacteria ⁴	% Tests Positive	<5% of Monthly Samples	0	0.00%		0				Naturally present in the environment.
Cryptosporidium	No. of oocyst/L	TT	0	0		0				Naturally present in the environment
Lead & Copper Rule (2013)	Units	RAL	PHG	Samples Collected		Above RAL		90th Percentile		
Lead ⁶	µg/L	15	0.2	32		0		ND		Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits, leaching from wood preservatives.
Copper ⁶	µg/L	1300	300	32		0		309		
Secondary Drinking Water Standards (SDWS)	Units	Maximum Contaminant Level (MCL)		Jameson Lake Average	Jameson Lake Range	Ground Water Average	Ground Water Range	Cachuma Lake Average	Cachuma Lake Range	Major Sources of Contamination in Drinking Water
Aesthetic Standards										
Color	Units	15		ND	ND	ND	ND	19	ND - 26	Naturally-occurring organic minerals. Runoff or leaching from natural deposits; seawater influence.
Chloride	mg/L	500		6	6	229	96 - 463	64.7	19.2 - 187	
Iron	µg/L	300		ND	ND	10	ND - 240	68	ND - 130	Leaching from natural deposits; industrial wastes.
Manganese	µg/L	50		ND	ND	5	ND - 60	17	ND - 39	Leaching from natural deposits.
Threshold Odor at 60 Degrees Celcius	Units	3		ND	ND	ND	ND	11	2 - 20	Naturally-occurring organic minerals.
Specific Conductance	µS/cm	1600		793	793	1267	924 - 1660	857	400 - 1052	Substances that form ions in water.
Sulfate	mg/L	500		208	208	196	95 - 270	218	1.5 - 407	Runoff or leaching from natural deposits; industrial wastes.
Total Dissolved Solids	mg/L	1000		530	530	783	550 - 1100	590	210 - 752	Runoff or leaching from natural deposits.
Zinc	mg/L	5		ND	ND	0.038	ND - 0.150	NA	NA	Runoff or leaching from natural deposits; industrial wastes.

2017 ANNUAL DRINKING WATER CONSUMER CONFIDENCE REPORT

Secondary Drinking Water Standards (SDWS)	Units	Maximum Contaminant Level (MCL)	Jameson Lake Average	Jameson Lake Range	Ground Water Average	Ground Water Range	Cachuma Lake Average	Cachuma Lake Range	Major Sources of Contamination in Drinking Water
Additional Constituents Analyzed									
pH	pH units	NS	7.87	7.60 - 8.30	7.0	6.8 - 7.2	7.82	7.32 - 8.14	
Total Hardness ⁷	mg/L	NS	385	368 - 412	456	265 - 582	315	54 - 470	
Total Alkalinity	mg/L	NS	191	156 - 208	200	180 - 230	170	33 - 191	
Calcium	mg/L	NS	104	104	141	65 - 202	77.4	20 - 106	
Magnesium	mg/L	NS	24	24	50	25 - 84	33	1 - 47	
Sodium	mg/L	NS	26	26	99	70 - 150	59	48 - 83	
Potassium	mg/L	NS	2	2	1	1 - 2	3.9	3 - 4.6	

Definitions Used in the Chart

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of drinking water. Contaminants with SDWS do not affect the health at MCL levels.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Regulatory Action Level (RAL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

mg/L: Milligrams per liter, or parts per million. 1 mg/L is equal to about one drop in 17 gallons of water.

ug/L: Micrograms per liter, or parts per billion. 1 ug/L is equal to about one drop in 17,000 gallons of water.

< : Less than.

NA: Not applicable.

NS: No Standard.

ND: Non-detected.

pCi/L: Pico curies per liter, a measure of radiation

umhos/cm: Micromhos per centimeter (an indicator of dissolved minerals in water).

NTU: Nephelometric turbidity unit.

LRAA: Locational Running Annual Average.

Footnotes:

¹The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, is more than one year old.

²Surface water sources include the District's Jameson Lake and Lake Cachuma. The District's Amapola Well, Paden Well No. 2, Ennisbrook Well No. 5, Ennisbrook Well No. 2, and T. Mosby Well No. 2 were used as groundwater supply sources.

³Turbidity is a measure of the cloudiness of the water. Montecito Water District monitors for it continuously because turbidity is a good indicator of water quality. High turbidity can hinder the effectiveness of disinfectants. 100% of the District's samples met the Turbidity Performance standard. The highest single surface water turbidity measurement during the year was 0.29 NTU.

⁴An average number of 52 coliform samples were collected each month at 12 District sampling stations in compliance with the Federal Coliform Rule.

⁵Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in

serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider. MWD's highest Nitrate level in 2017 was 7.2 mg/L.

⁶Lead & Copper Rule

Every three years, 30 residences are tested for lead and copper levels at the tap. The most recent set of 32 samples was collected in 2017. All of the samples were well below the regulatory action level (RAL). Copper was detected in 29 samples. The 90th percentile value was at 309 µg/L. Lead was detected in 1 sample (7.6 µg/L). The 90th percentile value was Non-Detect. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Montecito Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/lead.

⁷Surface water has a hardness range of 21 to 24 grains per gallon; groundwater has a range of 15 to 34 grains per gallon.

A comprehensive source water assessment of the District's drinking water sources was adopted in May 2017. A copy of this report is available on the District's website.

People with Sensitive Immune Systems

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Drinking Water Info

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791 or visit <http://water.epa.gov/drink>.

The District again wishes to extend deep appreciation to the many mutual aid agencies and individuals who came to assist in the restoration of the water delivery system following the 2018 Thomas Fire Debris Flow incident.



THANK YOU

**For Your Assistance, Your Generosity,
Your Patience, Your Teamwork
and Your Support.**



City of Santa Barbara ~ Santa Barbara County ~ City of Ventura ~ City of Santa Maria
City of San Luis Obispo ~ San Luis Obispo County ~ Tierra Construction ~ Z World/GIS
Lash Construction ~ Goleta Water District ~ Carpinteria Sanitary District ~ Allen Larson
Tetra Tech, Inc. ~ Rauch Communications ~ Souza Construction ~ Ferguson Waterworks
Famcon Pipe & Supply ~ Central Machine & Welding ~ Cascade Well & Pump
Dudek ~ FGL Environmental ~ Oilfield Electric ~ General Pump ~ Shoreline Welding
Electric Part Center ~ Big Red Crane Co. ~ D-KAL Engineering ~ American Red Cross
Arcadia Studio ~ California Conservation Corps ~ Montecito Fire Protection District
Santa Barbara County Office of Emergency Management ~ Cal Fire ~ Jordano's
The Garden Club of Santa Barbara ~ Calvin Designs ~ District Residents

And Many More!

Board of Directors

W. Douglas Morgan, President
Floyd Wicks, Vice-President
Sam Frye, Director
Tobe Plough, Director
Richard Shaikewitz, Director

General Manager & Board Secretary

Nick Turner, P.E.


Public participation is encouraged.
For meeting times, agendas, and
additional resources:

Montecito Water District

583 San Ysidro Road
Montecito, CA 93108
phone: 805.969.2271
email: info@montecitowater.com
web: www.montecitowater.com

YOUR 2017 DRINKING WATER CONSUMER CONFIDENCE REPORT
Will be available online by June 30, 2018
at www.montecitowater.com/CCR_2017.htm

To receive a printed version please email info@montecitowater.com, call us at 805-969-2271, or visit the District office at 583 San Ysidro Road, Montecito, CA 93108.



Water Quality Continues to Exceed Standards

Montecito Water District is pleased to provide you with the Annual Drinking Water Consumer Confidence Report.

The 2017 results will be available on-line by June 30, 2018.* We encourage you to view the report and learn more about your drinking water by visiting this page on our web site:
www.montecitowater.com/CCR_2017.htm


Printed copies will be provided upon request.

*We are no longer mailing the reports in an effort to reduce costs and minimize environmental impact.

Attention landlords, businesses, schools and other groups: Please share this information with tenants, students, and other water users at your location who may not be customers receiving communications directly from Montecito Water District.

Para información en español llame 805-969-2271

Este aviso contiene las instrucciones mas recientes para obtener información importante sobre su agua potable. Traducir, o hablar con alguien que lo entienda.



Bill Message (appearing on all invoices delivered in June) :

DELIVERING HIGH QUALITY WATER: IT'S OUR MISSION!
ANNUAL DRINKING WATER CONSUMER CONFIDENCE REPORT
2017 RESULTS AVAILABLE ON LINE BY JUNE 30, 2018
www.montecitowater.com/CCR_2017.htm

Direct Email

From: Montecito Water District <info@montecitowater.com>
Sent: Wednesday, June 13, 2018 7:45 AM
To: District Customers
Subject: IMPORTANT MESSAGE! Your 2017 Consumer Confidence Report is Now Available

[Trouble Viewing this email? View it in your browser.](#)



**2017 Annual Drinking Water Consumer Confidence Report
Now Available Online at www.montecitowater.com/CCR_2017.htm**

Attention landlords, businesses, schools and other groups: Please share this information with tenants, students, and other water users at your location who may not be customers receiving communications directly from Montecito Water District.

Dear Montecito Water District Customer,

Montecito Water District is pleased to provide you with the Annual Drinking Water Consumer Confidence Report. We encourage you to view the report and learn more about your drinking water by visiting: www.montecitowater.com/CCR_2017.htm

We no longer mail the annual report in an effort to reduce costs and environmental impact. If you would like to receive a printed version, please reply to this email (info@montecitowater.com) with your mailing address, call us at 805-969-2271, or visit the District office at 583 San Ysidro Road, Montecito, CA 93108.

Para información en español llame 805-969-2271

Este aviso contiene las instrucciones mas recientes para obtener información importante sobre su agua potable. Traducir, o hablar con alguien que lo entienda.

Please **CONTACT** the District if you have questions:

Montecito Water District
583 San Ysidro Road
Santa Barbara, CA 93108
Phone: 805.969.2271
Fax: 805.969.7261
Email: info@montecitowater.com
www.montecitowater.com

Stay Informed with Regular Email Updates from Montecito Water District

[Click here to subscribe to our enews letter](#)

Connect with us on Social Media

Facebook — facebook.com/montecitowater.com

Twitter — [@montecitowater](https://twitter.com/montecitowater)

Web — montecitowater.com

The mission of Montecito Water District is to provide an adequate and reliable supply of high quality water to the residents of Montecito and Summerland, at the most reasonable cost. In carrying out this mission, the District places particular emphasis on providing outstanding customer service, conducting its operations in an environmentally sensitive manner, and working cooperatively with other agencies.

583 San Ysidro Road, Montecito, CA 93108-2124 • 805-969-2271 • email: info@montecitowater.com

BOARD OF DIRECTORS: W. Douglas Morgan, President | Floyd Wicks, Vice President

Richard Shaikewitz, Director | Samuel Frye, Director | Tobe Plough, Director

General Manager and Board Secretary: Nick Turner

Unsubscribe

This message was sent to lcamp@montecitowater.com from info@montecitowater.com

Montecito Water District
583 San Ysidro Road
Montecito, CA 93108

From: Montecito Association <execdirector=montecitoassociation.org@mail69.suw151.rsgsv.net> on behalf of Montecito Association <execdirector@montecitoassociation.org>
Sent: Wednesday, June 27, 2018 11:25 AM
To: Montecito Association Members
Subject: Montecito Water District - Annual Drinking Water Consumer Confidence Report



Dear Montecito Association Members:

Please find the below message from the Montecito Water District regarding the **2017 Annual Drinking Water Consumer Confidence Report**.

Best regards,
Allison Marcillac
Executive Director
Montecito Association

[Trouble Viewing this email? View it in your browser.](#)



2017 Annual Drinking Water Consumer Confidence Report
Now Available Online at www.montecitowater.com/CCR_2017.htm

Attention landlords, businesses, schools and other groups: Please share this information with tenants, students, and other water users at your location who may not be customers receiving communications directly from Montecito Water District.

Dear Montecito Water District Customer,

Montecito Water District is pleased to provide you with the Annual Drinking Water Consumer Confidence Report. We encourage you to view the report and learn more about your drinking water by visiting: www.montecitowater.com/CCR_2017.htm

We no longer mail the annual report in an effort to reduce costs and environmental impact. If you would like to receive a printed version, please reply to this email (info@montecitowater.com) with your mailing address, call us at 805-969-2271, or visit the District office at 583 San Ysidro Road, Montecito, CA 93108.

Para información en español llame 805-969-2271

Este aviso contiene las instrucciones mas recientes para obtener información importante sobre su agua potable. Traducir, o hablar con alguien que lo entienda.

Please CONTACT the District if you have questions:

Montecito Water District

583 San Ysidro Road

Santa Barbara, CA 93108

Phone: 805.969.2271

Fax: 805.969.7261

Email: info@montecitowater.com

www.montecitowater.com

Stay Informed with Regular Email Updates from Montecito Water District

[Click here to subscribe to our enews letter](#)

Connect with us on Social Media

Facebook — facebook.com/montecitowater.com

Twitter — [@montecitowater](https://twitter.com/montecitowater)

Web — montecitowater.com

The mission of Montecito Water District is to provide an adequate and reliable supply of high quality water to the residents of Montecito and Summerland, at the most reasonable cost. In carrying out this mission, the District places particular emphasis on providing outstanding customer service,



Contact: Laura Camp, Public Information Officer
Telephone: (805) 969-2271
Email: lcamp@montecitowater.com
Website: www.montecitowater.com

FOR IMMEDIATE RELEASE

WATER QUALITY MEETS OR EXCEEDS STANDARDS

(Montecito, California, June 26, 2018)

Montecito Water District's 2017 Annual Drinking Water Consumer Confidence Report (CCR) is now available online at www.montecitowater.com/CCR_2017.htm . This report describes the District's water sources, provides information on water quality and how it is measured, and presents the District's 2017 test results which show that drinking water met, or was better than, state and federal water quality standards. Landlords, businesses, schools and other groups are asked to share this information with tenants, students, and other water users who may not be customers receiving communications directly from Montecito Water District.

Para los clients del Montecito Water District, este aviso contiene las instrucciones mas recientes para obetener información importante sobre agua potable. Para información en español llame 805-969-2271, traducir, o hablar con alguien que puede explicarlo.

Montecito Water District's mission is to provide an adequate and reliable supply of high quality water to the residents of Montecito and Summerland, at the most reasonable cost. In carrying out this mission, the District places particular emphasis on providing outstanding customer service, conducting its operations in an environmentally sensitive manner, and working cooperatively with other agencies. For additional information visit www.montecitowater.com, like Montecito Water District [on Facebook](#), and follow on twitter [@MontecitoWater](#).



###END###



Don't let your summer budget slip down the drain

Read your meter every week

Be on the lookout for a water leak

See moving dials or a surprising number?

Contact us or call a plumber!

Use water wisely... every drop counts.

**2017 Annual Drinking Water Consumer Confidence Report
now available online:
montecitowater.com/CCR_2017.htm
Water Quality Continues to Meet or Exceed Standards**


Version #1 MWD June Journal Ad

Montecito Water District 1/4 page advertisement runs June 21, 2018.



Social Media: Facebook Post

Page Inbox Notifications Publishing Tools Promotions



Montecito Water District
@montecitowater

Home

Posts

Videos


Photos


About


Community


Promote


Manage Promotions

 Like

 Following ▾

 Share

 ...




Montecito Water District

Published by Laura Braswell Camp [?] · June 14 at 1:50 PM · 🌐

2017 Annual Drinking Water Consumer Confidence Report is now available online at www.montecitowater.com/CCR_2017.htm
Test results indicate that water provided by the District met, or was better than, all primary state and federal water quality standards.
For more information call 805.969.2271

Este aviso contiene las instrucciones mas recientes para obtener información importante sobre s... See More


See Translation




2017 ANNUAL DRINKING WATER CONSUMER CONFIDENCE REPORT


This report explains where your water comes from, provides information on water quality and how it is measured, and presents the District's 2017 test results which show that drinking water met, or was better than, state and federal water quality standards.


The graphic shows a map of the Montecito Water District with various water sources and infrastructure labeled: Bay Delta, Calaveras Aqueduct, Santa Rosa Reservoir, Central Branch Pipeline, Lake Cachuma, Santa Rosa River, Jameson Lake, Doulton Tunnel, and Santa Rosa Treatment Plant. A circular inset highlights 'TABLE A IMPORTED WATER AND SUPPLEMENTAL WATER'.


 91 people reached

Boost Post

 Like

 Comment

 Share

 ▾