



2019

CONSUMER CONFIDENCE REPORT

conservation

A NEW WAY OF LIFE

2019 Consumer Confidence Report

Water System Name: CITY OF SOLVANG

Report Date: JUNE 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Ground Water (Solvang Wells & ID#1 Wells) & Surface Water (CCWA)

Name & general location of source(s): Wells 3 & 7A River Wells; Well 4, 21, 22, & HCA South Upland Wells; Santa Ynez River Water Conservation District, Improvement District No. 1 (ID#1) & Central Coast Water Authority (CCWA)

Drinking Water Source Assessment information: Source Assessments for the City's wells were completed September 2002

Time and place of regularly scheduled board meetings for public participation: Second & Fourth Monday of each Month at 1644 Oak Street, Solvang, CA @ 6:30 P.M.

For more information, contact: Mike Mathews Phone: (805) 688-5575

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste
<i>E. coli</i>	0	0	A routine sample and a repeat sample detect total coliform and either sample also detects <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PH G	Typical Source of Contaminant
Lead (ppb)	3/29/17	20	8.7	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppb)	3/29/17	20	620	0	1300	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2017-2019	63	55-72	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2017-2019	599	412-713	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Fluoride (ppm)	2017-2019	0.20	<0.1-0.3	2	1	Erosion of Natural deposits; water additive which promotes strong teeth
Nitrate (ppm) (as N03)	2017-2019	5.56	<0.5-17.0	45	45	Runoff & leaching from fertilizer use; sewage; erosion of natural deposits
Nitrate and Nitrite (as N) (ppm)	2017-2019	1.26	<.1-3.9	10	10	Runoff & leaching from fertilizer use; sewage; erosion of natural deposits
Hexavalent Chromium (ppb)	2017-2019	<.1	<1-1	10	.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Tetrachloroethylene (PCE) (ppb)	2016-2019	.45	0-0.7	5	N/A	Leaching from PVC pipes; discharge from factories, dry cleaners and auto shops (metal degreasers)
Gross Alpha Activity (pCi/L)	2016-2019	8.94	3.75-16	15	N/A	Erosion of natural deposits
Uranium (pCi/L)	2016-2019	7.66	1.3-16.5	20	.5	Erosion of natural deposits
Trihalomethane (TTHM) (ppb)	1/19-10/19	29.1	14-36	80	N/A	Byproduct of drinking water chlorination
Haloacetic Acid (HA A5) (ppb)	1/19-10/19	17.6	7-30	60	N/A	Byproduct of drinking water chlorination
Selenium (ppb)	2017-2019	9.33	<1-23	50	50	Erosion of natural deposits; discharge chemical manufacturers and runoff from livestock lot.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	2017-2019	76.33	51-117	500	N/A	Runoff/leaching from natural deposits; seawater influence
Odor (units)	2017-2019	0.06	<.1-.34	3	N/A	Natural occurring materials
Specific conductance (Umhos/cm)	2017-2019	1353	1120-1590	**2	1	Substance that forms ions when in water; seawater influence
Sulfate (ppm)	2017-2019	279	203-337	*2	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	2017-2019	925	760-1090	1000	N/A	Runoff/leaching from natural deposits

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Boron (ppb)	2017- 2019	250	200-300	---	Some men who drink water containing boron in excess of the action level over many years may experience reproductive effects based on studies in dogs.
Vanadium (ppb)	2017- 2019	6.5	<1.0-10	---	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Solvang is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <https://www.epa.gov/lead>



CENTRAL COAST WATER AUTHORITY
OLONIO PASS WATER TREATMENT PLANT
WATER QUALITY TABLE
 COVERING THE REPORTING PERIOD OF JANUARY-DECEMBER 2019

Please see last page for key to abbreviations.

Parameter	Units	State MCL	PHG (MCLG)	State DLR	Range Average	TREATED CCWA	SOURCE STATE WATER	Major Sources in Drinking Water
-----------	-------	-----------	------------	-----------	---------------	--------------	--------------------	---------------------------------

PRIMARY STANDARDS--Mandatory Health-Related Standards

CLARITY (a)

Combined Filter Effluent Turbidity (a)	NTU	TT=<1 NTU every 4 hours TT=95% of samples <0.3 NTU	Range %	0.03 - 0.1 100%	NA NA	Soil runoff
--	-----	---	------------	--------------------	----------	-------------

INORGANIC CHEMICALS

Aluminum	mg/L	1 (b)	0.6	0.05	Range Average	ND - 0.094 0.056	ND - 0.31 0.127	Erosion of natural deposits; residual from some surface water treatment processes
----------	------	-------	-----	------	------------------	---------------------	--------------------	---

RADIONUCLIDES

Gross Alpha Particle	pCi/L	15	(0)	3	Range Average	ND ND	5.3 5.3	Erosion of natural deposits
----------------------	-------	----	-----	---	------------------	----------	------------	-----------------------------

DISTRIBUTION SYSTEM MONITORING

Total Chlorine Residual	mg/L	MRDL = 4.0	MRDLG = 4.0	NA	Range Average	0.33 - 3.5 2.47	NA NA	Drinking water disinfectant added for treatment
Total Coliform Bacteria (c)	--	5.0% of monthly samples	(0)	--	Range Average Highest	0 0 0%	NA NA NA	Naturally present in the environment
Total Trihalomethanes (d)	ug/L	80	NA	(0.5)	Range Average Highest LRAA	24 - 75 45 47.8	NA NA NA	By-product of drinking water chlorination
Haloacetic Acids (d)	ug/L	60	NA	(1) (e)	Range Average Highest LRAA	7.4 - 25 15 15.5	NA NA NA	By-product of drinking water chlorination

SECONDARY STANDARDS--Aesthetic Standards

Chloride	mg/L	500 (j)	NA	(1)	Range Average	13 - 146 59	11 - 142 56	Runoff/leaching from natural deposits; seawater influence
Color	ACU	15 (j)	NA	(3)	Range Average	ND ND	20 20	Naturally occurring organic materials
Corrosivity (Aggressivity Index) (i)	SU	non-corrosive	NA	(0.1)	Range Average	12 12	12 12	
Manganese, Total	ug/L	50 (j)	NA	(2)	Range Average	ND ND	8.8 8.8	
Odor Threshold	TON	3 (j)	NA	(1)	Range Average	ND ND	2 2	Naturally occurring organic materials
Specific Conductance	uS/cm	1600 (j)	NA	NA	Range Average	138 - 762 403	131 - 691 353	Substances that form ions when in water; seawater influence
Sulfate	mg/L	500 (j)	NA	(0.5)	Range Average	46 46	34 34	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS)	mg/L	1000 (j)	NA	(10)	Range Average	260 260	250 250	Runoff/leaching from natural deposits
Turbidity (Monthly) (a)	NTU	5 (j)	NA	(0.1)	Range Average	ND - 0.12 0.05	0.38 - 55 3.39	Soil runoff

ADDITIONAL PARAMETERS (Unregulated)

2-Methylisoborneol	ng/L	NA	NA	(1)	Range Average	ND - 1 0.2	2 - 8 3.8	An organic compound mainly produced by blue-green algae (cyanobacteria)
Alkalinity (Total) as CaCO3 equivalents	mg/L	NA	NA	(2)	Range Average	30 - 80 56	28 - 86 59	Runoff/leaching from natural deposits; seawater influence
Calcium	mg/L	NA	NA	(1)	Range Average	19 19	18 18	Runoff/leaching from natural deposits; seawater influence
Geosmin	ng/L	NA	NA	(1)	Range Average	ND - 6 2.8	2 - 8 3.8	An organic compound mainly produced by bacterial growth in surface water
Hardness (Total) as CaCO3	mg/L	NA	NA	(3)	Range Average	26 - 144 82	28 - 144 82	Leaching from natural deposits

Heterotrophic Plate Count (f)	CFU/mL	TT	NA	NA	Range	0 - 2	NA	Naturally present in the environment
					Average	0	NA	
Magnesium	mg/L	NA	NA	(0.1)	Range	12	11	Runoff/leaching from natural deposits; seawater influence
					Average	12	11	
pH	SU	NA	NA	(0.1)	Range	7.7 - 8.7	7.5 - 9.3	Runoff/leaching from natural deposits; seawater influence
					Average	8.4	8.4	
Potassium	mg/L	NA	NA	(1)	Range	3.1	3.1	Runoff/leaching from natural deposits; seawater influence
					Average	3.1	3.1	
Sodium	mg/L	NA	NA	(1)	Range	58	50	Runoff/leaching from natural deposits; seawater influence
					Average	58	50	
Total Organic Carbon (TOC) (g)	mg/L	TT	NA	(0.3)	Range	1.5 - 3	2.6 - 5.4	Various natural and man made sources
					Average	1.9	3.2	

ABBREVIATIONS AND NOTES

Footnotes:

- Turbidity (NTU) is a measure of the cloudiness of the water and it is a good indicator of the effectiveness of our filtration system. Monthly turbidity values are listed in the Secondary Standards section.
- Aluminum has a Secondary MCL of 0.2 ppm.
- Total coliform MCLs: Systems that collect ≥ 40 samples/month no more than 5.0% of the monthly samples may be Total Coliform positive. Systems that collect < 40 samples per month no more than 1 positive sample per month may be Total Coliform positive.
Fecal coliform/E. coli MCLs: The occurrence of 2 consecutive Total Coliform positive samples, one of which contains fecal coliform/E. coli, constitutes an acute MCL violation.
- Compliance based on the running quarterly annual average of distribution system samples.
- Monochloroacetic Acid (MCAA) has a DLR of 2.0 ug/L while the other four Haloacetic Acids have DLR's of 1.0 ug/L.
- Pour plate technique
- TOCs are taken at the treatment plant's combined filter effluent.
- State MCL is 45 mg/L as NO₃, which equals 10 mg/L as N.
- Al ³ 12.0 = Non-aggressive water
Al (10.0 - 11.9) = Moderately aggressive water
Al \leq 10.0 = Highly aggressive water
Reference: ANSI/AWWA Standard C400-93 (R98)
- Secondary MCL

Abbreviations

ACU = Apparent Color Units
 CCWA = Central Coast Water Authority
 CFU/ml = Colony Forming Units per milliliter
 DLR = Detection Level for purposes of Reporting
 MCL = Maximum Contaminant Level
 MCLG = Maximum Contaminant Level Goal
 MRDL = Maximum Residual Disinfectant Level
 MRDLG = Maximum Residual Disinfectant Level Goal
 NA = Not Applicable
 ND = Non-detected above detection limit (DLR)
 NTU = Nephelometric Turbidity Units
 pCi/L = PicoCuries per liter
 PHG = Public Health Goal
 ppb = parts per billion, or micrograms per liter ($\mu\text{g/L}$)
 ppm = parts per million, or milligrams per liter (mg/L)
 TON = Threshold Odor Number
 TT = Treatment Technique
 LRAA = Locational Running Annual Average

2019 Annual Water Quality Report - Santa Ynez River Water Conservation District, ID#1

						Drinking Water Source		
Parameter	Units	State MCL	PHG (MCLG)	State DLR	Range Average	State Water	Ground Water	Major Sources in Drinking Water
PRIMARY STANDARDS--Mandatory Health-Related Standards								

CLARITY

Combined Filter Effluent Turbidity ^a	NTU	TT=<1 NTU every 4 hours TT=95% of samples <0.3 NTU			Range	0.03 - 0.1	NA	Soil runoff
					%	100%	NA	

INORGANIC CHEMICALS

Aluminum ^b	ppm	1 (b)	0.6	0.05	Range	ND - 0.094	ND	Residue from water treatment process;
					Average	0.056	ND	Erosion of natural deposits
Arsenic	ppb	10	0.004	2	Range	ND	ND - 3	Erosion of natural deposits; orchard runoff; from
					Average	ND	1.1	glass/electronics production wastes
Chromium (Total Cr)	ppb	50	(100)	10	Range	ND	ND - 18	Erosion of natural deposits; steel,
					Average	ND	6.0	pulp mills, and chrome plating wastes
Fluoride	ppm	2	1	0.1	Range	ND	ND - 0.30	Erosion of natural deposits;
					Average	ND	0.17	water additive for tooth health
Nickel	ppb	100	12	10	Range	ND	ND - 11	Erosion of natural deposits; discharge from
					Average	ND	1.6	metal factories
Nitrate (as Nitrogen)	ppm	10	10	0.4	Range	NA	ND - 2.7	Runoff and leaching from fertilizer use; leaching
					Average	NA	0.9	from septic tanks and sewage; erosion of natural deposits

RADIONUCLIDES

Gross Alpha ^c	pCi/L	15	NA	3	Range	ND	ND - 11	Erosion of natural deposits
					Average	ND	2.5	
Uranium ^d	pCi/L	20	0.5	1	Range	NC	2.5 - 5.6	Erosion of natural deposits
					Average	NC	4.1	
Radium 226 ^e	pCi/L	5	NA	3	Range	NC	ND - 0.093	Erosion of natural deposits
					Average	NC	0.05	

SECONDARY STANDARDS--Aesthetic Standards

Aluminum	ppm	0.2	NA	0.05	Range	ND - 0.094	ND	Residue from water treatment process;
					Average	0.056	ND	Erosion of natural deposits
Chloride	ppm	500	NA	--	Range	13 - 146	30 - 54	Runoff/leaching from natural deposits;
					Average	59	40.4	seawater influence
Color	ACU	15	NA	--	Range	ND	ND - 3	Naturally-occurring organic materials
					Average	ND	0.3	
Corrosivity (Aggressive Index) ^f	none	non-corrosive	NA	--	Range	12	12.1 - 12.4	Balance of hydrogen, carbon, & oxygen in water, affected by temperature & other factors
					Average	12	12.27	
Iron	ppb	300	NA	100	Range	ND	ND - 160	Leaching from natural deposits; industrial wastes
					Average	ND	33	
Manganese	ppb	50	NA	20	Range	ND	ND - 23	Leaching from natural deposits
					Average	ND	2.9	
Odor Threshold	TON	3	NA	1	Range	ND	1 - 3	Naturally-occurring organic materials
					Average	ND	1.2	
Specific Conductance	µmho/cm	1600	NA	--	Range	138 - 762	730 - 1100	Substances that form ions when in water; seawater influence
					Average	403	880	
Sulfate	ppm	500	NA	0.5	Range	46	30 - 270	Runoff/leaching from natural deposits; industrial wastes
					Average	46	161	
Total Dissolved Solids (TDS)	ppm	1000	NA	--	Range	260	460 - 710	Runoff/leaching from natural deposits;
					Average	260	561	
Lab Turbidity (ID#1) Turbidity (State Water)	NTU	5	NA	--	Range	ND - 0.12	ND - 1.4	Soil erosion/runoff
					Average	0.05	0.31	

ADDITIONAL PARAMETERS (Unregulated)

Alkalinity (Total) as CaCO ₃ equivalents	ppm	NA	NA	--	Range	30 - 80	260 - 290	Runoff/leaching from natural deposits; seawater influence
					Average	56	281	
Boron	ppb	NA	NL=1,000	100	Range	NC	110 - 320	Runoff/leaching from natural deposits; wastewater, and fertilizers/pesticides.
					Average	NC	201	
Calcium	ppm	NA	NA	--	Range	19	46 - 100	Runoff/leaching from natural deposits; seawater influence
					Average	19	71.3	
Chromium, Hexavalent ^g	ppb	NA	0.02	1.0	Range	NC	ND - 13	Discharges from industrial manufacturers; erosion of natural deposits
					Average	NC	6.2	
Geosmin	ng/L	NA	NA	(1)	Range	ND - 6	NC	An organic compound mainly produced by blue-green algae (cyanobacteria)
					Average	2.8	NC	
Hardness (Total) as CaCO ₃	ppm	NA	NA	--	Range	26 - 144	300 - 490	Leaching from natural deposits
					Average	82	397	

2019 Annual Water Quality Report - Santa Ynez River Water Conservation District, ID#1

Drinking Water Source								
Parameter	Units	State MCL	PHG (MCLG)	State DLR	Range Average	State Water	Ground Water	Major Sources in Drinking Water
Heterotrophic Plate Count ^h	CFU/mL	TT	NA	--	Range	0 - 2	NA	Naturally present in the environment
					Average	0	NA	
Magnesium	ppm	NA	NA	--	Range	12	49 - 58	Runoff/leaching from natural deposits; seawater influence
					Average	12	53	
2-Methylisoborneol (MIB)	ng/L	NA	NA	NA	Range	ND - 1	NC	An organic compound mainly produced by blue-green algae (cyanobacteria)
					Average	0.2	NC	
pH	pH Units	NA	NA	--	Range	7.7 - 8.7	7.47 - 7.88	Runoff/leaching from natural deposits; seawater influence
					Average	8.4	7.6	
Potassium	ppm	NA	NA	--	Range	3.1	2.0 - 2.3	Runoff/leaching from natural deposits; seawater influence
					Average	3.1	2.2	
Sodium	ppm	NA	NA	--	Range	58	38 - 52	Runoff/leaching from natural deposits; seawater influence
					Average	58	45	
Total Organic Carbon (TOC) ⁱ	ppm	TT	NA	0.30	Range	1.5 - 3	NA	Various natural and manmade sources.
					Average	1.9	NA	
Vanadium	ppb	NA	NL=50	3	Range	NC	3.3 - 25	Leaching from natural deposits; industrial wastes
					Average	NC	11	

Distribution System Water Quality

ORGANIC CHEMICALS

Total Trihalomethanes ^j	ppb	80	NA	NA	Range	24 - 75	8.8 - 37.7	By-product of drinking water chlorination
					Highest LRAA	47.8	28.2	
Haloacetic Acids	ppb	60	NA	1,2 ^k	Range	7.4 - 25	ND - 16.9	By-product of drinking water chlorination
					Highest LRAA	15.5	8.9	

DISINFECTION

Total chlorine residual	ppm	MRDL =	MRDLG =	--	Range	0.33 - 3.5	--	Measurement of the disinfectant used in the production of drinking water
CCWA Distribution		4.0	4.0		Average	2.47	--	
Free/total chlorine residual	ppm	MRDL =	MRDLG =	--	Range	--	0.29 - 2.85	Measurement of the disinfectant used in the production of drinking water
ID#1 Distribution		4.0	4.0		Average	--	1.4	

Abbreviations and Notes

Footnotes:

- Turbidity (NTU) is a good indicator of the effectiveness of a filtration system. Monthly turbidity values for State Water are listed in the Secondary Standards section.
- Aluminum has a Secondary MCL of 0.2 ppm.
- Gross alpha particle activity monitoring required every nine years for State Water; more frequent monitoring is required for some groundwater based on detected levels. Reported average and range are from most recent sampling of all supply wells.
- Uranium monitoring is dependent on measured gross alpha particle activity.
- The MCL for radium is based on a combined total of radium 226 and radium 228.
- AI \geq 12.0 = Non-aggressive water
AI (10.0 - 11.9) = Moderately aggressive water
AI \leq 10.0 = Highly aggressive water
Reference: ANSI/AWWA Standard C400-93 (R98)
- There is currently no MCL for Hexavalent Chromim. The previous MCL of 10.0 ppb was withdrawn on September 11, 2017.
- Pour plate technique -- monthly averages.
- TOCs are taken at the State Water treatment plant's combined filter effluent.
- Compliance based on the LRAA of distribution system samples. Values reported are the range of all 2019 sample results and highest locational running annual average.
- Monochloroacetic Acid (MCAA) has a DLR of 2.0 ug/L while the other four Haloacetic Acids have DLR's of 1.0 ud/L.

Abbreviations

ACU = Apparent Color Units
 CCWA = Central Coast Water Authority
 CFU/ml = Colony Forming Units per milliliter
 DLR = Detection Limit for the Purpose of Reporting
 ID#1 = Santa Ynez River Water Conservation District, Improvement District No.1
 LRAA - Locational Running Annual Average
 NA = Not Applicable
 NC = Not Collected
 ND = Non-detect
 ng/L = nanograms per liter
 NL = Notification Level
 NTU = Nephelometric Turbidity Units
 pCi/L = PicoCuries per liter
 ppb = parts per billion, or micrograms per liter (ug/L)
 ppm = parts per million, or milligrams per liter (mg/L)
 SI = saturation index
 TON = Threshold Odor Number
 umho/cm = micromhos per centimeter

Analytical Results

The following summary table of analytical results confirms that water served by the District met or exceeded all water quality standards during the 2019 reporting period. The table lists the range and average concentrations of the drinking water contaminants (as well as other water quality constituents) that were detected during the most recently required sampling for each source and constituent listed. Also listed are results of the District's required distribution system sampling. It is worth noting that chemicals not detected are not included in the report. Additionally, DDW sampling requirements allow for source monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year. Therefore, some of the data listed in the tables, though representative of the source water quality, are more than a year old.

City of Solvang Conservation Efforts

The City of Solvang has downgraded to Stage 1 Drought Regulations.

For a full list of the regulations, please see: www.cityofsolvang.com

Conservation Programs

□ Landscape Rebate

For more information on these programs, please contact the City of Solvang at 805-688-5575

Water Wise Facts

□ 1 Unit of water on your water bill = One Hundred Cubic Feet (1 HCF)

□ 1 Unit = 1 HCF = 100 Cubic Feet = 748 gallons

□ The State of California Department of Water Resources has determined the minimum quantity of water for health & safety purposes is 50/gallons per person per day.

□ For a family of four, 50/gallons per person per day = 8.3 Units/month.

Additional Resources

Waterwise Santa Barbara, www.waterwisesb.org

ABBREVIATIONS AND NOTES

Footnotes:

- (a) Turbidity (NTU) is a measure of the cloudiness of the water and is a good indicator of the effectiveness of a filtration system. Monthly turbidity values for State Water are listed in the Secondary Standards section.
- (b) Aluminum has a Secondary MCL of 200 ppb.
- (c) Gross alpha particle activity monitoring required every nine years for State Water; more frequent monitoring is required for some groundwater based on detected levels. Reported average represents highest running source average.
- (d) Uranium monitoring is dependent on measured gross alpha particle activity.
- (e) Pour plate technique -- monthly averages.
- (f) TOCs are taken at the State Water treatment plant's combined filter effluent.
- (g) Total coliform MCLs: No more than 5.0% (State Water) or 1 sample (ID#1) of the monthly samples may be Total Coliform positive. All required follow-up and confirmation samples collected in response to each of the positive Total Coliform samples were absent for Total Coliform.
- (h) Compliance based on the running quarterly annual average of distribution system samples. Values reported are range of all sample results and highest running annual average.
- (j) Monochloroacetic Acid (MCAA) has a DLR of 2.0 ug/L while the other four Haloacetic Acids have DLR's of 1.0 ug/L.

CCWA = Central Coast Water Authority

CFU/ml = Colony Forming Units per milliliter

ID#1 = Santa Ynez River Water Conservation District, Improvement District No.1

NA = Not Applicable

NC = Not Collected

NL = Notification Level

NTU = Nephelometric Turbidity Units

pCi/L = PicoCuries per liter

ppb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

SI = saturation index

µmho/cm = micromhos per centimeter, (unit of specific conductance of water)

Abbreviations

ACU = Apparent Color Units

