PRIMARY STANDARDS-Mandatory Health-Related Standards

					TREATED	SOURCE		
Parameter	Units	State	PHG	Range	CCWA	STATE	GROUND	Major Sources of Drinking Water
Clarity		MCL	(MCLG)	Average	PPWTP	WATER	WATER	
Combined Filter Effluent	NTU	TT=< NTU EVERY 4HOURS			0.04-0.12	NA	0.09-0.43	Soil runoff
Turbidity		TT=95% OF SAMPLES <0.3 NTU			100%	NA	0.22	
MICROBIOLOGICAL								
Total Coliform Bacteria (Distr. System-Wide)	–	5.00%	0	Range	0%	NA	0 positives	Naturally present in the environment
				Average	0.00%	NA	0 positives	
Fecal Coliform E. coli (Distr. System-Wide)	–	–	0	Range	0 positives	NA	0 positives	Human and animal fecal waste
				Average	0 positives	NA	0 positives	
INORGANIC CHEMICALS								
Aluminum	ppm	1	0.6	Range	ND-.056	ND-.082	ND	Residue from water treatment process; Erosion of natural deposits
				Average	ND	ND	ND	
Arsenic (Total)	ppb	10	0.004	Range	ND	2.3	ND-2.8	Erosion of natural deposits; glass & electronics production wastes
				Average	ND	2.3	1.8	
Nitrate (as N)	ppm	10	10	Range	0.53	0.47	ND-.51	Runoff & leaching from fertilizer use; sewage; erosion of natural deposits
				Average	0.53	0.47	0.13	
Fluoride	ppm	2	1	Range	ND	ND	.26-.35	Runoff & leaching from fertilizer use; sewage; erosion of natural deposits
				Average	ND	ND	0.31	
RADIONUCLIDES (f)								
Gross Alpha	pCi/L	15	0	Range	ND	ND	7.82-10.1	Erosion of Natural deposits
				Average	ND	ND	8.8	
Uranium	pCi/L	20	0.43	Range	NA	ND	5.7-7.2	Erosion of Natural deposits
				Average	NA	ND	6.4	
DISTRIBUTION SYSTEM MONITORING								
TOTAL CHLORINE RESIDUAL	ppm	MRDL=4	MRDLG=4	Range	.05-3.64	NA	0.19-2.20	Measurement of the disinfectant used in the prodution of drinking water
				Average	2.90	NA	1.42	
Total Trihalomethanes	ppb	80	n/a	Range	32-71	NA	3.6-4.8	By-product of drinking water Chlorination
				Average	49	NA	4.2	
Haloacetic acids	ppb	60	NA	Range	9.5 - 24	NA	ND-1.5	By-product of drinking water Chlorination
				Average	14	NA	0.75	
SECONDARY STANDARDS-Aesthetic Standards								
Chloride	ppm	500	NA	Range	26-155	21-150	37-56	Runoff/leaching from natural deposits; seawater influence
				Average	68	64	45	
Color (ACU)	ACU	15	NA	Range	ND	10	ND	Naturally occurring organic materials
				Average	ND	10	ND	
Iron	ppb	300	NA	Range	ND	0.034	ND	Leaching trom natural deposits; Industrial wastes
				Average	ND	0.034	ND	
Manganese	ppb	50	NA	Range	ND	13	ND	Leaching from natural deposlts
				Average	ND	13	ND	
Odor Threshold	TON	3	NA	Range	ND	2	ND	Naturally occurring organic materials
				Average	ND	2	ND	
Specific Conductance	Us/CM	1600	NA	Range	243-684	205-740	1100	Substances that form ions when in seawater influence water;
				Average	470	425	1100	
Sulfate	ppm	500	NA	Range	29	18	220-310	Runoff/leaching from natural deposits; industrial wastes
				Average	29	18	270	
Total Dissolved Solids	ppm	1000	NA	Range	260	260	860-940	Runoff/leaching from natural deposits; seawater influence
				Average	260	260	903	
Turbidity (Monthly)	NTU	5	NA	Range	ND - ND	.21- 13.5	0.09-0.43	Soil runoff
				Average	0.05	1.99	0.25	
UNREGULATED SUBSTANCES - Additional Parameters								
Alkalinity (Total)	ppm	NA	NA	Range	52 - 104	54-116	270-300	Runoff/leaching from natural deposits; seawater influence
				Average	68	72	288	
Calcium	ppm	NA	NA	Range	16	16	110-120	Runoff/leaching from natural deposits; seawater influence
				Average	16	16	113	
Hardness (Total Hardness)	ppm	NA	NA	Range	42-146	54-148	500-540	Leaching from natural deposits
				Average	90	90	518	
Heterotrophic Plate Count	CFU/ml	TT	NA	Range	0 - 1	NA	ND	Naturally present in the environment
				Average	0	NA	ND	
Magnesium	ppm	NA	NA	Range	12	12	52-63	Runoff/leaching from natural deposits; seawater influence
				Average	12	12	59	
pH	pH	NA	NA	Range	7.7- 8.8	7.8- 9.4	7.8-8.0	Runoff/leaching from natural deposits; seawater influence
				Average	8.4	8.6	7.9	
Potassium	ppm	NA	NA	Range	2.7	2.7	2.8-3.4	Runoff/leaching from natural deposits; seawater influence
				Average	2.7	2.7	3.1	
Sodium	ppm	NA	NA	Range	60	53	62-65	Runoff/leaching from natural deposits; seawater influence
				Average	60	53	64	
Total Organic Carbon (TOC)	ppm	TT	NA	Range	1.5- 3	2.2- 4.1	.79-1.6	Various naturals and manmade sources
				Average	2.1	3.1	1.35	

LEAD AND COPPER RULE

Data for Lead and Copper is from August/September 2023 - Triennial Sampling. Next sampling is in 2026.	No. of Samples Collected	90th %tile Detected	No. Sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (PPB)	20	0	1	0.015	0.1	Internal corrosion of household water plumbing systems; discharges from industrial manufaturers, erosion of natural deposits
Copper (PPM)	20	1.1	1	1.3	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching wood preservatives

MONITORING VIOLATIONS

None.

What happened / What is Being Done:

For Lead and Cooper: Both households were notified of their results of exceedence for Lead or Copper and an informational letter regarding health effects, potential sources and how to reduce exposure in drinking water. In compliance with 40 Code of Federal Regulations Section 141.85(d), these notices were delivered by hand on August 14, 2023.

Data represented on these tables covers the reporting period of January - December 2025. Consumer Confidence Report is printed on June 2026.