

2020 Consumer Confidence Report

(NOTE: Consumer should keep this report until June 2022)

Water System Name: Roseview Heights Mutual Water Company Report Date: 02/22/21

We test the drinking water quality for constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020. We purchase our water from San Jose Water Company and store it in reservoirs for use in the community. We add chlorine to the water to maintain quality during storage. Point of delivery water quality testing is performed by Roseview Heights MWC and is listed below.

Source water quality testing by San Jose Water Company is reported in the attached pamphlet.

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: See San Jose Water Company report attached.

Name & location of source(s): San Jose Water Company

Drinking Water Source Assessment information: See San Jose Water Company report.

Time and place of regularly scheduled board meetings for public participation: Announced in bill

For more information, contact Tim Schacher Phone: (408) 259-4760

TERMS USED IN THIS REPORT: (SEE SAN JOSE WATER COMPANY REPORT)

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (to be completed only if there was a detection of bacteria)	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) <u>0</u>	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) <u>0</u>	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set)	No. of samples collected	90 th percentile level detected	No. Sites exceeding AL	AL	MCLG	Typical Source of Contaminant
Lead (ppb) 10/2018	5	ND	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppm) 10/2018	5	0.21	0	1.3	0.17	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives.

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS (SEE SAN JOSE WATER COMPANY REPORT)

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD
(SEE SAN JOSE WATER COMPANY REPORT AND TWO ITEMS BELOW)

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Asbestos	01/14	ND	N/A	7	7	Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.
TTHMs (ppb) [Total Trihalomethanes]	06/20	22	N/A	80	N/A (N/A)	Byproduct of drinking water chlorination
Halocetic Acids (ppb)	06/20	18	N/A	60	N/A (N/A)	Byproduct of drinking water chlorination

TABLE 5 - DETECTION OF CONTAMINANTS WITH A <u>SECONDARY</u> DRINKING WATER STANDARD (SEE SAN JOSE WATER COMPANY REPORT)

Summary Information for Contaminants Exceeding an MCL or AL, or a Violation of any Treatment or Monitoring and Reporting Requirements

None
