

2018 Consumer Confidence Report

Muriel Wright Residential Center

June 12, 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse MCSI Water Systems Management a (831) 659-5360 para asistirlo en español.

Type of water source(s) in use: The water system receives its water from Great Oaks Water Company.

Name & general location of source(s): All of Muriel Wright Residential Center's water is pumped from Great Oaks Water Company's 20 groundwater wells. The information provided in this report was taken from the Great Oaks Water Company's Consumer Confidence Report. Additional information may be found on the website: www.greatoakswater.com.

Drinking Water Source Assessment information: Great Oaks Water conducted Drinking Water Source Assessments for all Wells to determine potential sources of contamination. A copy is available for viewing at Great Oaks Water Company, 20 Great Oaks Blvd., STE 120, San Jose, CA or call (408) 227-9540.

Time and place of regularly scheduled board meetings for public participation: None

For more information, contact: MCSI Water Systems Management Phone: (831) 659-5360

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	9/2015	5	0.115	0	15	0.2	Not applicable	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/2015	5	ND	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2017	28	23-42	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2017	280	230-390	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4A – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD-SOURCE

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
1,1,1, Trichloroethane (ppb)	2017	0.003	ND-1.4	200	1000	Discharge from metal degreasing sites and other factories
Freon 113 (ppb)	2017	0.001	ND-12	1200	10	Discharge from metal degreasing sites and other factories; dry-cleaning solvent
Arsenic (ppb)	2017	0.004	ND-1.7	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Asbestos (MFL)	2017	0.4	ND-0.4	7	7	Internal corrosion of asbestos cement water mains; erosion of natural deposits
Barium (ppm)	2017	0.10	0.09-0.18	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium Total (ppb)	2017	3.77	1.9-9.3	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits.
Fluoride (ppm)	2017	0.17	0.15-0.23	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (ppm) (as N) - Raw	2017	1.46	0.97-5.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate +Nitrite (as N) (ppm)	2017	0.391	ND-1.7	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)

DETECTION OF RADIOACTIVE CONTAMINANTS

Gross Alpha Activity (pCi/L)	2017	3.5	3-4.6	15	(0)	Erosion of natural deposits
------------------------------	------	-----	-------	----	-----	-----------------------------

TABLE 4B – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD-DISTRIBUTION

Total Trihalomethanes (ppb)	9/2017	74	--	80	N/A	Byproduct of drinking water disinfection
Total Haloacetic Acids (ppb)	9/2017	16	--	60	N/A	Byproduct of drinking water disinfection
Chlorine (ppm) ¹	2018	1.43	0.52-2.2	[MRDL=4 (as Cl ₂)]	[MRDL=4 (as Cl ₂)]	Drinking water disinfectant added for treatment

¹ Chlorine residuals are taken in the field and reported on the coliform report.**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Aluminum (ppm)	2017	0.022	ND-0.1	0.2	N/A	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Chloride (ppm)	2017	50	37-68	500	N/A	Runoff/leaching from natural deposits; seawater influence
Copper (ppm)	2017	0.0004	ND-0.0048	1	0.3	Erosion of natural deposits; leaching of wood preservatives
Iron (ppb)	2017	60	ND-260	300	N/A	Leaching from natural deposits; industrial wastes
Manganese (ppm)	2017	0.007	ND-0.007	0.05	N/A	Leaching from natural deposits
Odor (Units)	2017	0.03	ND-1	3	N/A	Naturally-occurring organic materials

Specific Conductance (µS/cm)	2017	657	560-880	1600	N/A	Substances that form ions when in water; seawater influence
Sulfate (ppm)	2017	41	36-64	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	2017	394	360-540	1000	N/A	Runoff/leaching from natural deposits
Turbidity (NTU)	2017	0.24	ND-3.0	5	N/A	Soil runoff

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average	Range of Detections	Notificati on Level	Health Effects Language
Chlorate (ppb)	--	9.57	ND-58.5	800	Animal studies demonstrated that chlorate exposure in rats caused adverse effects to the pituitary and thyroid glands.
Chlorodifluoromehtane (ppb)	--	0.181	ND-0.98	--	
Chromium-6 (ppb)	--	3.322	1.8-6.55	--	
Strontium (ppb)	--	535.5	385-775	--	
Vanadium (ppb)	--	1.756	1.2-2.75	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Muriel Wright Residential Center is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. **[OPTIONAL:** If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Nitrate above 5 ppm (50% of the MCL), but below 10 ppm (the MCL) (as nitrogen): Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

- Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

- None

**Summary Information for Federal Revised Total Coliform Rule
Level 1 and Level 2 Assessment Requirements**

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

- The water system was not required to complete neither a Level 1 nor Level 2 in 2018.

System Update

- The facility had extensive renovations that had the system out of service and under construction for over 12 months. The main building plans to reopen in July 2019.