

## 2023 Consumer Confidence Report

### Water System Information

Water System Name: **Vista Robles Association**

Report Date: June 8, 2024

Type of Water Source(s) in Use: Groundwater (wells)

Name and General Location of Source(s): Wells 1 and 2 located on Quail Hollow Rd, adjacent to subdivision

Drinking Water Source Assessment Information: On file at Santa Cruz County Environmental Health Services

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Board meets on a "as needed basis". Call 831-336-8204 for information

For More Information, Contact: Mary Hoff at 831-336-8204

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2023 and may include earlier monitoring data. This report contains only the contaminants that were detected. Many of the constituents that are tested for are not detected, and consequently are not listed here.

### Importance of This Report in the Spanish Language

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse a Vista Robles Association, 1330 Quail Hollow Rd, Ben Lomond Ca. 831-336-8204 para asistirlo en español.

### Terms Used in This Report

| Term                            | Definition                                                                                                                                                                                                                                                                  |
|---------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Level 1 Assessment              | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.                                                                                             |
| Level 2 Assessment              | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level (MCL) | The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.            |

| Term                                             | Definition                                                                                                                                                                                             |
|--------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Maximum Contaminant Level Goal (MCLG)            | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).                           |
| Maximum Residual Disinfectant Level (MRDL)       | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.                        |
| Maximum Residual Disinfectant Level Goal (MRDLG) | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| Primary Drinking Water Standards (PDWS)          | MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.                                                           |
| Public Health Goal (PHG)                         | The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.                                 |
| Regulatory Action Level (AL)                     | The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.                                                                       |
| Secondary Drinking Water Standards (SDWS)        | MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.                                                |
| Treatment Technique (TT)                         | A required process intended to reduce the level of a contaminant in drinking water.                                                                                                                    |
| Variances and Exemptions                         | Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.                                             |
| ND                                               | Not detectable at testing limit.                                                                                                                                                                       |
| ppm                                              | parts per million or milligrams per liter (mg/L)                                                                                                                                                       |
| ppb                                              | parts per billion or micrograms per liter (µg/L)                                                                                                                                                       |
| ppt                                              | parts per trillion or nanograms per liter (ng/L)                                                                                                                                                       |
| ppq                                              | parts per quadrillion or picogram per liter (pg/L)                                                                                                                                                     |
| pCi/L                                            | picocuries per liter (a measure of radiation)                                                                                                                                                          |

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

| Microbiological Contaminants | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria   |
|------------------------------|---------------------------|----------------------------|-----|------|------------------------------|
| <i>E. coli</i>               | 2023<br>0                 | 0                          | (a) | 0    | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

| Lead and Copper | Sample Date | No. of Samples Collected | 90 <sup>th</sup> Percentile Level Detected | No. Sites Exceeding AL | AL   | PHG | Typical Source of Contaminant                                                                                                 |
|-----------------|-------------|--------------------------|--------------------------------------------|------------------------|------|-----|-------------------------------------------------------------------------------------------------------------------------------|
| Lead (ppb)      | 7/20/2017   | 5                        | N.D.                                       | 0                      | 15   | 0.2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppb)    | 7/20/2017   | 5                        | 500                                        | 0                      | 1300 | 0.3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives               |

**Table 3. Sampling Results for Sodium and Hardness**

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL  | PHG (MCLG) | Typical Source of Contaminant                                                                                        |
|-----------------------------------------------|-------------|----------------|---------------------|------|------------|----------------------------------------------------------------------------------------------------------------------|
| Sodium (ppm)                                  | 2023        | 7.8            | N/A                 | None | None       | Salt present in the water and is generally naturally occurring                                                       |
| Hardness (ppm)                                | 2023        | 31             | N/A                 | None | None       | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

| <b>Chemical or Constituent (and reporting units)</b> | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL [MRDL]</b> | <b>PHG (MCLG) [MRDLG]</b> | <b>Typical Source of Contaminant</b>                                                                                     |
|------------------------------------------------------|--------------------|-----------------------|----------------------------|-------------------|---------------------------|--------------------------------------------------------------------------------------------------------------------------|
| Chromium (ppb)                                       | 2023               | 1.0                   | N/A                        | 50                | 100                       | Discharge from steel and pulp mills and chrome plating; erosion of natural deposits                                      |
| Fluoride (ppb)                                       | 2023               | 120                   | N/A                        | 2000              | 1000                      | Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories |
| Gross Alpha (p/CiL)                                  | 2020               | 0.78                  | N/A                        | 15                | 0                         | Erosion of natural deposits                                                                                              |
| Nitrate as N (ppm)                                   | 2023               | 1.2                   | N/A                        | 10                | 10                        | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits              |

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

| <b>Chemical or Constituent (and reporting units)</b> | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>SMCL</b> | <b>PHG (MCLG)</b> | <b>Typical Source of Contaminant</b>                      |
|------------------------------------------------------|--------------------|-----------------------|----------------------------|-------------|-------------------|-----------------------------------------------------------|
| Chloride (ppm)                                       | 2023               | 6.5                   | N/A                        | 500         | N/A               | Runoff/leaching from natural deposits; seawater influence |
| Iron (ppb) *                                         | 2023               | 330                   | N/A                        | 300         | N/A               | Leaching from natural deposits; industrial wastes         |
| Sulfate (ppm)                                        | 2023               | 4.1                   | N/A                        | 500         | N/A               | Runoff/leaching from natural deposits; industrial wastes  |
| Total Dissolved Solids                               | 2020               | 82                    | N/A                        | 1000        | N/A               | Runoff/leaching from natural deposits.                    |

**Table 6. Detection of Unregulated Contaminants**

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | Notification Level | Health Effects |
|-----------------------------------------------|-------------|----------------|---------------------|--------------------|----------------|
| PH                                            | 2023        | 7.1            | N/A                 | N/A                | N/A            |

**Additional Testing in 2023**

Vista Robles Association conducted additional testing from Wells 1 and 2 in 2023 for 8 Synthetic Organic chemicals (SOCs) and 31 Volatile organic Chemicals (VOCs) in 2022, all of which were undetected.

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Vista Robles Association is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

**Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

| <b>Table 7.<br/>Violation of a<br/>MCL, MRDL, AL,<br/>TT or Monitoring<br/>Reporting<br/>Requirement<br/>Violation</b> | <b>Explanation</b>                                                                                                | <b>Duration</b> | <b>Actions Taken to<br/>Correct Violation</b> | <b>Health Effects<br/>Language</b>                                                                                                                                                                                                                                                                                                  |
|------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------|-----------------|-----------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| * Iron, secondary<br>MCL                                                                                               | Vista Robles wells 1 and 2 have varying concentrations of Iron which sometimes exceeds the MCL by a minor amount. | Intermittent    | None                                          | <i>Iron was found at levels that exceed the secondary MCL of 300 µg/L. The iron MCL was set to protect you against unpleasant aesthetic effects (e.g., color, taste, and odor) and the staining of plumbing fixtures (e.g., tubs and sinks) and clothing while washing. The iron levels are due to leaching of natural deposits</i> |