

2024 Consumer Confidence Report

Water System Information

Water System Name: Buena Vista Migrant Center – CA4400763

Report Date: 6/19/2025

Type of Water Source(s) in Use: Ground Water Well

Name and General Location of Source(s): Well 1 – Middle of Property

Drinking Water Source Assessment Information: N/A

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Email to request a meeting

For More Information, Contact: Kim Ryan kryan@stanregionalha.org (209) 557-2006

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2024 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Buena Vista Migrant Center a 113 Tierra Alta Drive Watsonville, CA 95076 or (209) 557-2006 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Buena Vista Migrant Center 以获得中文的帮助: 113 Tierra Alta Drive Watsonville, CA 95076 (209) 557-2006.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Buena Vista Migrant Center and 113 Tierra Alta Drive Watsonville, CA 95076 o tumawag sa (209) 557-2006 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Buena Vista Migrant Center tại 113 Tierra Alta Drive Watsonville, CA 95076 or (209) 557-2006 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Buena Vista Migrant Center ntawm 113 Tierra Alta Drive Watsonville, CA 95076 or (209) 557-2006 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	Range of Results	AL	PHG	Violation	Typical Source of Contaminant
Lead (ppb)	2022	5	ND	0	ND	15	0.2	No	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	2022	5	0.076	0	0.033-0.089	1.3	0.3	No	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2020	42	NA	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2020	270	NA	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Inorganic Contaminants						
Arsenic (ppb)	8/19/24	1.3	NA	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	8/19/24	0.023	NA	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (hexavalent) (ppb)	10/8/24	16	NA	10	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities.
Chromium [Total] (ppb)	8/19/24	5.2	NA	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	8/19/24	0.1	NA	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate as N (ppm)	8/19/24	1.4	NA	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Selenium (ppb)	8/19/24	1.6	NA	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Radioactive Contaminants						
Gross Alpha Particle Activity (pCi/L)	2019	2.09	NA	15	(0)	Erosion of natural deposits
Disinfection Byproducts						
TTHMs [Total Trihalomethanes] (ppb)	9/3/24	4	NA	80	NA	Byproduct of drinking water disinfection
Chlorine (ppm)	2024	0.67	0.06-1.95	[4.0]	[4]	Drinking water disinfectant added for treatment

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	2019	41.3	NA	500	None	Runoff/leaching from natural deposits; seawater influence
Odor (TON)	2019	1	NA	3	None	Naturally-occurring organic materials
Specific Conductance (µS/cm)	2019	654	NA	1,600	None	Substances that form ions when in water; seawater influence
Sulfate (ppm)	2019	39	NA	500	None	Runoff/leaching from natural deposits
Total Dissolved Solids [TDS] (ppm)	2019	330	NA	1,000	None	Runoff/leaching from natural deposits; industrial wastes
Turbidity (NTU)	2019	0.1	NA	5	None	Soil Runoff

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Perfluorobutane sulfonic Acid (PFBS) (ppt)	2024	13.25	10-16	500	PFBS exposures resulted in decreased thyroid hormone in pregnant female mice.
Perfluorooctane Sulfonic Acid (PFOS) (ppt)	2024	8.05	7.7-8.5	6.5	PFOS exposures resulted in immune suppression and cancer in laboratory animals.
Perfluorooctanoic Acid (PFOA) (ppt)	2024	9.4	8.2-11	5.1	PFOA exposures resulted in increased liver weight and cancer in laboratory animals.
Perfluorohexane Sulfonic Acid (PFHXS) (ppt)	2024	2.7	2.1-3.1	3	PFHXS exposures resulted in decreased total thyroid hormone in male rats.
Perfluorobutanoic Acid (PFBA) (ppt)	2024	2.55	2.2-2.8	NA	NA
Perfluoroheptanoic Acid (PFHPA) (ppt)	2024	2.1	ND-2.3	NA	NA
Perfluorohexanoic Acid (PFHXA) (ppt)	2024	2.5	2.0-3.0	NA	NA
Perfluorononanoic Acid (PFNA) (ppt)	2024	2.7	2.5-2.9	NA	NA
Perfluoropentanoic Acid (PFPEA) (ppt)	2024	2.25	2.0-2.5	NA	NA

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Buena Vista Migrant Center is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Buena Vista Migrant Center and (209) 557-2006. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Buena Vista Migrant Center has completed a lead service line inventory and is pleased to report that the service lines feeding the system are all classified as non-lead. A copy of this inventory is posted within the office. If you have any questions about this inventory or would like to obtain a copy, please contact us at (209) 557-2006.

Chromium (hexavalent) was detected at levels that exceed the chromium (hexavalent) MCL. While a water system of our size is not considered in violation of the chromium (hexavalent) MCL until after October 1, 2028, we are working to address this exceedance and comply with the MCL. Specifically, we are planning to increase sampling frequency and investigating potential treatment upgrades.

Some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer.