

2024 Consumer Confidence Report

Water System Information

Water System Name: River Breeze Mobile Home Park

Report Date: May 10, 2025

Type of Water Source(s) in Use: Groundwater

Name and General Location of Source(s): Well 01 River Breeze MHP 6950 Riverland Dr, Redding, CA, North East corner of property

Drinking Water Source Assessment Information: Tehama County Environmental Health Water System No. 4500092

Time and Place of Regularly Scheduled Board Meetings for Public Participation: None

For More Information, Contact: Scott Martin 1-530-737-8786

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2024 and may include earlier monitoring data.

Terms Used in This Report

| Term | Definition |
|--|---|
| Level 1 Assessment | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. |
| Level 2 Assessment | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level (MCL) | The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water. |
| Maximum Contaminant Level Goal (MCLG) | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA). |
| Maximum Residual Disinfectant Level (MRDL) | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |

| Term | Definition |
|--|--|
| Maximum Residual Disinfectant Level Goal (MRDLG) | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| Primary Drinking Water Standards (PDWS) | MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements. |
| Public Health Goal (PHG) | The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency. |
| Regulatory Action Level (AL) | The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow. |
| Secondary Drinking Water Standards (SDWS) | MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels. |
| Treatment Technique (TT) | A required process intended to reduce the level of a contaminant in drinking water. |
| Variances and Exemptions | Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions. |
| ND | Not detectable at testing limit. |
| ppm | parts per million or milligrams per liter (mg/L) |
| ppb | parts per billion or micrograms per liter (µg/L) |
| ppt | parts per trillion or nanograms per liter (ng/L) |
| ppq | parts per quadrillion or picogram per liter (pg/L) |
| pCi/L | picocuries per liter (a measure of radiation) |

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

| Microbiological Contaminants | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria |
|------------------------------|---------------------------|----------------------------|-------------------------------|------|------------------------------|
| <i>E. coli</i> | 0 | | (a) 1 positive monthly sample | 0 | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 1.A. Compliance with Total Coliform MCL between January 1, 2024 and January 31, 2024 (inclusive)

| Microbiological Contaminants | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria |
|-----------------------------------|---------------------------|----------------------------|-------------------------------|------|--------------------------------------|
| Total Coliform Bacteria | 0 | 0 | 1 positive monthly sample (a) | 0 | Naturally present in the environment |
| Fecal Coliform and <i>E. coli</i> | 0 | 0 | 0 | None | Human and animal fecal waste |

(a) For systems collecting fewer than 40 samples per month: two or more positively monthly samples is a violation of the total coliform MCL

For violation of the total coliform MCL, include potential adverse health effects, and actions taken by water system to address the violation: [Enter information]

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

| Lead and Copper | Sample Date | No. of Samples Collected | 90 th Percentile Level Detected | No. Sites Exceeding AL | AL | PHG | No. of Schools Requesting Lead Sampling | Typical Source of Contaminant |
|-----------------|-------------|--------------------------|--|------------------------|-----|-----|---|---|
| Lead (ppm) | 8/24/23 | 5 | .0029 | 0 | 15 | 0.2 | 1 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm) | 8/24/23 | 5 | 0.112 | 0 | 1.3 | 0.3 | Not applicable | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

Table 3. Sampling Results for Sodium and Hardness

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|---|-------------|----------------|---------------------|------|------------|--|
| Sodium (ppm) | 6/2/20 | 458 | | None | None | Salt present in the water and is generally naturally occurring |
| Hardness (ppm) | 6/2/20 | 109 | | None | None | Sum of polyvalent cations present in the |

| | | | | | | |
|--|--|--|--|--|--|---|
| | | | | | | water, generally magnesium and calcium, and are usually naturally occurring |
|--|--|--|--|--|--|---|

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|--|--------------------|-----------------------|----------------------------|-------------------|---------------------------|---|
| Nitrate (ppm) | 6/3/24 | 1.79 | 1.99-2.24 | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion from natural deposits |
| Nitrite (ppm) | 4/30/24 | ND | | 1 | | Sewage and livestock manure, fertilizer use. |
| Arsenic (ppm) | 6/7/16 | ND | | 10 | | Erosion of natural deposits; runoff from orchards; glass and electronics production wastes |

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL | PHG (MCLG) | Typical Source of Contaminant |
|--|--------------------|-----------------------|----------------------------|-------------|-------------------|---|
| Total Dissolved Solids (TDS) (mg/L) | 6/7/16 | 151 | | 1000 mg/L | | Runoff/leaching from natural deposits |
| Chloride (mg/L) | 6/7/16 | 3.4 | | | | Runoff/leaching from natural deposits; seawater influence |

| | | | | | | |
|----------------|--------|------|--|--|--|--|
| Sulfate (mg/L) | 6/7/16 | 6.91 | | | | Runoff/leaching from natural deposits; industrial wastes |
|----------------|--------|------|--|--|--|--|

Table 6. Detection of Unregulated Contaminants

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | Notification Level | Health Effects |
|---|-------------|----------------|---------------------|--------------------|--|
| Manganese (ppm) | 6/2/20 | ND | | 500 | Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system. |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

State Revised Total Coliform Rule (RTCR): [Enter Additional Information Described in Instructions for SWS CCR Document]

For Water Systems Providing Groundwater as a Source of Drinking Water**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

| Microbiological Contaminants (complete if fecal-indicator detected) | Total No. of Detections | Sample Dates | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|---|-------------------------|--------------|------------|--------------------|-------------------------------|
| <i>E. coli</i> | 0 | | 0 | (0) | Human and animal fecal waste |
| Enterococci | 0 | | TT | N/A | Human and animal fecal waste |
| Coliphage | 0 | | TT | N/A | Human and animal fecal waste |

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

